


200 G.P.M. - DUAL DRIVE - 15 H.P.

need 6.5 ft on air line to
clear screen



ELL # 44


BALLOON BARRAGE WELL

"V" 44

BBWELL # 44

200 G.P.M. - DUAL DRIVE - 15 H.P.

need 6.5 ft on air line to
clean screen





DATE 13 Apr 2000

PWSID 0467047

WELL # BB-44

WELL NAME Courthouse Bay 44

BLDG. BB44

CODE Ground

AVAILABILITY Permanent

LOCATION Horn Road C4B

LATITUDE 34° 35 min 04 sec 166 N

LONGITUDE 077° 21 min 42 sec 268 W

WELL DIAMETER 8"

WELL DEPTH 62'

SCREEN INTERVAL 0 to 23' 8" pipe

32' to 62' 8" screen

YIELD 200 gpm

STATIC LEVEL 17'

PUMPING LEVEL 27'

PUMP TYPE verticle turbine

MOTOR HP 5

INTAKE DEPTH 40'

DESIGN CAPACITY 140 gpm

ACTUAL GPM 115

SIZE OF CONCRETE SLAB 76x6

HEIGHT OF CASING 32ft

11-101

11-101

83-451

**BANKCARD REQUEST
PUBLIC UTILITIES DIVISION
CAMP LEJEUNE, NORTH CAROLINA 28542**

SHOP 83	PHONE 451-7190 ext. 235/233	DATE 6-24-03
SHOP EMPLOYEE Doug Kopp	RDD 7-24-03	TICKET 0343675
JUSTIFICATION	BUILDING BB-44	PRIORITY
SUGGESTED SOURCE Charles R. Underwood, Inc.	VENDOR PC Pete Lowe	VENDOR PHONE 919-775-2463

QTY	U/I	MFR & P/N	NOMENCLATURE/DESCRIPTION	UNIT PRICE	TOTAL PRICE
1	EA	7CLO	Goulds model 4Stage with L Bowl Assen. w/2" Suction + 4" discharge Connections		
1	EA		4" SS Cone Type Strainer		
3	EA		4" x 10' Schedul 40 W/2 Column Pipe		
2	EA		4" x 5' Schedul 40 W/2 Column Pipe		
3	EA		1.1875" x 10' 416 SS Line shaft		
1	EA		1.1875" x 5' 416 SS Line shaft		
1	EA		1.1875" x 64" 416 SS Top shaft		

SHOP SUPERVISOR'S SIGNATURE: _____
SUBMISSION OF REQUEST CONSTITUTES VERIFICATION OF STOCKAGE OF ITEM(S) ON EXCESS LISTINGS

SHOP WILL RECEIVE A COPY OF 2035 AFTER BUY IS MADE


AC	FA	WC	FC	OC/SOC	CAC	BRC	JON	RON	RBC
M67001	23	83	AD	2607			E021		

*****TO BE COMPLETED BY SUPPLY ONLY*****

CALL#

JULIAN DATE

DOCUMENT NUMBER(S) ASSIGNED EACH ITEM ABOVE



83-451

**BANKCARD REQUEST
PUBLIC UTILITIES DIVISION
CAMP LEJEUNE, NORTH CAROLINA 28542**

SHOP 83	PHONE 451-7190 ext. 235/233	DATE 6-24-03
SHOP EMPLOYEE Doug Yopp	RDD 7-24-03	
JUSTIFICATION	TICKET 03-43675	
	BUILDING B33-44	
	PRIORITY	
SUGGESTED SOURCE Charles R. Underwood, Inc.	VENDOR PC Rate Lowe	
	VENDOR PHONE 919-775-2463	

QTY	U/I	MFR & P/N	NOMENCLATURE/DESCRIPTION	UNIT PRICE	TOTAL PRICE
4	EA		4" Bronze Bearing Retainers		
4	EA		1.1875" Rubber Bearings		
1	EA		1.1875" Packing Box Bearing		
1	EA		Set Packing		
			Total Cost		3914.60
			Estimated Freight		145.00
					4059.60

SHOP SUPERVISOR'S SIGNATURE: _____
SUBMISSION OF REQUEST CONSTITUTES VERIFICATION OF STOCKAGE OF ITEM(S) ON EXCESS LISTINGS

SHOP WILL RECEIVE A COPY OF 2035 AFTER BUY IS MADE

AC	FA	WC	FC	OC/SOC	CAC	BRC	JON	RON	RBC
M67001	23	83	AD	2607			E021		

*****TO BE COMPLETED BY SUPPLY ONLY*****

CALL# JULIAN DATE DOCUMENT NUMBER(S) ASSIGNED EACH ITEM ABOVE

12/10/54

12/10/54

12/10/54

12/10/54

12/10/54

12/10/54

12/10/54

12/10/54

12/10/54

12/10/54

12/10/54

12/10/54

Phone: 919-713-2463

Fax: 919-708-7232 THE SOURCE FOR PUMP SOLUTIONS

**Charles Underwood,
Inc.**

Fax

To: Ms. Robin

From: N. F. "Pete" Lowe

Fax-- 1-910-451-7195

Date: June 19, 2003

Phone:

Pages: Three

Pump Proposal


CC:

Urgent For Review Please Comment X Please Reply Please Recycle

Comments: Following hard proposal for the pump equipment you requested.

Hard copy to follow via mail.

Thanks !!!!!!!!!!!!!!! "Pete"



Charles R. Underwood, Inc.

Municipal Pump Sales & Service

2189 Fverett Dnwly Road
Sanford, North Carolina 27330Phone (919) 775-2463
Fax (919) 708-7232

June 19, 2003

Quote # 03132

Commanding General
Public Utilities Div. Bin 1
Water & Waste Water Sec. FC 440
MCH PSC Box 20004
Camp LeJeune, NC 28542-0004

Att: Mr. Doug Yopp

Ref: Well BB-44

Dear Mr. Yopp


We are pleased to offer the following proposal for the replacement pump you requested. This will be as follows.

Conditions: 130 GPM @ 95' TDH, 1770 RPM

- 1 ea. New Goulds Model 7CLO, 4 Stage W/L Bowl Assembly-with 4" Suction and 4" Discharge Connections.
- 1 ea. 4" Stainless Steel Cone Type Strainer
- 3 ea. 4" X 10' Schedule 40 W/L Column Pipe
- 2 ea. 4" X 5' Schedule 40 W/L Column Pipe
- 3 ea. 1.1875" X 10' 416 Stainless Steel Line Shaft
- 1 ea. 1.1875" X 5' 416 Stainless Steel Line Shaft
- 1 ea. 1.1875" X 64" 416 Stainless Steel Top Shaft
- 4 ea. 4" Bronze Bearing Retainers
- 4 ea. 1.1875" Rubber Bearings
- 1 ea. 1.1875" Packing Box Bearing
- 1 ea. Set packing

Your cost	\$3,914.60
Estimated freight	<u>145.00</u>
Total	\$4,059.60

Delivery would be 10-14 days after receipt of your order. Price does not include any taxes, anchor bolts, gauges or other accessories not listed above




After disassembly and inspection of the bowl removed from this well, it appears the bowl shaft was bent. It is difficult to determine if this occurred in shipping and handling or in the installation of this unit. The bowl shaft had .065" run out at the top of the shaft. This tolerance on a new pump is .002"-.004".


When you place the order for this material, please have your service crew send the packing box to us via UPS so we may install the new packing box bearing and packing.

Trust this meets with your approval. If you have any questions please give us a call.

Best regards,



N. F. "Pete" Lowe
General Manager



BANKCARD REQUEST
 BASE MAINTENANCE DIVISION
 CAMP LEJEUNE, NORTH CAROLINA 28542

84-227

HOP () PHONE 451-7190 EXT DATE 2-26-01
 SHOP EMPLOYEE Hill
 JUSTIFICATION To Replace well Pump
 TICKET
 BUILDING BB 44
 PRIORITY
 SUGGESTED SOURCE Charles Underwood Inc
 Sanford N.C.
 VENDOR POC Pete Lowe
 VENDOR PHONE (919) 775-2463

Quote # 01138

QTY	U/I	MFR & P/N	NOMENCLATURE/DESCRIPTION	UNIT PRICE	TOTAL PRICE
1	EA	7WAHC	Gould 4 stage bowl Assem.		
1	EA		4" GALVANIZED cone strainer		
1	EA		4" X 10' Suction P:pe		
2	EA		4" X 5' Top/Bottom column P:pe		
3	EA		4" X 10' Intermediate column P:pe		
2	EA		1.1875" X 5' 416 stainless Line shaft		
3	EA		1.1875" X 10' 416 SS Intermediate shaft		
4	EA		4" BRONZE BEARING Retainers		
4	EA		1.1875" Rubber Bearing		
1	EA		Gould 4X10 Type "A" Discharge head		
1	EA		1.1875" 416 SS motor shaft		
1	EA		1.1875" head shaft.		4,549.70
			" Sole Source only "		

HOP SUPERVISOR'S SIGNATURE D. HILL *D. Hill*


REMISSION OF REQUEST CONSTITUTES VERIFICATION OF STOCKAGE OF ITEM(S) ON EXCESS LISTINGS

SHOP WILL RECEIVE A COPY OF 2035 AFTER BUY IS MADE

AC	FA	WC	FC	OC/SOC	CAC	BRC	JON	RON	RBC
7001	23	83	RP	2607	EAE0		EAE0		

***** TO BE COMPLETED BY SUPPLY ONLY *****

JULIAN DATE DOCUMENT NUMBER(S) ASSIGNED EACH ITEM ABOVE



Charles R. Underwood, Inc.
Municipal Pump Sales & Service

2189 Everett Dowdy Road
Sanford, North Carolina 27330

Phone (919) 775-2463
Fax (919) 708-7232

February 15, 2001

Quote # 01138

Commanding General
Att: Base Maintenance Division
Bin 1-83 Marine Corps Base
PSC Box 20004
Camp LeJeune, NC 28542-0004

Att: Danny Hill/Stanley Miller

Ref: Well BB-44

Dear Mr. Hill/Miller


We are pleased to offer our proposal for the replacement pump in the above referenced well. This would be as follows.

Conditions: 120 GPM @ 110' TDH

- ✓ 1 ea. Goulds Model 7WAHC, 4 Stage, Water Lubricated bowl Assembly
- ✓ 1 ea. 4" Galvanized Cone Strainer
- 1 ea. 4" X 10' Suction Pipe
- ✓ 2 ea. 4" X 5' Top/Bottom Column Pipe
- ✓ 3 ea. 4" X 10' Intermediate Column Pipe
- ✓ 2 ea. 1.1875" X 5' 416 Stainless Steel Top/Bottom Line Shaft
- ✓ 3 ea. 1.1875" X 10' 416 Stainless Steel Intermediate Line Shaft
- ✓ 4 ea. 4" Bronze Bearing Retainers
- ✓ 4 ea. 1.1875" Rubber Bearings
- 1 ea. Goulds 4 X 10 Type "A" Discharge Head
- 1 ea. 1.1875" 416 Stainless Steel Motor Shaft
- 1 ea. 1.1875" Head Shaft Nut

Your cost \$4,549.70

We suggest you use the existing motor on the new pump. The new discharge head will require a 1" shim to make the discharge flange match with the existing piping. Price includes freight to your location. Delivery could be made in approximately 10 days to two weeks.



Phone: 919-775-2463

Fax: 919-708-7232

THE SOURCE FOR PUMP SOLUTIONS

**Charles Underwood,
Inc.**

Fax

To: Mr. Stanley Miller/Danny Hill **From:** N. F. "Pete" Lowe

Fax: 1-910-451-7195 **Date:** February 15, 2001

Phone: **Pages:** Eleven

Q: Well Pump - BB 44 **CC:**

Urgent **For Review** **Please Comment XPlease Reply** **Please Recycle**

•Comments Following quotation for the above pump equipment.


Hard copy to follow via mail.


Thanks !!!!!!!!!!!!!!!!!!!!!!!!!!!!!!! "Pete"

10-10-10

Trust this meets with your approval. If you have any questions please give us a call.

Best regards,


N. F. "Pete" Lowe
General Manager



Charles Underwood, Inc.
N.F. "Pete" Lowe
Camp LeJeune, Well BB-44

Goulds Turbine Pump Selection ver. 6.042
02/14/01

PUMP DATA SHEET
Goulds Turbine 60 Hz

Selection file: (untitled)
Catalog: TURB60.MPC v 1.6.1

Curve: E6407WAPCO

Design Point: Flow: 120 US gpm
Head: 110 ft

Fluid: Water Temperature: 60 °F
SG: 1

Pump: TURBINE - 1800 Size: 7WAHC; (4 stages)
Speed: 1770 rpm Dia: 5.1875 in

Viscosity: 1.122 cP
Vapor pressure: 0.2568 psi_a
Atm pressure: 14.7 psi_a

Limits: Temperature: --- °F Sphere size: 0.29 in
Pressure: 365 psi_g Power: --- bhp

NPSHa: --- ft

Specific Speed: Ns: 1684 Nss: ---

Piping: System: ---
Suction: --- in
Discharge: --- in

Vertical Turbine: Bowl Size: 7.13 in Max Lateral: 0.5 in
Thrust K Factor: 2.63


Motor: 5 hp Speed: 1800 Frame: 184T
NEMA Standard ODP Enclosure
sized for Max Power on Design Curve

Suction Size-4" Discharge Sizes-4",5",6"

--- Data Point ---
Flow: 120 US gpm
Head: 111 ft
Eff: 78.7%
Power: 4.29 bhp
NPSHr: 3.38 ft

-- Design Curve --
Shutoff Head: 126 ft
Shutoff dP: 54.5 psi
Min Flow: - US gpm
BEP: 79.3% eff
@ 135 US gpm
NOL Pwr: 4.72 bhp
@ 150 US gpm


-- Max Curve --
Max Pwr: 5.46 bhp
@ 159 US gpm



--- PERFORMANCE EVALUATION ---

Flow	Speed	Head	Pump	Power	NPSHr	Motor	Motor	Hrs/yr	Cost
US gpm	rpm	ft	%eff	bhp	ft	%eff	kW		/kWh
120	1770	111	78.7	4.29	3.38	86.2	3.71	1500	0.08
96	1770	118	75.7	3.76	2.59	86.2	3.25	3000	0.08
72	1770	121	67.6	3.25	2	86.3	2.81	1000	0.06

Total Annual Power Consumption: 18,131 kWh
Annual Operating Cost: \$1,394






GOULDS TURBINE HYDRAULIC ANALYSIS of DWT-CATM PUMP

Date: 02-14-2001
4 Stage 4x7WAHC



Pump Data

AD:	0.75	Size:	7WAHC
AG:	21.25	Stages:	4
BD:	10.00	Impellers:	Bronze
BL:	30.50	Bowl:	Cast Iron
CAN:	0	Bearing:	Rubber
CD:	17.56	Basket:	No
CL:	0	LineShaft Type:	Open
COL:	480.00	Column:	Steel
DD:	9.00	Column:	4" Threaded
DH:	5.00	Bearing Spacing:	10 feet
G:	16.50	Section Length:	
H:	14.00	Head:	A:Cast
HH:	13.50	Flange (Disch.):	4" 125#
J:	0.63	Inlet:	
R:	7.50	Coupling:	416SS
S:	1.81	Seal:	Packing
SL:	12.00	LineShaft:	416SS 1.19"
TPL:	522.50	SubBase:	Other
UG:	0		
V:	0.75		
W:	18.00		
X:	16.00		
XC:	3.34		
Y:	0.63		
Z:	12.00		



Hydraulic Data

Flow (gpm):	120
Pump Head (ft):	80.9
TDH (ft):	111.0
Speed (rpm):	1770
Fluid:	Water
Temperature (F):	60
Viscosity:	1.122
Spec. Grav:	1

Miscellaneous


Thrust At Design:	449
Thrust At Shutoff:	489
Min Water Level(in):	348

Weight

Pump:	1020
Motor:	120
Total:	1140

Motor Data

Model Number:	6968
Make:	USEM
HP:	5
RPM:	1800
Type:	TU
Efficiency:	82.5
Frame:	184TP
Ratchet:	NRR



GOULDS TURBINE HYDRAULIC ANALYSIS of DWT-CATM PUMPDate: 02-14-2001
4 Stage 4x7WAHC**Overall Pump Parameters**

Size and Model:	7WAHC	Pump Operating Speed, RPM:	1770
Capacity, GPM:	120	Total Dynamic Head, Ft.:	111
Total Pump Length, In.:	522.5	Impeller Trim, In.:	5.1875
Pump Type:	OpenSump	Head Type:	A:Cast
Pump K-Factor:	2.63	Number of Stages:	4
		Pumping Level, In.:	348.0

LineShaft-Related Data

Shaft Diameter, In.:	1.19	Shaft Limit, HP:	126
Shaft Material:	416SS	Matl Correction Fact:	1.18
LineShaft Length, In.:	480.00	Shaft Elongation, w/o Adder:	0.00
		LineShaft Type:	Open

Bowl Data

Total Bowl Length, In.:	30.50	Bowl Diameter, In.:	7.125
		Bowl Shaft Limit, HP:	125

Column Data

Column Diameter, In.:	4	Column Load, Lb.:	104.5
Wall Thickness, In.:	Standard	Column Elongation, In.:	0.00

HorsePower Data

Shaft Friction Loss, Hp.:	0.29	Thrust Load Loss, Hp.:	0.06
Bowl HP At Design, Hp.:	4.29	Motor HorsePower, Hp.:	5

Head Data

Column Loss, Ft.:	0.95	Discharge Head Loss, Ft.:	0.11
		Total Loss, Ft.:	1.06

Other Data


Hydraulic Thrust, Lb.:	291.9	Thrust at Design, Lb.:	449.0
Thrust at Shutoff, Lb.:	488.5	Design NPSH, Ft.:	3.38
Max Lateral, In.:	0.5	Min. Lateral Required, In.:	0.13
		Actual Head above Grade, Ft.:	80.94

Efficiency Data

Bowl Efficiency:	78.70	Pump Efficiency:	72.77
Motor Efficiency:	82.50	Overall Efficiency:	60.04
		KWH/1000 gallons:	0.58

Component Weights

Bowl Weight, Lbs.:	150	Column Weight, Lbs.:	720
Head Weight, Lbs.:	150	Can Weight, Lbs.:	0
Motor Weight, Lbs.:	120	Total Pump Weight, Lbs.:	1140



HP Hadnot Point

○ new holes

Sneeds Ferry
Sonic South

HP

637 ✓ no lithology

642 ✓ x 652 ✓ (611) (612)

606 ✓

609 ✓

concord

628 ✓ x 638 ✓ no lith

661 no DATA

662 no DATA

Mass Rd

640

632

(595)

Firetower

(596)

South Rd

BB - Courthouse Bay

~~HWY 122~~

BB 220

BB 221 BB 218 NW + NW

BB 44

BB 47



~~Omslow Beach~~


~~BA 145~~

~~BA 164~~

~~BA 190~~

Lithology

Resistivity logs
Gamma logs




WELL NUMBER <u>BB 44</u>		BY <u>SALAS</u>			DATE <u>4-17-02</u>	
AIR LINE	STATIC LEVEL	PUMPING LEVEL	DRAIN DOWN	DISCHARGE PRESSURE	GPM	START TIME
<u>40</u>	<u>15</u>	<u>20</u>	<u>05</u>	<u>25</u>	<u>120</u>	<u>05</u>
		<u>22</u>	<u>07</u>	<u>20</u>	<u>108</u>	<u>15</u>
		<u>25</u>	<u>10</u>	<u>15</u>	<u>115</u>	<u>25</u>
		<u>25</u>	<u>10</u>	<u>10</u>	<u>128</u>	<u>35</u>
		<u>25</u>	<u>06</u>	<u>05</u>	<u>130</u>	<u>45</u>

REMARKS

D/H - 35

NOTE: pressure will not set @ less than 40 PSI.

MANUFACTURER	STAGE	S.N.	TOTAL HEAD	SIZE



WELL NUMBER	BY			DATE		
AIR LINE	STATIC LEVEL	PUMPING LEVEL	DRAIN DOWN	DISCHARGE PRESSURE	GPM	START TIME
40	15	25	8	22	100	10
		28	12	18	115	20
		30	15	15	128	30
	SET AT ⇒	30	10	10	140	

REMARKS


D/H-38


TOOK BAC-T SAMPLE 11:45 9/22/03
by JOE S.


MANUFACTURER	STAGE	S.N.	TOTAL HEAD	SIZE


31
41


29















BB 44

10-23-85

A/L	S/L	R/L	D/O	PSI	CPM	Time
42	16	27	11	23	104	15
		32	16	18	128	15





SOURCE INFORMATION GROUND WATER

Date Form Completed

M M D D Y Y
 0 1 2 5 9 5

PWSID
 0 4 6 7 0 4 7

Owner Assigned source Code Well Name (if purchase, name of system)

44 COURTHOUSE BAY ~~BB~~ 44

Code G=Ground W=Purchase/G Y=G w/direct influence Z=W w/direct influence

G

If Purchase, seller ID# Source Begin Date Source exempt-SWIR? Direct Influence Date Availability

Source Begin Date: M M Y Y
 Source exempt-SWIR? Y N
 Direct Influence Date: M M D D Y Y
 Availability: P Permanent E Emergency S Seasonal I Interim O Other

Location of well within the system (if purchase, location of master meter)

HORN ROAD CHB

Latitude (N) Longitude (W) How Determined GPS Data No. of Sats. Locked on

Latitude (N): Deg. Min. Sec. 3 4 3 5 0 4
 Longitude (W): Deg. Min. Sec. 0 7 7 2 1 4 3
 How Determined: G GPS M Map S Surveyed
 GPS Data: Q# or DOP #
 No. of Sats. Locked on:

(If purchase, use seller's primary source lat/long)

Vulnerable (VOCs) Y N Assessment Date: M M D D Y Y

ENTRY POINT INFORMATION

Owner Assigned Entry Point Code

600

Entry Point Name

~~BB~~ MCB COURTHOUSE BAY [w/TP]

Use Code C=Ground/Permanent D=Ground/non-permanent Availability P=Year-round E=Emergency S=Seasonal I=Interim O=Other

C

P

Location:

Well Site: Owned or controlled? Y (Y,N) Control Area (100' radius)? N (Y,N) If no, explain: _____

Sources of pollution/distance: Road @ 60'

Surface water within 200'? Y N If yes, actual distance _____ feet If yes, bact. samples collected? _____ (Y,N)

Adequate slope? Y (Y,N) Flooding? N (Y,N) Maintenance: OK

Well House: Free of stored materials? Y (Y,N) Properly drained? Y (Y,N) Locked? Y (Y,N)

Condition of house: OK Type of freeze protection: NONE

Well: Diameter: 8" Type: GRAVEL PACKED Yield (gpm): 200-400 Properly sealed? Y (Y,N)

Properly vented? N (Y,N) Casing depth 32 ft. (If unknown, put 'UNK') Well depth: 62 Meter available? N (Y,N) Size: 2626

Concrete slab adequate? _____ (Y,N) If no, explain: _____
 Size of blow-off: 4" Sample tap: Before treatment? Y (Y,N) After treatment? _____ (Y,N)

Pumps: Capacity: GPM: 200-140 HP: 5 Pump intake depth: 40 Auxiliary Power? N (Y,N)
 Type pump: VERTICAL TURBINE Height above floor (pump/casing): 14 1/2"

Storage at well site: Elev: _____ Hydro: _____ Ground: _____

If hydroautomatic, air volume control? _____ (Y,N) Safety valves? _____ (Y,N) Coded? _____ (Y,N)


High service pumps: 1. _____ gpm _____ hp 2. _____ gpm _____ hp 3. _____ gpm _____ hp Auxiliary Power? _____ (Y,N)

Is the water treated at this well? Y N If yes, complete back of form.

If other wells are treated here, which ones? _____ If treated elsewhere, where? CHB PLANT

If purchase, retreat? Y N If yes, complete back of form.

- ① no vent
- ② no meter
- ③ leaking valve



Well depth 62'10"
pump depth 4'
air line 42"
W level 16'

out. in
10-1-73 1028-73

Well blowed. 10-2-73 sand.

BB 44


Johnston

4"


4 stage



DATE	WELL #	DISCHARGE PRESSURE	GAGE READING STATIC	PUMPING LEVEL FT GAGE READING	FT DRAW DOWN	G.P.M.
4-15-63	BB-44	60	10 ² FT.			159
"	"	55	Air Line Broken			170
"	"	52				175
"	"	50				183
"	"	48				185
"	"	45				192



DATE	WELL #	DISCHARGE PRESS	GAGE READING STATIC	PUMPING LEVEL GAGE READING	DD-FT.	GPM
4-15-63	WB-43	60	32 FT	21 FT	7 FT	130
"	"	55'	—	24 "	8 FT	151
"	"	52	—	23 "	9 "	159
"	"	50	—	22 "	10 "	167
"	"	48	—	21 "	11 "	172
"	"	45'	—	20 "	12 "	180



Water level

16 ft from pump
base

42' air line

GPM 200

Depth 62' 10"

Gray sand

4 stage.

rev imp shaft

out 10/1/73

in 10/3/73

J BB 44 10/4/73
GA 4204

7CC

5 $\frac{1}{4}$
4-stage

8/22/68

Johnston

4''

40 setting
10 tail

4ft imp unit

Tank full at 48#

(6-6-67)

pumping at 49#

200 GPM @ -12.2
AIR LINE

BB-44	STATIC ?	PUMP LEVEL ?	P.D. ?	LINE PRES.	HEAD SHUT OFF 91#	G.P.M.	S.L. ELEV.
				53		172	
				45		195	
				40		205	
				43		201	
				48		192	
				51		178	✓
				55		170	
				58		159	
				60		154	
63#	air line +32.6 67.4 -35.3						
	48	17	31	12	27*	104	-18.3
		15	33	10		111	-20.3
		14	34	8		115	-21.3
		13	35	6		119	-22.3
		12	36	4		122	-23.3
		10	38	0		133	-25.3

$$\begin{array}{r}
 2.31 \\
 48 \\
 \hline
 1848 \\
 924 \\
 \hline
 110.88
 \end{array}$$



April - 15, 1963

CHB WELL 44 LINE PRESSURE 52 lb.

DD	DPM	Gauge PRE	in.
	159	60	14 $\frac{1}{2}$
	170	55	16 $\frac{1}{2}$
	175	52	17 $\frac{1}{2}$
	183	50	19
	185	48	19 $\frac{1}{2}$
	192	45	21

CHB WELL 43 LINE PRESSURE 51

DD	DPM	Gauge PRE	in.	ST LEVEL
25	130	60	9 $\frac{1}{2}$	32 ft
24	151	55	13	
23	159	52	14 $\frac{1}{2}$	
22	167	50	16	
21	172	48	17	
20	180	45	18 $\frac{1}{2}$	



10/2/21

TO MORRIS

3-24-65

~~WELL: CAP.~~

~~BB = #43 + 44~~

~~A-5~~

BB.43 WELL. W

150. GPM.

BB.44 WELL. V.


~~100~~²⁰⁰ GPM.

A-5. WELL V.

250 GPM

Well #43 near Plant

10-15-71 cleaned



U.S. DEPARTMENT OF THE INTERIOR
GEOLOGICAL SURVEY
OFFICE OF WATER DATA COORDINATION
INVENTORY OF HYDROLOGIC DATA STATIONS
QUALITY OF WATER

APPROVED.
Budget Bureau No. 42-R1485
Approval Expires June 30, 1968

1. AGENCY CODE MC	2. TYPE Q	3. LATITUDE ° 34 ' 35 " 04 N	4. LONGITUDE ° 77 ' 21 " 43 W	5.
-----------------------------	---------------------	--	---	----

6. AGENCY STATION NO. BB44	7. STATION NAME BB44-W
--------------------------------------	----------------------------------

8. DRAINAGE BASIN CODE No. 6 Letter N	9. STATE CODE 32	10. COUNTY CODE 133	11. COUNTY NAME ONslow
--	----------------------------	-------------------------------	----------------------------------

12. PERIOD OF RECORD Began 1942 Discontinued	Y <input type="checkbox"/> Continuous <input type="checkbox"/> Interruption Exceeds 1 Year	13.	14.
--	---	-----	-----

15. SITE	<input type="checkbox"/> 101 Stream	<input type="checkbox"/> 102 Canal	<input type="checkbox"/> 103 Lake	<input type="checkbox"/> 104 Reservoir	<input type="checkbox"/> 105 Estuary	<input type="checkbox"/> 106 Spring	<input checked="" type="checkbox"/> 107 Well	<input type="checkbox"/> 110 Other
----------	-------------------------------------	------------------------------------	-----------------------------------	--	--------------------------------------	-------------------------------------	--	------------------------------------

16. FREQUENCY OF MEASUREMENT	<input type="checkbox"/> 201 Continuous Recorder	<input type="checkbox"/> 202 Telemetered	<input type="checkbox"/> 203 Daily	<input type="checkbox"/> 204 Weekly	<input type="checkbox"/> 205 Monthly	<input type="checkbox"/> 206 Quarterly	<input type="checkbox"/> 207 Seasonal	<input type="checkbox"/> 208 Annual	<input type="checkbox"/> 209 Other Periodic	<input checked="" type="checkbox"/> 210 Occasional
------------------------------	--	--	------------------------------------	-------------------------------------	--------------------------------------	--	---------------------------------------	-------------------------------------	---	--

17. TYPES OF DATA AVAILABLE	<i>Physical</i>	<i>Chemical</i>	<i>Organic</i>
	<input type="checkbox"/> 311 Temperature	<input type="checkbox"/> 331 Dissolved solids	<input type="checkbox"/> 351 Pesticides (insecticides, herbicides, etc.)
	<input type="checkbox"/> 312 Specific Conductance	<input checked="" type="checkbox"/> 332 Chlorides Only	<input type="checkbox"/> 352 Synthetic detergents
	<input type="checkbox"/> 313 Turbidity	<input type="checkbox"/> 333 Nutrients (Nitrogen and phosphorus compounds)	<input type="checkbox"/> 353 Other
	<input type="checkbox"/> 314 Color		<i>Biologic</i>
	<input type="checkbox"/> 315 Odor	<input type="checkbox"/> 334 Common ions	<input type="checkbox"/> 361 Coliforms
	<input type="checkbox"/> 316 Radioactivity	<input type="checkbox"/> 335 Hardness	<input type="checkbox"/> 362 Other Micro-organisms
	<input type="checkbox"/> 317 pH (field)	<input type="checkbox"/> 336 Radiochemical	<input type="checkbox"/> 363 BOD
	<input checked="" type="checkbox"/> 318 pH (lab)	<input type="checkbox"/> 337 Dissolved oxygen	<input type="checkbox"/> 364 Other
	<input type="checkbox"/> 319 Eh	<input type="checkbox"/> 338 Other Gases	<i>Sediment</i>
	<input type="checkbox"/> 320 Other	<input type="checkbox"/> 339 Other	<input type="checkbox"/> 371 Concentration
			<input type="checkbox"/> 372 Particle size
			<input type="checkbox"/> 373 Other

18. SUPPLEMENTARY DATA FOR SITE	<input type="checkbox"/> 421 Surface Water Station	<input type="checkbox"/> 422 Ground Water Station	<input type="checkbox"/> 423 Water Stage or Level	<input checked="" type="checkbox"/> 424 Water discharge	<input type="checkbox"/> 425 Time of Travel	<input type="checkbox"/> 426 Drainage Area
---------------------------------	--	---	---	---	---	--

19. STORAGE OF DATA	<input type="checkbox"/> 501 Periodic Report	<input type="checkbox"/> 502 Areal Report	<input checked="" type="checkbox"/> 503 Not Published	<input type="checkbox"/> 504 Data on Punchcard	<input type="checkbox"/> 505 Data on Magnetic Tape	<input type="checkbox"/> 506 Other
---------------------	--	---	---	--	--	------------------------------------

20. OFFICE AT WHICH DATA AVAILABLE	Office <u>BASE MAINTENANCE DEPARTMENT, UTILITIES DIVISION</u>
Street No. <u>MARINE CORPS BASE</u>	City Code
City, State, Zip <u>CAMP LEJEUNE, N. C. 28542</u>	<u>0735</u>

21. OFFICE COMPLETING FORM <u>BASE MAINTENANCE DEPARTMENT</u>
--

22. COMPILER'S NAME	23. DATE Month <u>04</u> Year <u>1966</u>
---------------------	--



WATER ANALYSIS

By N.H. Kellan

Date 3-19-42

Sample from Well No. 1 Ballon Barrage
62' Deep 40 hrs Pumping

Total Solids 180 PPM Dissolved Solids 150 PPM

Suspended Solids 30 PPM Volatile Solids _____ PPM

Phenol. Alk. as CaCO₃ 0 PPM Silica as SiO₂ 35 PPM

Total Alk. " " 124 " Ferrous Iron as Fe 0 "

Carbonates " " 0 " Total Iron as Fe 0.4 "

Bicarbonates " " 124 " Aluminum as Al. 2.9 "

Chlorides as Cl. 18 " Calcium as Ca. 51.8 "

Sulphates as SO₄ 7 " Magnesium as Mg. 2.6 "

Nitrites as NO₂ 0 " Sodium as Na. Trace "

Carbon Dioxide as CO₂ 0 "

pH 7.8 Soap Hardness as CaCO₃ 140 PPM

Odor Very slight Turbidity 20

REMARKS _____

WATER ANALYSIS

By _____

Date _____

Sample from _____

Total Solids _____ PPM Dissolved Solids _____ PPM

Suspended Solids _____ PPM Volatile Solids _____ PPM

Hardness as CaCO₃ _____ PPM Silicon as SiO₂ _____ PPM

Total Alkalinity _____ PPM Ferrous Iron as Fe _____ PPM

Total Iron as Fe _____ PPM Chlorides as Cl _____ PPM

Hardness as CaCO₃ _____ PPM Aluminum as Al _____ PPM

Hardness as CaCO₃ _____ PPM Calcium as Ca _____ PPM

Hardness as CaCO₃ _____ PPM Magnesium as Mg _____ PPM

Hardness as CaCO₃ _____ PPM Sodium as Na _____ PPM

Hardness as CaCO₃ _____ PPM Carbon Dioxide as CO₂ _____ PPM

Hardness as CaCO₃ _____ PPM Total Hardness as CaCO₃ _____ PPM

Hardness as CaCO₃ _____ PPM Turbidity _____

Hardness as CaCO₃ _____ PPM _____

Hardness as CaCO₃ _____ PPM _____

Hardness as CaCO₃ _____ PPM _____

Hardness as CaCO₃ _____ PPM _____

Hardness as CaCO₃ _____ PPM _____

43-60/DRB/arc
N62470-68-B-0020/
NBy-88313
11 March 1970

Resident Officer in Charge of Construction,
Jacksonville, North Carolina Area

Base Maintenance Officer (Att: Dir of Utilities, Mr. Herndon)

Contract N62470-68-B-0020/NBy-88313, Water Treatment Plant, Courthouse
Bay, MCB, Camp Lejeune, N. C.

Ref: (a) Memo from Mr. W. R. PRICE dtd 9 Feb 1970

1. Reference (a) requested the length of air lines on wells #43 and #44. This length is 40 feet.
2. Reference (a) also noted several deficiencies on the subject contract. As of this date items 2 through 6 have been repaired and action is being taken to repair items 1 and 7.

D. R. BROSMAN
By direction

1944
1945
1946

1947
1948
1949

1950
1951
1952

1953
1954
1955

1956
1957
1958

1959
1960
1961


1962
1963
1964

1965
1966

JOHNSTON VERTICAL TURBINE PUMP

← 5/8 " DIA. HOLES ON 5 7/8 " B.C.

4 " x 125 " ASA DISCHARGE FLANGE



CONDITIONS:

U.S. GALLONS PER MINUTE— 190
 TOTAL DYNAMIC HEAD IN FT.— 60
 LIQUID— WATER
 SPEC. GRAV. 1:0 @ °F. TEMP.

G.E. OR EQUAL
 VERTICAL HOLLOW SHAFT MOTOR
 HP— 5 PHASE— 3 CYCLE— 60
 VOLTAGE— 208 RPM— 1760
 ENCLOSURE— DRIPPROOF

TYPE "A" DISCHARGE HEAD— 10 x 4

COLUMN ASSEMBLY— 4 x 2 x 3/16

BOWL ASSEMBLY— 4 STAGE 7CC

SUCTION PIPE & CONE STRAINER— 4"

CUSTOMER

PO#


DEALER HARTSFIELD WATER, CO

PO#

JOHNSTON SERIAL NO.

JOHNSTON QUOTATION NO. A 417

NOTE: DO NOT USE FOR CONSTRUCTION
 UNLESS CERTIFIED



WELL NO. 44

JOHNSTON PUMP CO.
 GLENDORA, CALIFORNIA

H-1253-A

1108371

OFFICE OF THE
OFFICER IN CHARGE OF CONSTRUCTION
CAMP LEJEUNE, NORTH CAROLINA

APPROVED


SUBJECT TO CONTRACT REQUIREMENTS
CONTRACT NBy 88313 SPEC. NO. 88313/67

DATE: 3 July 1968

J.W.
J. W. UPDEGROVE
CAPT. CEC, USN
Officer in Charge
of Construction

JOHNSTON PUMP Co. A417

WELL NO 44



FEET TOTAL DYNAMIC HEAD

FEET N.P.S.H. REQUIRED
@ SUCTION IMPELLER

PAGE 55 APRIL 6, 1964

BRAKE HORSEPOWER

PERFORMANCE BASED ON MULTISTAGE TESTS
PUMPING CLEAR COLD WATER SP. GR. 1.0

FOR 1 STAGE MULTIPLY HEAD & EFF. BY 0.95
FOR 2 STAGES MULTIPLY HD. & EFF. BY 0.98

DATE 1-2-64

U.S. GALLONS PER MINUTE



JOHNSTON PUMP COMPANY
Pasadena, California
ESTABLISHED 1909

7 CC TURBINE PUMP 1760 R.P.M.
IMPELLER — BRONZE BOWL — CAST IRON

4 STAGE

CURVE SHEET NO.
9682


OFFICE OF THE
OFFICER IN CHARGE OF CONSTRUCTION
CAMP LEJEUNE, NORTH CAROLINA

APPROVED

SUBJECT TO CONTRACT REQUIREMENTS
CONTRACT NBy 88313 SPEC. NO. 88313/67
DATE: 3 July 1968

J.W.
J. W. UPDEGROVE
CAPT. CEC, USN
Officer in Charge
of Construction

647087-3



0 GPM 100 120 140 160 180 200 220 240 260
 5 MINUTES 5 10 15 20 25 30

CAMP LEJEUNE

WELL V

FEB. 26, 1957


DATA SHEETS

SPEC # 3885

NO. 700-10

CHARLES BRUNING COMPANY, INC.
10 x 10 to the inch.
PRINTED IN U. S. A.

COURTHOUSE Bay



HYDRAULIC PERFORMANCE IS CONTINGENT ON WELL FINISHING WITH CLEAR, FRESH NON-AERATED OR NON-GASEOUS WATER FREE FROM DETRITUS WITH NO SUCTION LIFT AND TEMPERATURE NOT TO EXCEED 88 DEGREES FAHRENHEIT

NOTE: ALL COLUMN LOSSES ARE INCLUDED

CUSTOMER: _____

P.O.# _____




DEALER: HEATER WELL

P.O.# _____

JOHNSTON SERIAL: _____

Pump # V

CHANGE EFFICIENCY AS FOLLOWS	NUMBER OF POINTS	FOR NUMBER OF STAGES
NOTE: ANY CHANGE IN EFFICIENCY CHANGES EITHER THE HEAD OR HORSEPOWER IN PROPORTION		



IMPELLER Bez.
5 3/32" DIA.
DATE: 3-21 BY: JDM

JOHNSTON PUMP CO.
VERTICAL PUMPS
JOHNSTON
PASADENA • CALIFORNIA • USA

PERFORMANCE 10 STAGE
7CC DEEP WELL TURBINE PUMP
1800 R. P. M.
CURVE SHEET No. _____

697001-9

HORSE POWER

PUBLIC WORKS DEPARTMENT
CAMP LEJEUNE, NORTH CAROLINA

APPROVED

SUBJECT TO CONTRACT REQUIREMENTS

CONTRACT NO. 3885 SPEC. NO. 3885/56


TITLE Repair to Well Pump

DATE: 3-27-57 H. J. Evans, Jr.

BY DIRECTION OF OFFICER
IN CHARGE OF CONSTRUCTION

JB


JOHNSTON VERTICAL TURBINE PUMP



Furnished By Others
 VERTICAL HOLLOW SHAFT MOTOR

HP	PHASE	CYCLE
	VOLT	RPM
		ENCLOSURE

Furnished By Others
 TYPE "A" DISCHARGE HEAD
 " X 125# FLANGE



5" x 2" x 1 3/16" BWI
 COLUMN ASSEMBLY

10 STAGE 7CC BOWL ASSEMBLY

CONDITIONS:
 200 USGPM
 160 FT. TOTAL HEAD
 LIQUID WATER
 SPEC. GRAV. 1.0 @ °F PUMPING TEMP.

5" SUCTION PIPE 5" CONE STRAINER

CUSTOMER _____
 PC# _____
 DEALER **HEATER Well Co**
 PO# _____
 JOHNSTON SERIAL # _____
 JOHNSTON QUOTATION # _____

NOTE: DO NOT USE FOR CONSTRUCTION
 UNLESS CERTIFIED

Pump # V

PUBLIC WORKS DEPARTMENT
CAMP LEJEUNE, NORTH CAROLINA

APPROVED

As Noted

SUBJECT TO CONTRACT REQUIREMENTS

CONTRACT NO. 3885 SPEC. NO. 3885/6

TITLE Repairs of Well Pumps

DATE: 3-27-57 *H. F. Edwards, Jr.*

BY DIRECTION OF OFFICER
IN CHARGE OF CONSTRUCTION *AB*

WELL #

PLACE - Courthouse Bay

DATE - 28 Feb 1957

ORIGINAL WELL CAPACITY G.P.M. 200

ORIGINAL WELL		TESTING	
Depth of Well	62	Depth after Cleaning	62.8
Pump Size		Test Pump Setting	40
Pump Setting	35	Measured Static Water Level	15.8
Static Water Level	2.8	Depth of Air Line	40

Static on gauge 17' 0"

CONDITION OF WELL - Cleaned 18" of sand out of well.

STATIC LEVEL ON GAUGE

Inches of water in dizometer tube	G.P.M.	30 Min.	45 Min.	60 Min.	1 Hour
	100	PL	PL	PL	PL 20
	120	PL	PL	PL	PL 23.5
	140	PL	PL	PL	PL 24.5
	160	PL	PL	PL	PL 25.5
	180	PL	PL	PL	PL 26.5
	200	PL	PL	PL	PL 27.5
	220	PL	PL	PL	PL 29
		PL	PL	PL	PL
		PL	PL	PL	PL
		PL	PL	PL	PL
		PL	PL	PL	PL

RECOVERY	
10 Sec.	23
20 PL	23
30 PL	22.5
40 PL	22.5
50 PL	22
60 PL	22
2 Min. PL	21.5
4 PL	21.5
8 PL	21
16 PL	20
32 PL	19.5

44


Well # V-CHB

Date	Line Ft.	G.P.M.	D.D. El. FT	Static El. FT	Shut off Head FT	D.D. Ft.
6-1-53	150	150	AIRLINE	STOPPED UP.	188	
"	125	200				
"	117	245				
"	68	285				

NEW JOHNSTON PUMP - BY HEATER.
 PUT IN OPERATION.

7-20-62	³⁵ 55LB.	180	7' GAGE READING.			
"	50LB	197	6' " "			
"	45LB	205'	5' " "			

Air Line new - 3-21-57 - 60'-0" 40'



Test run on No. 44 Well
at Courthouse Bay.

Date. 8/21/47.

Head P. 50, G.P.M. 229

Date. 1/6/50

Head P. 50, G.P.M. 133

LETTER ON TO...
AT... ..

Date: 1/21/87
Head: 1. 50
D.H.M. 98

Date: 1/21/80
Head: 1. 50
D.H.M. 100

44

Marine Barracks
New River, N. C.
March 25, 1942

Well: Permanent Water Supply at Balloon Barrage

By Layne Atlantic Company

Report on Well No. 1 or Well V at Balloon Barrage

Location: 65 feet east of center line of new Access Road to Balloon Barrage
at Station 2350.

Date Drilled: March 1942

Status: Ground elevation 17.79
A 17 $\frac{1}{2}$ " hole drilled to a depth of 32 feet. This was reamed to
23 inches in diameter to a depth of 30 feet. 29 feet of 18 inch
I.D. Steel casing set and the annular space around pipe filled
with cement grout to ground level. A 17 inch hole was then
drilled to a depth of 69 feet.

Log of Formation:	0 to 1'6"	Black top soil
	1'6" to 31'	Very fine yellow sand, (Funs bad)
	31' to 69'	Soft shell rock and sand in layers

Due to the sand mixed with the coguina rock,
it was necessary to construct a well of
gravel wall construction.

Gravel Wall Construction: 32 feet of 8 inch pipe and 30 feet of silician bronze shutter
screen with cement plug was lowered into the well. The annular
space around this was filled with a special $\frac{1}{4}$ inch gravel.

Log of Screen setting:	0 to 32'	8" Pipe
	32' to 62'	8" Screen

Static Water Level: 10 feet from surface

1942
1943
1944

14

... ..
... ..
... ..
... ..

... ..
... ..
... ..
... ..

... ..
... ..
... ..

... ..
... ..
... ..
... ..

... ..
... ..
... ..

... ..
... ..
... ..

Pumping: Well pumps 460 G.P.M. with a 45 foot draw down below static level, after 40 hours pumping. This is approximately 10.2 gallons per foot of draw down. Pumps 350 gallons per minute with a 35 foot draw down from static level. This is approximately 10 gallons per foot of draw down.

Further pumping test will be made after the deep well turbin pumps are set.

See separate report for chemical analysis.

N. H. Kellam
Asst. Chem. Eng.

Faint, illegible text at the top of the page, possibly a header or title area.

A single line of faint, illegible text in the middle of the page.

A small block of faint, illegible text located in the lower-middle section of the page.

WATER ANALYSIS

By N. H. Kellam

Date 3-11-42

Sample from Test Well No. 1 Ballou Barrage
60' Deep 18 hrs Pumping

Total Solids _____ PPM Dissolved Solids _____ PPM

Suspended Solids _____ PPM Volatile Solids _____ PPM

Phenol. Alk. as CaCO₃ 0 PPM Silica as SiO₂ _____ PPM

Total Alk. " " 180 " Ferrous Iron as Fe _____ "

Carbonates " " 0 " Total Iron as Fe _____ "

Bicarbonates " " 180 " Aluminum as Al. _____ "

Chlorides as Cl. 20 " Calcium as Ca. _____ "

Sulphates as SO₄ _____ " Magnesium as Mg. _____ "

Nitrites as NO₂ _____ " Sodium as Na. _____ "

Carbon Dioxide as CO₂ 0 "

pH 7.7 Soap Hardness as CaCO₃ 130 PPM

Odor Slight Turbidity 15

REMARKS _____

WATER ANALYSIS

Sample from _____
Date _____

Total Solids _____ PPM
Suspended Solids _____ PPM
Dissolved Solids _____ PPM

Phosphorus as PO_4 _____ PPM
Total Alk. " " _____
Carbonates " " _____
Bicarbonates " " _____
Chlorides as Cl _____
Sulfates as SO_4 _____
Nitrates as NO_3 _____
Carbon Dioxide as CO_2 _____

Hardness as $CaCO_3$ _____ PPM
Oder _____
Turbidity _____

B.B. WELL 44