

11331
NREAD
7 Apr 86

Mr. John McFadyen
Water Supply Branch
Division of Health Services
North Carolina Department of
Human Resources
Post Office Box 2091
Raleigh, North Carolina 27602

Dear Mr. McFadyen:

Enclosed are the completed Department of Health Forms (DHS 1942 2/74) for all water treatment plants aboard Marine Corps Base, Camp Lejeune for the period 1-31 March 1986. Also enclosed are the weekly Chemical Analysis Forms (MCBCL 11330/3 Rev 3-82) for the same period, as requested in the 25 October 1982 letter from Mr. Charles Rundgren of your office.

The analysis is run by the Quality Control Laboratory located in the Natural Resources and Environmental Affairs Division, Assistant Chief of Staff, Facilities, Marine Corps Base, Camp Lejeune. Ms. Elizabeth Betz, Supervisory Chemist, Quality Control Laboratory, telephone (919) 451-5977 is the point of contact in this matter.

Sincerely,

J. I. WOOTEN
Director

Encl:
(1) Dept of Health Forms
(2) Chemical Analysis Forms

Copy to:
LANTNAVFACENCOM (Code 114)

Blind copy to:
BMO (Util Dir)
QCL (2)

Faint, illegible text, possibly bleed-through from the reverse side of the page.

Find copy of
RMO (OFF) 2011
of (2)

Month MARCH
Year 1986

HADNOT POINT

MEMBRANE FILTER PROCEDURE
WATER TREATMENT PLANT AT Camp Lejeune

Method Code: 303
Contaminant Code: 3000


REPORT OF BACTERIOLOGICAL RESULTS TO DIVISION OF HEALTH SERVICES
N. C. DEPARTMENT OF HUMAN RESOURCES

Serial # 04-67-041

DATE	RAW WATER COLIFORMS (MFP)						NO. OF COLIFORMS PER 100 ml.	TOTAL PLATE COUNT	MFP COLIFORMS per 100 ml.	FINISHED	TOTAL PLATE COUNT	MFP COLIFORMS per 100 ml.	TOTAL PLATE COUNT	DISTRIBUTION SYSTEM					REPEAT SAMPLES	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.	INCUBATOR TEMP.				
	A		B		C									COLIFORMS (MFP)													
	VOLUME FILTERED ml.	TOTAL COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES								1	2	3	4	5									
1																											
4	>4													0	9	0/0	0/0	0/0	0/0	0							35
5																											
6																											
7																											
8																											
9																											
10																											
11	>11													0	9	0/0	0/0	10/0	0/0	10							35
12																											
13																											
14																											
15																											
16																											
17																											
18	>18													0	9	0/0	0/0	0/0	0/0	0							35
20																											
21																											
22																											
23																											
24																											
25	>25													0	9	0/0	0/0	0/0	0/0	0							35
26																											
27																											
28																											
29																											
30																											
31																											
MF MEDIA		BBL mEndo		BACTERIAL DENSITY		ARITH. MEAN								0	DIST. SYSTEM		TOTAL NO. SAMPLES					36					
TPC MEDIA						GEO. MEAN								1			SAMPLES EXCEEDING 3/50, (4/100), 7/200, 13/500=1					0					

Elyse H. B. J.

B-Well 4087



Month MARCH
Year 1986

MARINE CORPS AIR STATION

WATER TREATMENT PLANT AT Camp Lejeune

Method Code: 303

REPORT OF BACTERIOLOGICAL RESULTS TO DIVISION OF HEALTH SERVICES

Contaminant Code: 3000

Serial # 04-67-042

N. C. DEPARTMENT OF HUMAN RESOURCES

DATE	RAW WATER COLIFORMS (MFP)						NO. OF COLIFORMS PER 100 ml.	TOTAL PLATE COUNT	MFP COLIFORMS per 100 ml.	FINISHED	TOTAL PLATE COUNT	MFP COLIFORMS per 100 ml.	TOTAL PLATE COUNT	DISTRIBUTION SYSTEM					INCUBATOR TEMP.			
	A		B		C									COLIFORMS (MFP)						REPEAT SAMPLES		
	VOLUME FILTERED ml.	TOTAL COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES								1	2	3	4	5		COLIFORMS per 100 ml.	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.
1																						
2																						
3																						
4	> 4										0	7	0	0	0	0			35			
5																						
6																						
7																						
8																						
9																						
10																						
11	> 11										0	7	0	0	0	0	10		35.3			
12																						
13																						
14																						
15																						
16																						
17																						
18	> 12										0	7	0	0	0	0	0		35.2			
19																						
20																						
21																						
22																						
23																						
24																						
25	> 25										0	7	0	0	0	0	10		35.3			
26																						
27																						
28																						
29																						
30																						
31																						
MFP MEDIA		BBL mEndo		BACTERIAL DENSITY		ARITH. MEAN														28		
TPC MEDIA						GEO. MEAN																

Handwritten signature and notes at the bottom of the page.



Month MARCH
Year 1986

HOLCOMB 13LVD

WATER TREATMENT PLANT AT Camp Lejeune

Method Code: 303

REPORT OF BACTERIOLOGICAL RESULTS TO DIVISION OF HEALTH SERVICES

Contaminant Code: 3000

Serial # 04-67-043

N. C. DEPARTMENT OF HUMAN RESOURCES

DATE	RAW WATER COLIFORMS (MFP)						NO. OF COLIFORMS PER 100 ml.	FILTERED TOTAL PLATE COUNT	FINISHED TOTAL PLATE COUNT	TOTAL PLATE COUNT	DISTRIBUTION SYSTEM COLIFORMS (MFP)					REPEAT SAMPLES	INCUBATOR TEMP.	
	A		B		C						1	2	3	4	5			
	VOLUME FILTERED ml.	TOTAL COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES												COLIFORMS per 100 ml.
1																		
2																		
3																		
4	>4									0	7	0/0	0/0	0/0	0/1		35	
5																		
6																		
7																		
8																		
9																		
10																		
11	>11									0	7	0/0	0/0	10	10	0/1	35, 3	
12																		
13																		
14																		
15																		
16																		
17																		
18	>12									0	7	10	0/0	10	0/1	10	35, 2	
19												0/1						
20																		
21																		
22																		
23																		
24																		
25	>25									0	7	0/0	0/0	0/0	0/0		35, 3	
26																		
27																		
28																		
29																		
30																		
31																		
MF MEDIA		BBL mEndo		BACTERIAL DENSITY		ARITH. MEAN				①	DIST. SYSTEM		TOTAL NO. SAMPLES					28
TPC MEDIA						GEO. MEAN				1			SAMPLES EXCEEDING 3/50. (4/100, 7/200, 13/500)					①

Elizabeth (B) Sect. 600 B-well



Month MARCH
Year 1986

TARAWA TERRACE

WATER TREATMENT PLANT AT Camp Lejeune

Method Code: 303
Contaminant Code: 3000

REPORT OF BACTERIOLOGICAL RESULTS TO DIVISION OF HEALTH SERVICES
N. C. DEPARTMENT OF HUMAN RESOURCES

Serial # 04-67-044

DATE	RAW WATER COLIFORMS (MFP)						NO. OF COLIFORMS PER 100 ml.	TOTAL PLATE COUNT	MFP COLIFORMS per 100 ml.	TOTAL PLATE COUNT	MFP COLIFORMS per 100 ml.	TOTAL PLATE COUNT	DISTRIBUTION SYSTEM										INCUBATOR TEMP.						
	A		B		C								COLIFORMS (MFP)					REPEAT SAMPLES											
	VOLUME FILTERED ml.	TOTAL COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES							1	2	3	4	5	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.							
1																													
2																													
3																													
4	>4											0	3	0	0	0												35	
5																													
6																													
7																													
8																													
9																													
10																													
11	>11											0	3	0	0	1	0											35	
12																													
13																													
14																													
15																													
16																													
17																													
18	>18											0	3	0	0		0											35	
19																													
20																													
21																													
22																													
23																													
24																													
25	>25											0	3	0	0		1											35	
26																													
27																													
28																													
29																													
30																													
31																													
MFP MEDIA												RBI mEndo		BACTERIAL DENSITY		ARITH. MEAN								TOTAL NO. SAMPLES		12			
TPC MEDIA																GEO. MEAN								SAMPLES EXCEEDING 3/50 (4/100) 7/200 13/500ml		0			

Elizabeth A. St...

4087-W



Month MARCH
 Year 1986

CAMP JOHNSON

WATER TREATMENT PLANT AT Camp Lejeune

Method Code: 303
 Contaminant Code: 3000

REPORT OF BACTERIOLOGICAL RESULTS TO DIVISION OF HEALTH SERVICES
 N. C. DEPARTMENT OF HUMAN RESOURCES

Serial # 04-67-045

DATE	RAW WATER COLIFORMS (MFP)						NO. OF COLIFORMS PER 100 ml.	TOTAL PLATE COUNT	MFP COLIFORMS per 100 ml.	TOTAL PLATE COUNT	MFP COLIFORMS per 100 ml.	TOTAL PLATE COUNT	DISTRIBUTION SYSTEM					REPEAT SAMPLES	INCUBATOR TEMP.	PLANKTON		
	A		B		C								COLIFORMS (MFP)									
	VOLUME FILTERED ml.	TOTAL COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES							1	2	3	4	5					
1																						
2																						
4	>4									0	3	0	0	0					35			
5																						
6																						
7																						
8																						
9																						
10	7																					
11	>11									0	3	10	10	0					35	3		
12																						
13																						
14																						
15																						
16																						
17																						
18	>18									0	3	10		10	0				35	2		
19																						
21																						
22																						
23																						
24																						
25	>25									0	3	10			10	0			35	3		
26																						
27																						
28																						
29																						
30																						
31																						
MFP MEDIA		BBL mEndo		DACTERIAL DENSITY		ARITH. MEAN				0		DIST. SYSTEM		TOTAL NO. SAMPLES					12			
TPC MEDIA						GEO. MEAN								SAMPLES EXCLUDING 3/50, 4/100, 11/200, 13/500ml					0			

#37807

Elizabeth B...



Month MARCH
Year 1986

RIFLE RANGE

WATER TREATMENT PLANT AT Camp Lejeune

Method Code: 303

REPORT OF BACTERIOLOGICAL RESULTS TO DIVISION OF CAMP HEALTH SERVICES

Contaminant Code: 3000

N. C. DEPARTMENT OF HUMAN RESOURCES

Serial # 04-67-046

DATE	RAW WATER COLIFORMS (MFP)						NO. OF COLIFORMS PER 100 ml.	FILTERED TOTAL PLATE COUNT	FINISHED TOTAL PLATE COUNT	DISTRIBUTION SYSTEM COLIFORMS (MFP)					REPEAT SAMPLES			INCUBATOR TEMP.		
	A		B		C					AVE. COLIFORMS per 100 ml.	NO. OF SAMPLES EXAMINED	1	2	3	4	5	COLIFORMS per 100 ml.		COLIFORMS per 100 ml.	COLIFORMS per 100 ml.
	VOLUME FILTERED ml.	TOTAL COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES														
1																				
2																				
3																				
4	74										0	3	0	0	0			35		
5																				
6																				
7																				
8																				
9																				
10																				
11	71										0	3	0	0	0			35		
12																				
13																				
14																				
15																				
16																				
17																				
18	718										0	3	0	0	0			35		
19																				
20																				
21																				
22																				
23																				
24																				
25	725										0	3	0	0	10			35		
26																				
27																				
28																				
29																				
30																				
31																				
MF MEDIA	BRI mEndo		BACTERIAL DENSITY	ARITH. MEAN		GEO. MEAN					0	DIST. SYSTEM	TOTAL NO. SAMPLES					12		
TPC MEDIA											1		SAMPLES EXAMINED MFC 4/100, 7/200, 13/500					0		

Elizabeth A. By

GRADE B-WALL 4087-W



Month MARCH
Year 1986

COURTHOUSE 13A7

WATER TREATMENT PLANT AT Camp Lejeune

Method Code: 303

REPORT OF BACTERIOLOGICAL RESULTS TO DIVISION OF HEALTH SERVICES

Contaminant Code: 3000

Serial # 04-67-047

N. C. DEPARTMENT OF HUMAN RESOURCES

DATE	RAW WATER COLIFORMS (MFP)								NO. OF COLIFORMS PER 100 ml.	TOTAL PLATE COUNT	MFP COLIFORMS per 100 ml.	TOTAL PLATE COUNT	MFP COLIFORMS per 100 ml.	TOTAL PLATE COUNT	DISTRIBUTION SYSTEM					INCUBATOR TEMP.	
	A		B		C		COLIFORMS (MFP)								REPEAT SAMPLES						
	VOLUME FILTERED ml.	TOTAL COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES	1	2							3	4	5	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.		COLIFORMS per 100 ml.
1																					
2																					
4	>4											0	4	0	0	0			35		
5																					
6																					
7																					
8																					
9																					
10																					
11	>11											0	4	0	0	0	0		35.3		
12																					
13																					
14																					
15																					
16																					
17																					
18	>18											0	4	0	0		10	0	35.2		
19																					
20																					
21																					
22																					
23																					
24																					
25	>25											0	4	0	0	0		10	35.3		
26																					
27																					
28																					
29																					
30																					
31																					
MF MEDIA	BBL mEndo		BACTERIAL DENSITY	ARITH. MEAN								0	1	TOTAL NO. SAMPLES					16		
TPC MEDIA				GEO. MEAN								1	1	SAMPLES EXCEEDING 1000 (4/100) 7/200 13/5000					0		

Elyse A. St...

GRADE B WELL 9087-W



Month MARCH
Year 1986

ONSLow BEACH

WATER TREATMENT PLANT AT Camp Lejeune

Method Code: 303
Contaminant Code: 3000

REPORT OF BACTERIOLOGICAL RESULTS TO DIVISION OF HEALTH SERVICES
N. C. DEPARTMENT OF HUMAN RESOURCES

Serial # 04-67-048

DATE	RAW WATER COLIFORMS (MFP)						NO. OF COLIFORMS PER 100 ml.	FILTERED TOTAL PLATE COUNT	MFP COLIFORMS per 100 ml.	FINISHED TOTAL PLATE COUNT	MFP COLIFORMS per 100 ml.	TOTAL PLATE COUNT	DISTRIBUTION SYSTEM COLIFORMS (MFP)					REPEAT SAMPLES			INCUBATOR TEMP.
	A		B		C								1	2	3	4	5	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.	
	VOLUME FILTERED ml.	TOTAL COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES															
1																					
2																					
3																					
4	74											0	2	0	0					35	
5																					
6																					
7																					
8																					
9																					
10																					
11	74											0	2	0	0					35.3	
12																					
13																					
14																					
15																					
16																					
17																					
18	718											0	2	0	0					35.2	
19																					
20																					
21																					
22																					
23																					
24																					
25	725											0	2	0	0					35.3	
26																					
27																					
28																					
29																					
30																					
31																					
MFP MEDIA		BRI mEndo		BACTERIAL DENSITY		ARITH. MEAN						0	DIST. SYSTEM		TOTAL NO. SAMPLES					8	
TPC MEDIA						GEO. MEAN						1			SAMPLES EXCEEDING 3/100 (4/100) 7/100, 13/1000					0	

Elizabeth A. Bly

GRADE B-Well 4087-W



CHEMICAL ANALYSIS — WATER TREATMENT PLANTS
 MCBCL 11330 3 (REV 6-84)

DATE COLLECTED
 3-4-86

DATE OF ANALYSIS
 3-4-86

PARAMETER SERIAL # 21-67	HADNOT POINT -041	CAMP JOHNSON -045	TARAWA TERRACE -044	ONSLow BEACH -048	COURTHOUSE BAY -047	RIFLE RANGE -046	HOLCOMB BLVD -043	NEW RIVER -042		
PH (IN LAB W/ PLANT)	8.1	7.5	8.9	7.3	8.0	8.2	8.7	9.3		
PHENOLTHALEIN ALKALINITY	0	0	6	0	2	2	4	20		
METHYL ORANGE ALKALINITY	78	180	42	154	160	174	60	90		
CARBONATES AS CaCO ₃	0	0	12	0	4	4	8	40		
BICARBONATES AS CaCO ₃	78	180	30	154	156	170	52	50		
CHLORIDES AS Cl	10	30	12	20	20	20	10	50		
HARDNESS AS CaCO ₃	90	60	64	52	60	54	66	46		
IRON AS Fe	0.04	0.32	0.04	0.24	0.04	0.04	0.09	0.24		
FLUORIDE	AM 0.65		0.78				0.46			
	PM 0.85	0.19	0.67	0.16	0.12	0.10	0.46	0.34		
CHLORINE RESIDUAL	1.1	1.2	1.0	1.5	1.2	1.0	0.9	1.0		
TURBIDITY	AM 0.2		0.3				1.1			
	PM 0.2	1.4	0.8	0.2	0.3	0.3	3.2	3.0		
TOTAL PHOSPHATE		1.32			0.05					
ORTHO PHOSPHATE		0.88			0.02					
META PHOSPHATE		0.44			0.03					
STABILITY	-0.1	-0.5	+0.5	-0.8	-0.2	0.0	+0.3	+0.4		

REMARKS

- COPY TO:
- UTIL DIR _____
 - WATER TREATMENT
 - PMU MCAS PMU
 - NREAD FILE

NOTE: All results reported in parts per million unless otherwise noted except for pH, temperature, and specific conductance. One liter of potable water is assumed to weigh one kilogram.

LABORATORY ANALYSIS BY

H. J. BURNS



3-11-86

3-11-86

PARAMETER SERIAL # 01-67	HADNOT POINT -041	CAMP JOHNSON -045	TARAWA TERRACE -044	ONSLow BEACH -048	COURTHOUSE BAY -047	RIFLE RANGE -046	HOLCOMB BLVD -043	NEW RIVER -042		
PH (IN LAB NOT PLANT)	8.0	7.2	8.6	7.5	8.1	8.2	8.8	8.4		
PHENOLTHALEIN ALKALINITY	0	0	4	0	4	10	8	4		
METHYL ORANGE ALKALINITY	70	190	44	150	164	170	64	110		
CARBONATES AS CaCO ₃	0	0	8	0	8	20	16	8		
BICARBONATES AS CaCO ₃	70	190	36	150	156	150	48	102		
CHLORIDES AS Cl	10	16	10	20	20	24	10	32		
HARDNESS AS CaCO ₃	70	64	70	56	72	52	60	62		
IRON AS Fe	40.04	0.91	40.04	0.21	40.04	40.04	40.04	40.04		
AM	0.96		0.92				0.80			
FLUORIDE	1.11	0.20	0.99	0.23	0.18	0.14	0.80	0.48		
PM										
CHLORINE RESIDUAL	1.0	1.3	1.0	1.3	1.8	1.0	0.8	0.8		
AM	0.2		0.5				1.2			
TURBIDITY	0.7	1.8	9.9	0.2	0.1	0.4	1.4	0.5		
PM										
TOTAL PHOSPHATE		2.3			0.4					
ORTHO PHOSPHATE		1.4			0.3					
META PHOSPHATE		0.9			0.1					
STABILITY	-0.2	-0.9	+0.3	-0.8	-0.2	-0.2	+0.4	+0.1		

REMARKS

COPY TO:

UTIL DIR _____

WATER TREATMENT

PMU MCAS PMU

NREAD FILE

NOTE: All results reported in parts per million unless otherwise noted except for pH, temperature, and specific conductance. One liter of potable water is assumed to weigh one kilogram.

LABORATORY ANALYSIS BY

H. J. BURNS



PARAMETER	HADNOT POINT -041	CAMP JOHNSON -043	TARAWA TERRACE -044	ONSLOW BEACH -048	COURTHOUSE BAY -047	RIFLE RANGE -046	HOLCOMB BLVD -043	NEW RIVER -042		
PH (IN LAB NOT PLANT)	8.3	7.4	8.7	7.5	8.3	8.2	8.8	8.8		
PHENOLTHALEIN ALKALINITY	2	0	6	0	2	2	4	4		
METHYL ORANGE ALKALINITY	52	116	44	162	172	174	50	102		
CARBONATES AS CaCO ₃	4	0	12	0	4	4	8	8		
CARBONATES CaCO ₃	48	116	32	162	168	170	42	94		
CHLORIDES AS Cl	10	28	20	20	18	22	14	36		
HARDNESS AS CaCO ₃	54	60	70	56	44	54	50	48		
IRON AS Fe	20.04	0.29	0.07	0.29	20.04	0.06	20.04	0.11		
FLUORIDE	Am 1.20 Pm 1.33	0.26	0.97 0.98	0.23	0.16	0.14	0.98 0.93	0.48		
CHLORINE RESIDUAL	1.0	1.2	1.0	1.2	1.2	1.0	0.8	0.8		
TURBIDITY	Am 0.3 Pm 0.2	0.4	0.3 1.3	0.5	0.2	0.3	0.6 0.9	0.5		
TOTAL PHOSPHATE		1.17			0.03					
ORTHO PHOSPHATE		0.72			0.01					
META PHOSPHATE		0.45			0.02					
STABILITY	-0.1	-0.8	+0.3	-0.8	-0.2	-0.2	+0.3	+0.2		
REMARKS										


COPY TO:

- UTIL DIR _____
 WATER TREATMENT
 PMU MCAS PMU
 NREAD FILE

NOTE: All results reported in parts per million unless otherwise noted except for pH, temperature, and specific conductance. One liter of potable water is assumed to weigh one kilogram.

LABORATORY ANALYSIS BY

LANE + WADDOUPS



CHEMICAL ANALYSIS WATER TREATMENT PLANTS
 MCBCL 11330 3 (REV 6-84)

DATE COLLECTED

3-25-86

DATE OF ANALYSIS

3-25-86

PARAMETER SERIAL # 04-67	HADNOT POINT -041	CAMP JOHNSON -043	TARAWA TERRACE -044	ONSLow BEACH -048	COURTHOUSE BAY -047	RIFLE RANGE -046	HOLCOMB BLVD -043	NEW RIVER -042		
PH (IN LAB NOT PLANT)	8.8	7.4	8.6	7.5	8.2	8.4	8.6	8.7		
PHENOLTHALEIN ALKALINITY	6	0	4	0	6	6	4	6		
METHYL ORANGE ALKALINITY	54	190	48	164	180	170	60	102		
CARBONATES AS CaCO ₃	12	0	8	0	12	12	8	12		
BICARBONATES CaCO ₃	42	190	40	164	168	158	52	90		
CHLORIDES AS Cl	10	30	18	22	22	28	20	40		
HARDNESS AS CaCO ₃	84	80	96	84	76	60	74	68		
IRON AS Fe	20.04	0.31	20.04	0.20	20.04	20.04	20.04	20.04		
FLUORIDE	AM 0.20		0.19				0.96			
	PM 1.24	0.24	0.99	0.18	0.13	0.11	0.95	0.44		
CHLORINE RESIDUAL	1.0	1.3	1.2	1.1	1.0	0.7	1.0	0.8		
TURBIDITY	AM 0.3		1.5				0.3			
	PM 3.1	0.5	0.9	0.2	0.1	0.3	0.4	0.4		
TOTAL PHOSPHATE		1.5			0.07					
ORTHO PHOSPHATE		0.9			0.02					
META PHOSPHATE		0.6			0.05					
STABILITY	+0.5	-0.6	+0.2	-0.5	0.0	+0.1	+0.3	+0.1		
REMARKS										


COPY TO:

- UTIL DIR
- WATER TREATMENT
- PMU MCAS PMU
- NREAD FILE

NOTE: All results reported in parts per million unless otherwise noted except for pH, temperature, and specific conductance. One liter of potable water is assumed to weigh one kilogram.

LABORATORY ANALYSIS BY

WADDUPS & LANE



6286/1
NREAD
21 Apr 1986

Cur
DNA

From: Director, Natural Resources and Environmental Affairs
Division, Marine Corps Base, Camp Lejeune
To: Base Maintenance Officer (Attn: Utilities Director, Marine
Corps Base, Camp Lejeune

Subj: NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
PERMIT RELATED REPORTING DATA

Encl: (1) Monthly Report of Waste Treatment Plant Water Quality

1. It is requested that the enclosure be routed to the Utilities
Systems General Foreman. The enclosure summarizes the subject
data for all sewage treatment plants for 1-31 March 1986.

2. The data/information except chlorine residuals shown under
the "LAB" column are submitted to the EPA and State in accord-
ance with the NPDES Permit.

J. I. WOOTEN

Blind copy to:
QCL, NREAD w/encl
LabReadFile w/o encl

Writer: E. Betz, NREAD 5977
Typist: J. Cross 21Apr86

100

1951
1952
1953

Division of Investigation
U.S. Department of Justice
Washington, D.C.

MEMORANDUM FOR THE DIRECTOR
FROM: SAC, [illegible]

Subject: [illegible]

It is requested that you advise the Bureau of any developments in this matter.

The attached report contains information regarding the activities of [illegible].

Very truly yours,
[illegible]

Walter J. [illegible]
Special Agent in Charge


MONTHLY REPORT OF WASTE TREATMENT PLANT WATER QUALITY
 MCBC 11345/8 (REV 6-83)

PLANT COURTHOUSE BAY

MONTH MARCH 1986

DATE	PLANT EFFLUENT DATA				5 DAY 20° C. BOD			SUSPENDED SOLIDS			COLIFORM	
	FLOW TOTAL DAILY M GPD	PH	CHLORINE RESIDUAL		RAW mg/1	EFFLUENT mg/1	PERCENT REMOVAL	RAW mg/1	EFFLUENT mg/1	PERCENT REMOVAL	NUMBER PER 100 ml	GEOMETRIC MEAN
1	.25450	6.8	3.9									
2	.31430	6.8	2.7									
3	.46910	6.7	1.9									
4	.46340	6.7	2.0	1.3	60	13	78	52	3	92	0	
5	.44090	6.8	1.8									
6	.31212	6.9	1.6	1.8	120	13	89	3550	7	99	no sample	
7	.44714	6.7	2.9									
8	.45461	6.7	4.3									
9	.45408	6.7	4.0									
10	.45406	6.5	4.1									
11	.35794	6.7	2.8	1.8	148	13	91	278	12	96	0	
12	.56220	6.7	3.1									
13	.50620	6.6	1.9	1.9	172	8	95	100	4	96	0	
14	.48580	6.7	1.7									
15	.48380	6.7	1.8									
16	.48710	6.6	2.0									
17	.48560	6.7	2.0									
18	.44900	6.7	2.0	1.5	60	8	87	56	1	98	2	
19	.46550	6.6	2.4									
20	.48820	6.6	1.5	2.2	84	8	90	28	1	96	0	
21	.44360	6.7	2.0									
22	.44600	6.6	1.8									
23	.49230	6.6	3.3									
24	.33430	6.7	3.1									
25	.33210	6.8	1.8	1.2	104	7	93	144	10	93	20	
26	.30310	6.8	1.4									
27	.36300	6.8	2.4	1.4	100	11	89	70	9	87	0	
28	.36300	6.6	2.8									
29	.47130	6.9	2.9									
30	.21750	6.7	4.2									
31	.42430	6.8	2.1									
Tot.	12.02605		72.0	1.2	818	81	712	4270				

ENCLOSURE (1)



MONTHLY REPORT OF WASTE TREATMENT PLANT WATER QUALITY

MCBCL 11345-8 (REV. 6-83)

PLANT RIFLE RANGE

MONTH MARCH 1986

DATE	PLANT EFFLUENT DATA			5 DAY 20° C. BOD			SUSPENDED SOLIDS			COLIFORM		
	FLOW TOTAL DAILY M GPD	PH	CHLORINE RESIDUAL PLANT mg/1	LAB mg/1	RAW mg/1	EFFLUENT mg/1	PERCENT REMOVAL	RAW mg/1	EFFLUENT mg/1	PERCENT REMOVAL	NUMBER PER 100 ml	GEOMETRIC MEAN
1	.157450	6.4	5.3									
2	.208260	6.5	4.7									
3	.168410	6.6	7.5									
4	.168982	6.5	3.5	1.5	44	11	(75)	48	1	98	0	
5	.210210	6.5	2.6									
6	.167910	6.5	5.0	2.0	40	7	(83)	14	4	(71)	0	
7	.183030	6.5	3.7									
8	.176560	6.6	4.6									
9	.179390	6.5	5.7									
10	.166680	6.6	4.6									
11	.193790	6.5	4.5	2.0	20	6	(70)	38	5	87	0	
12	.194920	6.5	3.3									
13	.170850	6.6	3.3	1.9	24	6	(75)	38	2	95	0	
14	.313340	6.5	3.5									
15	.242160	6.5	5.1									
16	.235580	6.6	6.0									
17	.243580	6.5	6.0									
18	.227620	6.5	6.0	0.5	40	9	(78)	29	3	90	0	
19	.234850	6.5	3.0									
20	.252920	6.5	3.3	1.2	68	11	(84)	24	5	(79)	0	
21	.240640	6.5	4.9									
22	.223290	6.4	2.7									
23	.240040	6.3	5.5									
24	.207930	6.4	5.0									
25	.227230	6.4	4.2	1.0	64	8	88	33	6	(82)	10	
26	.231170	6.4	5.0									
27	.296990	6.6	4.0	2.2	80	11	86	110	4	96	2	
28	.169490	6.3	3.4									
29	.213380	6.3	7.4									
30	.198860	6.3	8.0									
31	.189920	6.3	8.0									
Tot.	6.535432		149.3	12.3	380	69	639	334	30	698		
Ave.	.210820		4.8	1.5	48	9	(80)	42	4	87		1.6



MONTHLY REPORT OF WASTE TREATMENT PLANT WATER QUALITY

MCBCL 11345/8 (REV. 6-83)

PLANT ONSLOW BEACH

MONTH MARCH 1986

DATE	PLANT EFFLUENT DATA				5 DAY 20° C. BOD			SUSPENDED SOLIDS			COLIFORM	
	FLOW TOTAL DAILY M GPD	PH	CHLORINE RESIDUAL PLANT mg/1	LAB mg/1	RAW mg/1	EFFLUENT mg/1	PERCENT REMOVAL	RAW mg/1	EFFLUENT mg/1	PERCENT REMOVAL	NUMBER PER 100 ml	GEOMETRIC MEAN
1	.080140	6.5	4.0									
2	.069520	6.5	4.0									
3	.093610	6.3	4.1									
4	.166950	6.3	4.0	1.8	60	12	(80)	32	2	94	0	
5	.178430	6.5	6.0									
6	.191180	6.6	5.0	1.8	72	18	(75)	32	5	(77)	12	
7	.135220	6.4	4.0									
8	.168870	6.4	5.0									
9	.193850	6.6	5.0									
10	.191940	6.4	4.0									
11	.148160	6.6	5.0	4.3	64	17	(73)	26	11	(58)	0	
12	.167130	6.5	4.0									
13	.102940	6.8	4.0	1.8	88	20	(77)	13	3	(77)	16	
14	.158700	6.5	5.0									
15	.124830	6.4	6.0									
16	.144010	6.6	5.0									
17	.158180	6.0	5.0									
18	.175120	6.3	5.0	1.5	44	26	(41)	15	Lab Error		2	
19	.116200	6.6	5.0									
20	.135740	6.5	4.0	2.3	212	17	92	35	2	94	0	
21	.110390	6.5	5.0									
22	.110390	6.5	5.0									
23	.165610	6.4	4.0									
24	.107960	6.4	4.0									
25	.104640	6.5	6.0	4.2	92	9	90	26	6	(77)	10	
26	.084380	6.6	6.0									
27	.084380	6.4	5.0	2.2	100	15	85	44	1	98	0	
28	.068880	6.4	6.0									
29	.076610	6.4	4.0									
30	.091110	6.6	6.0									
31	.081460	7.0	4.0									
Tot.	3.98653		148.1	19.9	732	134	613	233	30	575		
Avg.	.128597		4.8	2.5	92	17	(77)	28	4	(82)		2.8











MONTHLY REPORT OF WASTE TREATMENT PLANT WATER QUALITY

MCBOL 1345.8 (REV. 6-83)

PLANT CAMP JOHNSON

MONTH MARCH 1986

DATE	PLANT EFFLUENT DATA				5 DAY 20° C BOD			SUSPENDED SOLIDS			COLIFORM	
	FLOW TOTAL DAILY MGPD	PH	CHLORINE RESIDUAL		RAW mg/1	EFFLUENT mg/1	PERCENT REMOVAL	RAW mg/1	EFFLUENT mg/1	PERCENT REMOVAL	NUMBER PER 100 ml	GEOMETRIC MEAN
			PLANT mg/1	LAB mg/1								
1	.363	6.7	5.0									
2	.402	6.6	5.0									
3	.401	7.1	5.0									
4	.460	6.8	5.0	7.5	68	19	(72)	28	6	(79)	260	
5	.370	6.8	5.0									
6	.389	6.6	0.0	6.2	112	19	(83)	93	14	85	0	
7	.367	6.9	5.0									
8	.531	6.8	5.0									
9	.391	6.9	5.0									
10	.425	6.7	5.0									
11	.412	7.1	5.0	4.9	188	17	91	148	16	89	0	
12	.430	6.8	4.0									
13	.394	6.8	6.0	4.2	160	18	89	64	8	88	0	
14	.742	7.0	5.0									
15	.380	7.0	5.0									
16	.396	6.5	5.0									
17	.487	7.0	4.0									
18	.416	6.5	5.0	4.5	28	14	(50)	16	5	(69)	0	
19	.675	6.4	4.0									
20	.490	6.6	2.0	3.0	52	12	(77)	32	6	(81)	0	
21	.423	6.6	5.0									
22	.407	6.5	4.0									
23	.434	6.6	4.0									
24	.438	6.8	4.0									
25	.447	6.8	4.0	5.6	144	12	92	105	9	91	0	
26	.511	6.9	4.0									
27	.547	7.0	4.0	4.0	80	13	(84)	46	6	87	0	
28	.519	6.9	4.0									
29	.333	6.4	6.0									
30	.359	6.5	6.0									
31	.413	7.0	6.0									
Tot.	13.752		141.0	39.9	832	124	638	532	70	669		
Ave.	.444		4.5	5.0	104	16	(80)	67	9	(84)		2.0



MONTHLY REPORT - WASTE TREATMENT PLANT WATER QUALITY

MCBCL 11345 R REV 1-85

PLANT CAMP GEIGER

MONTH MARCH 1986

DATE	PLANT EFFLUENT DATA				5 DAY 20° C. BOD			SUSPENDED SOLIDS			COLIFORM	
	FLOW TOTAL DAILY MGPD	PH	CHLORINE RESIDUAL		RAW mg/1	EFFLUENT mg/1	PERCENT REMOVAL	RAW mg/1	EFFLUENT mg/1	PERCENT REMOVAL	NUMBER PER 100 ml	GEOMETRIC MEAN
			PLANT mg/1	LAB mg/1								
1	1.250	7.0	3.7									
2	1.000	6.8	4.0									
3	1.000	6.8	4.0	2.9	104	7	93	122	6	95	0	
4	1.250	6.8	4.0	2.7	120	4	97	110	2	98	0	
5	1.000	7.3	4.0	2.3	112	9	92	64	7	89	0	
6	1.250	7.1	3.8	2.4	144	11	92	78	7	91	0	
7	1.500	7.1	4.0	3.6	228	12	95	180	3	98	0	
8	1.500	7.2	4.0									
9	1.250	7.1	4.0									
10	1.250	7.1	4.0	2.2	120	9	93	104	7	93	0	
11	1.300	6.8	3.9	3.9	132	9	92	118	8	93	0	
12	1.250	6.9	3.6	2.7	124	7	94	94	4	96	0	
13	1.500	6.8	4.0	2.4	196	5	97	226	8	97	0	
14	1.000	6.9	2.9	2.5	168	12	93	168	6	96	2	
15	1.000	6.6	4.0									
16	1.000	6.6	4.0									
17	1.495	6.2	4.0	3.5	84	9	89	36	3	92	0	
18	1.500	7.0	4.0	3.5	72	10	86	18	5	72	1000	
19	1.283	6.8	4.0	4.3	136	9	93	66	6	91	0	
20	1.382	6.7	4.0	3.4	84	6	93	60	6	90	0	
21	1.000	6.8	4.0	3.7	88	8	91	50	2	96	0	
22	1.500	6.6	4.0									
23	1.518	6.6	4.0									
24	1.008	6.5	4.0	3.2	92	7	92	53	6	89	0	
25	1.250	6.6	4.0	4.0	100	7	93	92	7	92	0	
26	1.000	7.0	4.0	3.7	52	5	90	92	5	95	0	
27	1.578	6.9	4.0	0.4	216	8	96	34	5	85	0	
28	1.455	6.6	3.8	2.6	140	41	71	82	5	94	0	
29	1.321	6.8	4.0									
30	1.372	6.9	4.0									
31	1.402	6.9	4.0	3.0	188	7	96	96	4	96	0	
Tot.	39.364		121.7	62.9	2700	202	1928	1943	112	1938		
Ave.	1.270		3.9	3.0	129	10	92	93	5	92		1.4





MONTHLY REPORT OF WASTE TREATMENT PLANT WATER QUALITY

MOBCL 1134 (REV. 8-63)

PLANT HADNOT POINT

MONTH MARCH 1986

DATE	PLANT EFFLUENT DATA				5 DAY 20° C. BOD			SUSPENDED SOLIDS			COLIFORM	
	FLOW TOTAL DAILY M GPD	PH	CHLORINE RESIDUAL		RAW mg/1	EFFLUENT mg/1	PERCENT REMOVAL	RAW mg/1	EFFLUENT mg/1	PERCENT REMOVAL	NUMBER PER 100 ml	GEOMETRIC MEAN
			PLANT mg/1	LAB mg/1								
1	3.754	6.9	4.0									
2	3.699	6.8	4.0									
3	4.301	6.8	4.0	2.6	112	16	86	122	9	93	20/2	
4	4.320	6.8	4.0	2.5	136	16	88	96	4	96	20/0	
5	4.403	6.8	4.0	2.4	132	21	(84)	114	5	96	0/0	
6	4.016	6.8	4.0	2.6	96	21	(78)	58	6	90	30/0	
7	4.011	6.9	4.0	3.0	116	27	(77)	56	6	89	1000/2	
8	3.650	6.8	4.0									
9	3.609	6.8	4.0									
10	4.059	6.8	4.0	3.0	156	18	88	160	8	95	10/0	
11	4.200	6.9	3.7	3.2	96	18	(81)	68	12	(82)	0/0	
12	3.971	6.9	3.9	2.5	112	15	87	64	7	89	8/0	
13	4.323	6.9	4.0	2.8	188	15	92	108	6	94	10/0	
14	5.970	7.0	4.0	2.2	244	26	89	325	21	94	4/2	
15	4.757	6.9	4.0									
16	4.777	6.8	4.0									
17	5.571	6.8	4.0	2.9	116	16	86	62	9	85	104/2	
18	5.922	6.9	4.0	2.6	144	17	88	162	7	96	16/4	
19	4.966	7.0	4.0	4.0	192	26	86	102	10	90	160/8	
20	5.179	6.9	4.0	5.6	108	19	(82)	108	8	93	6/4	
21	4.664	6.9	4.0	4.0	116	20	(83)	88	8	91	0/0	
22	3.813	6.8	4.0									
23	3.882	6.8	4.0									
24	3.721	6.8	4.0	3.0	116	16	86	102	5	95	66/10	
25	3.720	6.8	4.0	3.5	132	15	89	110	6	95	16/2	
26	3.835	6.9	4.0	3.0	136	9	93	150	5	97	12/0	
27	4.258	6.9	4.0	2.1	132	25	(81)	116	9	92	30/8	
28	4.012	6.8	4.0	2.9	128	23	(82)	100	11	89	20/4	
29	3.748	6.9	4.0									
30	4.073	-	4.0									
31	4.525	6.8	4.0	2.5	148	13	91	108	6	94	14/0	
Tot.	133.709		123.6	62.9	2856	392	1797	2379	168	1935		
Ave.	4.313		4.0	3.0	136	19	86	113	8	92		15.2/2.0



6288
NREAD(L)
23 Apr 1986

Am

Mr. Paul Wilms, Director
Division of Environmental Management
North Carolina Department of Natural
Resources and Community Development
Post Office Box 27687
Raleigh, North Carolina 27611

Dear Sir:

In accordance with requirements of the National Pollutant Discharge Elimination System (NPDES) Permit Number NC 0003239, two copies of the Discharge Monitoring Reports (DRMs) for the month of March 1986 are submitted.

Camp Johnson Wastewater Treatment Plant violated the NPDES permit requirements for monthly Biochemical Oxygen Demand (BOD) and Total Suspended Residue (TSR) percent removal averages for March 1986. The violation is attributed to low influent coupled with a partially obstructed secondary sludge drawoff line. March's BOD influent and effluent monthly averages were 104mg/l and 16mg/l respectively. March's TSR influent and effluent monthly averages were 67mg/l and 9mg/l respectively.

Rifle Range Wastewater Treatment Plant violated the NPDES permit requirement for monthly BOD percent removal average for March 1986. The violation is attributed to the low BOD loading. March's influent and effluent monthly averages were 48mg/l and 9mg/l respectively.

Onslow Beach Wastewater Treatment Plant violated the NPDES permit requirement for monthly BOD and TSR percent removal averages for March 1986. The violation is attributed to low influent. March's BOD influent and effluent monthly averages were 92mg/l and 17mg/l respectively. March's TSR influent and effluent monthly averages were 28mg/l and 4mg/l respectively.

There are no oil and grease analysis for River Water points RW 02 to RW 09 for March. The laboratory ran out of liquid freon used in the analysis and was unable to get some more before the holding time on the samples ran out.

The storm drains listed on the enclosed table may be correlated with base geography and facilities by referring to maps with numbered storm drain monitoring points that have been previously

6588
MEMPHIS
2244

Mr. Paul W. Director
Division of Environmental Management
North Carolina Department of Natural
Resources and Community Development
Post Office Box 2758
Raleigh, North Carolina 27611

Dear Sir:

In accordance with requirements of the National Pollution Discharge Elimination System (NPDES) Permit under NC 0000000000, you are required to submit to the Division a copy of the Discharge Monitoring Report (DMR) for the month of March 1988.

Some of the parameters listed in the NPDES permit requirements for monthly biological oxygen demand (BOD) and total suspended solids (TSS) percent removal averages for each month. The violation is attributed to low treatment coupled with a partially obstructed secondary effluent flow line. March 1988 DMR and effluent monthly averages were 100% and 100% respectively.

The permit requires treatment plant effluent to meet the requirements for monthly BOD percent removal average for March 1988. The violation is attributed to the fact that the plant was not operating and effluent monthly averages were 100% and 100% respectively.

Water flow was zero. Treatment plant effluent quality requirements for monthly BOD and TSS percent removal averages for March 1988. The violation is attributed to the fact that the plant was not operating and effluent monthly averages were 100% and 100% respectively.

There are no oil and grease analyzers on River Street. The laboratory was out of service and was unable to perform the analysis on the samples.

The laboratory files on the enclosed table are as follows: with appropriate and facilities by reference to maps with which you may wish to refer to the data that have been provided.

provided. Storm drains that have no values reported for the quarter were checked; however, each time they were checked they were either dry or had no flow. The Base Environmental staff is continuing to work on operational control methodology to reduce oil and grease and total suspended residue discharges. New construction to replace outdated base facilities should further reduce oil and grease and total suspended residue discharges.

Questions regarding this report should be forwarded to Ms. Elizabeth A. Betz, Supervisory Chemist, Natural Resources and Environmental Affairs Division, Assistant Chief of Staff, Facilities at (919) 451-5977.

Sincerely,

J. I. WOOTEN
Director

Encl:
(1) DEM Forms MR-1, 2 and 3

Copy to:
EPA Region IV
CMDR LANTNAVFACENGCOM
NEESA

Blind copy to:
BMaint(UtilDir)
QCL NREAD (2)

provided. Some data that have no values reported for the
must be checked. However, as the data were checked they
were either 0 or had no value. The case number was
is continuing to work on operational control methodology for
reduce oil and grease and total suspended matter discharge.
New construction to replace outdated gas facilities should
further reduce oil and grease and total suspended matter
discharge.

Questions regarding this report should be forwarded to Mr.
Richard A. Bell, Regulatory Division, Water Resources
and Environmental Policy Division, Assistant Chief of Staff,
Facilities at (910) 437-7777.

Sincerely,

J. I. WOODRIF
Director

Encl:
(1) Form 100-1, 2 and 3

Copy to:
EPA Region IV
C/O JAMES W. BARRON
WETA

File copy to
EPA Region IV
WETA

EFFLUENT

DES PERMIT NO: NCO003239 DISCHARGE NO: 001 MONTH: March YEAR: 1986

CILITY NAME: Camp Geiger STP CLASS: III COUNTY: Onslow

ERATOR IN RESPONSIBLE CHARGE (ORC): Mack D. Davis GRADE: IV

RTIFIED LABORATORY: Water Quality Control Laboratory

PERSON(S) COLLECTING SAMPLES: STP Operators

CHECK BLOCK IF ORC HAS CHANGED

Mail original and one copy to:
 AT1 Central Files
 Division of Environmental Management
 N.C. Department of NRCD
 PO Box 27687
 Raleigh North Carolina 27611

I CERTIFY THAT THIS REPORT
 IS ACCURATE AND COMPLETE TO
 THE BEST OF MY KNOWLEDGE

X _____
 Signature of operator in responsible charge

DATE	TIME 2400 CLOCK	COMPOSITE TIME HRS	50050	00010	00400	00545	50060	00310	00340	00610	00500	00530	316 ⁶	00300	ENTER PARAMETER CODE ABOVE NAME AND UNITS BELOW			
			FLOW EFF <input type="checkbox"/>	TEMPERATURE CELSIUS	pH	SETTLABLE MATTER	RESIDUAL CHLORINE	BOD5 20°C	COD	AMMONIA NITROGEN	TOTAL RESIDUE	TOTAL SUSPENDED RESIDUE	FECAL COLIFORM <small>Geometric Mean</small>	DISSOLVED OXYGEN				
			DAILY RATE MGD	°C	UNIT	ML/L	MG/L	MG/L	MG/L	MG/L	MG/L	MG/L	MG/L	/100 ML	MG/L			
1	08		1.250		7.0		3.7											
2	08		1.000		6.8		4.0											
3	08	24	1.000		6.8		4.0	7				6	0					
4	08	24	1.250		6.8		4.0	4				2	0					
5	08	24	1.000		7.3		4.0	9				7	0					
6	08	24	1.250		7.1		3.8	11				7	0					
7	08	24	1.500		7.1		4.0	12				3	0					
8	08		1.500		7.2		4.0											
9	08		1.250		7.1		4.0											
10	08	24	1.250		7.1		4.0	9				7	0					
11	08	24	1.300		6.8		3.9	9				8	0					
12	08	24	1.250		6.9		3.6	7				4	0					
13	08	24	1.500		6.8		4.0	5				8	0					
14	08	24	1.000		6.9		2.9	12				6	2					
15	08		1.000		6.6		4.0											
16	08		1.000		6.6		4.0											
17	08	24	1.495		6.2		4.0	9				3	0					
18	08	24	1.500		7.0		4.0	10				5	1000					
19	08	24	1.283		6.8		4.0	9				6	0					
20	08	24	1.382		6.7		4.0	6				6	0					
21	08	24	1.000		6.8		4.0	8				2	0					
22	08		1.500		6.6		4.0											
23	08		1.518		6.6		4.0											
24	08	24	1.008		6.5		4.0	7				6	0					
25	08	24	1.250		6.6		4.0	7				7	0					
26	08	24	1.000		7.0		4.0	5				5	0					
27	08	24	1.578		6.9		4.0	8				5	0					
28	08	24	1.455		6.6		3.8	41				5	0					
29	08		1.321		6.8		4.0											
30	08		1.372		6.9		4.0											
31	08	24	1.402		6.9		4.0	7				4	0					
Average			1.270				3.9	10				5	1.4					
Max.			1.578		7.1		4.0	41				8	1000					
Min.			1.000		6.2		2.9	4				2	0					
Comp (C) Grab (G)					G		G	C				C	G					
Monthly Limit					6-9			30				30	200					

Facility Status: (Please check one of the following)

All monthly averages and / or other limitation do meet permit monitoring requirements (Compliant)

All monthly averages and / or other limitation do not meet permit monitoring requirements (Noncompliant)

If the facility is noncompliant, please comment on corrective actions being taken in respect to equipment, operation, maintenance, etc. and a time table for improvements to be made.

(Attach additional sheets if necessary)

I certify that this Report is accurate and complete to the best of my knowledge:

 Signature of Permittee

PARAMETER CODES

00010 Temperature	00556 Oil and Grease	00950 Dissolved Fluoride	01077 Silver	39516 PCBS
00065 Stream Stage	00600 Total Nitrogen	01002 Total Arsenic	01087 Total Vanadium	39941 Roundup
00076 Turbidity	00610 Ammonia Nitrogen	01027 Cadmium	01092 Zinc	50047 Max. flow during 24-hr. period
00300 Dissolved Oxygen	00625 Total Kjeldahl Nitrogen	01032 Hexavalent Chromium	01105 Total Aluminum	50048 Min. flow during 24-hr. period
00310 BOD ₅	00665 Total Phosphorous	01034 Chromium	01147 Total Selenium	50050 Flow
00340 COD	00720 Cyanide	01037 Total Cobalt	31504 Total Coliform	50060 Total Residual Chlorine
00400 pH	00745 Total Sulfide	01042 Copper	31614 Fecal Coliform, MPN, Tube	71880 Formaldehyde
00500 Total Solids	00927 Total Magnesium	01045 Total Iron	31616 Fecal Coliform	71900 Mercury
00530 TSS	00929 Total Sodium	01051 Lead	32730 Total Phenolics	81318 Ferrocyanides
00545 Settleable Solids	00940 Total Chloride	01067 Nickel	38260 MBAS	85652 Time

The monthly average for fecal coliform is to be reported as a geometric MEAN.

If using alternate units for reporting data, please designate.

EFFLUENT

PDES PERMIT NO: NC0003239 DISCHARGE NO: 002 MONTH: March YEAR: 1986
 FACILITY NAME: Tarawa Terrace STP CLASS: III COUNTY: Onslow
 OPERATOR IN RESPONSIBLE CHARGE (ORC): Mack D. Davis GRADE: IV
 CERTIFIED LABORATORY: Water Quality Control Laboratory

CHECK BLOCK IF ORC HAS CHANGED

Mail original and one copy to:
 AIT, Central Files
 Division of Environmental Management
 N.C. Department of NRCD
 PO Box 27687
 Raleigh, North Carolina 27611

PERSON(S) COLLECTING SAMPLES: STP Operators

I CERTIFY THAT THIS REPORT
 IS ACCURATE AND COMPLETE TO
 THE BEST OF MY KNOWLEDGE.

X

Signature of operator in responsible charge

DATE	TIME 2400 CLOCK	COMPOSITE TIME	50050	00010	00403	00545	50060	00310	00340	00610	00500	00530	31616	00300	ENTER PARAMETER CODE ABOVE NAME AND UNITS BELOW			
			FLOW EFF <input checked="" type="checkbox"/>	TEMPERATURE CELSIUS		SETTLABLE MATTER	RESIDUAL CHLORINE	BOD5 20°C	COD	AMMONIA NITROGEN	TOTAL RESIDUE	TOTAL SUSPENDED RESIDUE	FECAL COLIFORM Geometric Mean	DISSOLVED OXYGEN				
			DAILY RATE		pH													
			MGD	C°	UNIT	ML/L	MG/L	MG/L	MG/L	MG/L	MG/L	MG/L	/100 ML	MG/L				
1	08		.830		6.4		5.0											
2	08		.880		6.6		4.0											
3	08	24	.880		6.7		5.0	20				8	0					
4	08	24	.850		6.6		5.0	17				5	0					
5	08	24	.820		6.7		4.0	20				5	210					
6	08	24	.850		6.6		4.5	21				6	0					
7	08	24	.830		6.6		4.5	26				7	2					
8	08		.840		6.5		4.5											
9	08		.850		6.6		5.0											
10	08	24	.840		6.6		5.0	19				8	0					
11	08	24	.830		6.6		5.0	21				13	0					
12	08	24	.830		6.6		4.0	24				11	0					
13	08	24	.850		6.6		4.0	3				12	0					
14	08	24	.800		6.4		5.0	27				23	0					
15	08		.880		6.3		5.0											
16	08		.870		6.4		5.0											
17	08	24	.860		6.4		4.0	21				6	0					
18	08	24	.880		6.5		4.0	23				8	6					
19	08	24	.885		6.5		4.0	21				4	4					
20	08	24	.900		6.5		4.0	24				11	0					
21	08	24	.895		6.5		4.0	19				8	0					
22	08		.870		6.4		4.0											
23	08		.860		6.4		5.0											
24	08	24	.860		6.5		4.0	25				9	10					
25	08	24	.870		6.5		4.0	19				8	4					
26	08	24	.860		6.5		4.0	9				7	6					
27	08	24	.860		6.6		4.0	19				8	2					
28	08	24	.860		6.5		4.0	25				14	0					
29	08		.880		6.6		5.0											
30	08		.724		6.6		4.0											
31	08	24	.868		6.7		5.0	22				12	0					
Average			.854				4.4	20				9	2.0					
Max.			.900		6.7		5.0	27				23	210					
Min.			.724		6.3		4.0	3				4	0					
Comp (C) / Grab (G)					G		G	C				C	G					
Monthly Limit					6-9			30				30	200					

Facility Status: (Please check one of the following)

All monthly averages and / or other limitation do meet permit monitoring requirements (Compliant)

All monthly averages and / or other limitation do not meet permit monitoring requirements (Noncompliant)

If the facility is noncompliant, please comment on corrective actions being taken in respect to equipment, operation, maintenance, etc. and a time table for improvements to be made.

(Attach additional sheets if necessary)

I certify that this Report is accurate and complete to the best of my knowledge:

 Signature of Permittee

PARAMETER CODES

00010	Temperature	00556	Oil and Grease	00950	Dissolved Fluoride	01077	Silver	39516	PCBS
00065	Stream Stage	00600	Total Nitrogen	01002	Total Arsenic	01087	Total Vanadium	39941	Roundup
00076	Turbidity	00610	Ammonia Nitrogen	01027	Cadmium	01092	Zinc	50047	Max. flow during 24-hr. period
00300	Dissolved Oxygen	00625	Total Kjeldahl Nitrogen	01032	Hexavalent Chromium	01105	Total Aluminum	50048	Min. flow during 24-hr. period
00310	BOD ₅	00665	Total Phosphorous	01034	Chromium	01147	Total Selenium	50050	Flow
00340	COD	00720	Cyanide	01037	Total Cobalt	31504	Total Coliform	50060	Total Residual Chlorine
00400	pH	00745	Total Sulfide	01042	Copper	31614	Fecal Coliform, MPN, Tube	71880	Formaldehyde
00500	Total Solids	00927	Total Magnesium	01045	Total Iron	31616	Fecal Coliform	71900	Mercury
00530	TSS	00929	Total Sodium	01051	Lead	32730	Total Phenolics	81318	Ferrocyanides
00545	Settleable Solids	00940	Total Chloride	01067	Nickel	38260	MBAS	85652	Time

The monthly average for fecal coliform is to be reported as a geometric MEAN.

If using alternate units for reporting data, please designate.

EFFLUENT

DES PERMIT NO: N00003239 DISCHARGE NO: 003 MONTH: March YEAR: 1986

CILITY NAME: Camp Johnson STP CLASS: II COUNTY: Onslow

ERATOR IN RESPONSIBLE CHARGE (ORC): Mack D.Davis GRADE: IV

RTIFIED LABORATORY: Water Quality Control Laboratory

CHECK BLOCK IF ORC HAS CHANGED PERSON(S) COLLECTING SAMPLES: STP Operators

Mail original and one copy to:
 ATT: Central Files
 Division of Environmental Management
 NC Department of NRCD
 P O Box 27687
 Raleigh North Carolina 27611

I CERTIFY THAT THIS REPORT
 IS ACCURATE AND COMPLETE TO
 THE BEST OF MY KNOWLEDGE.

X _____
 Signature of operator in responsible charge

DATE	TIME 24HR CLOCK	COMPOSITE TIME	50050	00010	00409	00545	50060	00310	00340	00610	00500	00530	31616	00300	ENTER PARAMETER CODE ABOVE NAME AND UNITS BELOW			
			FLOW	TEMPERATURE	PH	SETTLEABLE MATTER	RESIDUAL CHLORINE	BOD5 20°C	COD	AMMONIA NITROGEN	TOTAL RESIDUE	TOTAL SUSPENDED RESIDUE	FECAL COLIFORM	DISSOLVED OXYGEN				
EFF <input checked="" type="checkbox"/>	CELSIUS	ML/L	MG/L	MG/L											MG/L	MG/L	MG/L	MG/L
		DAILY RATE																
		HRS	MGD	C°	UNIT	ML/L	MG/L	MG/L	MG/L	MG/L	MG/L	MG/L	/100 ML	MG/L				
1	08		.363		6.7		5.0											
2	08		.402		6.6		5.0											
3	08		.401		7.1		5.0											
4	08	8	.460		6.8		5.0	19				6	260					
5	08		.370		6.8		5.0											
6	08	8	.389		6.6		0.0	19				14	0					
7	08		.367		6.9		5.0											
8	08		.531		6.8		5.0											
9	08		.391		6.9		5.0											
10	08		.425		6.7		5.0											
11	08	8	.412		7.1		5.0	17				16	0					
12	08		.430		6.8		4.0											
13	08	8	.394		6.8		6.0	18				8	0					
14	08		.742		7.0		5.0											
15	08		.380		7.0		5.0											
16	08		.396		6.5		5.0											
17	08		.487		7.0		4.0											
18	08	8	.416		6.5		5.0	14				5	0					
19	08		.675		6.4		4.0											
20	08	8	.490		6.6		2.0	12				6	0					
21	08		.423		6.6		5.0											
22	08		.407		6.5		4.0											
23	08		.434		6.6		4.0											
24	08		.438		6.8		4.0											
25	08	8	.447		6.8		4.0	12				9	0					
26	08		.511		6.9		4.0											
27	08	8	.547		7.0		4.0	13				6	0					
28	08		.519		6.9		4.0											
29	08		.333		6.4		6.0											
30	08		.359		6.5		6.0											
31	08		.413		7.0		6.0											
Average			.444				4.5	16				9	2.0					
Max.			.675		7.1		6.0	19				16	260					
Min.			.333		6.4		0.0	12				5	0					
Comp (C)/ Grab(G)					G		G	C				C	G					
Monthly Limit					6-9			30				30	200					

Facility Status: (Please check one of the following)

All monthly averages and / or other limitation do meet permit monitoring requirements (Compliant)

All monthly averages and / or other limitation do not meet permit monitoring requirements (Noncompliant)

If the facility is noncompliant, please comment on corrective actions being taken in respect to equipment, operation, maintenance, etc. and a time table for improvements to be made.
(Attach additional sheets if necessary)

See cover letter for explanation.

I certify that this Report is accurate and complete to the best of my knowledge:

Signature of Permittee

PARAMETER CODES

00010 Temperature	00556 Oil and Grease	00950 Dissolved Fluoride	01077 Silver	39516 PCBS
00065 Stream Stage	00600 Total Nitrogen	01002 Total Arsenic	01087 Total Vanadium	39941 Roundup
00076 Turbidity	00610 Ammonia Nitrogen	01027 Cadmium	01092 Zinc	50047 Max. flow during 24-hr. period
00300 Dissolved Oxygen	00625 Total Kjeldahl Nitrogen	01032 Hexavalent Chromium	01105 Total Aluminum	50048 Min. flow during 24-hr. period
00310 BOD ₅	00665 Total Phosphorous	01034 Chromium	01147 Total Selenium	50050 Flow
00340 COD	00720 Cyanide	01037 Total Cobalt	31504 Total Coliform	50060 Total Residual Chlorine
00400 pH	00745 Total Sulfide	01042 Copper	31614 Fecal Coliform, MPN, Tube	71880 Formaldehyde
00500 Total Solids	00927 Total Magnesium	01045 Total Iron	31616 Fecal Coliform	71900 Mercury
00540 TSS	00929 Total Sodium	01051 Lead	32730 Total Phenolics	81318 Ferriocyanides
00545 Settleable Solids	00940 Total Chloride	01067 Nickel	38260 MBAS	85652 Time

The monthly average for fecal coliform is to be reported as a geometric MEAN.

If using alternate units for reporting data, please designate.

EFFLUENT

DES PERMIT NO: NC0003239 DISCHARGE NO: 004 MONTH: March YEAR: 1986

QUALITY NAME: Hadnot Point STP CLASS: IV COUNTY: Onslow

OPERATOR IN RESPONSIBLE CHARGE (ORC): Mack D. Davis GRADE: IV

CERTIFIED LABORATORY: Water Quality Laboratory

PERSON(S) COLLECTING SAMPLES: STP Operators

CHECK BLOCK IF ORC HAS CHANGED

Mail original and one copy to:
 ATT: Central Files
 Division of Environmental Management
 NC Department of NRCD
 PO Box 27687
 Raleigh, North Carolina 27611

I CERTIFY THAT THIS REPORT
 IS ACCURATE AND COMPLETE TO
 THE BEST OF MY KNOWLEDGE.

X _____
 Signature of operator in responsible charge

DATE	TIME 2400 CLOCK	COMPOSITE TIME	50050	00010	00403	00545	50060	00310	00340	00610	00500	00530	31616	00300	31504	ENTER PARAMETER CODE ABOVE NAME AND UNITS BELOW		
			FLOW EFF <input checked="" type="checkbox"/> INF <input checked="" type="checkbox"/>	TEMPERATURE CELSIUS	pH	SETTLABLE MATTER	RESIDUAL CHLORINE	BOD5 20°C	COD	AMMONIA NITROGEN	TOTAL RESIDUE	TOTAL SUSPENDED RESIDUE	FECAL COLIFORM <small>Geometric Mean</small>	DISSOLVED OXYGEN	TOTAL COLIFORM GEOMETRIC MEAN			
			MGD	C°	UNIT	ML/L	MG/L	MG/L	MG/L	MG/L	MG/L	MG/L	/100 ML	MG/L	/100 ML			
08			3.754		6.9		4.0											
1	08		3.699		6.8		4.0											
3	08	24	4.301		6.8		4.0	16				9				20		
4	08	24	4.320		6.8		4.0	16				4				20		
5	08	24	4.403		6.8		4.0	21				5				0		
6	08	24	4.016		6.8		4.0	21				6				30		
7	08	24	4.011		6.9		4.0	27				6				1000		
8	08		3.650		6.8		4.0											
9	08		3.609		6.8		4.0											
10	08	24	4.059		6.8		4.0	18				8				10		
11	08	24	4.200		6.9		3.7	18				12				0		
12	08	24	3.971		6.9		3.9	15				7				8		
13	08	24	4.323		6.9		4.0	15				6				10		
14	08	24	5.970		7.0		4.0	26				21				4		
15	08		4.757		6.9		4.0											
15	08		4.777		6.8		4.0											
17	08	24	5.571		6.8		4.0	16				9				104		
18	08	24	5.922		6.9		4.0	17				7				16		
18	08	24	4.966		7.0		4.0	26				10				160		
20	08	24	5.179		6.9		4.0	19				8				6		
21	08	24	4.664		6.9		4.0	20				8				0		
22	08		3.813		6.8		4.0											
23	08		3.882		6.8		4.0											
24	08	24	3.721		-		4.0	16				5				66		
25	08	24	3.720		6.8		4.0	15				6				16		
26	08	24	3.835		6.9		4.0	9				5				12		
27	08	24	4.258		6.9		4.0	25				9				30		
28	08	24	4.012		6.8		4.0	23				11				20		
29	08		3.748		6.9		4.0											
30	08		4.073		-		4.0											
31	08	24	4.525		6.8		4.0	13				6				14		
Average			4.313				4.0	19				8				15.2		
Max.			5.970		7.0		4.0	27				21				1000		
Min.			3.609		6.8		3.7	9				4				0		
Comp.(C)/Grab(G)					G		G	C				C				G		
Monthly Limit					6-9			30				30				70		

Facility Status: (Please check one of the following)

All monthly averages and / or other limitation do meet permit monitoring requirements

(Compliant)

All monthly averages and / or other limitation do not meet permit monitoring requirements

(Noncompliant)

If the facility is noncompliant, please comment on corrective actions being taken in respect to equipment, operation, maintenance, etc. and a time table for improvements to be made.

(Attach additional sheets if necessary)

I certify that this Report is accurate and complete to the best of my knowledge:

 Signature of Permittee

PARAMETER CODES

00010	Temperature	00556	Oil and Grease	00950	Dissolved Fluoride	01077	Silver	39516	PCBS
00065	Sediment Stage	00600	Total Nitrogen	01002	Total Arsenic	01087	Total Vanadium	39941	Roundup
00074	Turbidity	00610	Ammonia Nitrogen	01027	Cadmium	01092	Zinc	50047	Max. flow during 24-hr. period
00090	Dissolved Oxygen	00635	Total Kjeldahl Nitrogen	01032	Hexavalent Chromium	01105	Total Aluminum	50048	Min. flow during 24-hr. period
00110	BOD ₅	00665	Total Phosphorous	01034	Chromium	01147	Total Selenium	50050	Flow
00140	COD	00720	Cyanide	01037	Total Cobalt	31504	Total Coliform	50060	Total Residual Chlorine
00408	pH	00745	Total Sulfide	01042	Copper	31614	Fecal Coliform, MPN, Tube	71880	Formaldehyde
00500	Total Solids	00927	Total Magnesium	01045	Total Iron	31616	Fecal Coliform	71900	Mercury
00530	TSS	00929	Total Sodium	01051	Lead	32730	Total Phenolics	81318	Ferrocyanides
00540	Settleable Solids	00940	Total Chloride	01067	Nickel	38260	MBAS	85652	Time

The monthly average for fecal coliform is to be reported as a geometric MEAN.

If using alternate units for reporting data, please designate.

EFFLUENT

DES PERMIT NO: NC0003239 DISCHARGE NO: 005 MONTH: March YEAR: 1986
 FACILITY NAME: Rifle Range STP CLASS: II COUNTY: Onslow
 OPERATOR IN RESPONSIBLE CHARGE (ORC): Mack D. Davis GRADE: IV
 CERTIFIED LABORATORY: Water Quality Control Laboratory

PERSON(S) COLLECTING SAMPLES: STP Operators

CHECK BLOCK IF ORC HAS CHANGED

Mail original and one copy to:
 ATT: Central Files
 Division of Environmental Management
 N.C. Department of NRCD
 PO Box 27687
 Raleigh, North Carolina 27611

I CERTIFY THAT THIS REPORT
 IS ACCURATE AND COMPLETE TO
 THE BEST OF MY KNOWLEDGE.

X

Signature of operator in responsible charge

DATE	TIME 2400 CLOCK	COMPOSITE TIME	50050	00010	00400	00545	50060	00310	00340	00610	00500	00530	316'6	00300	31504		
			FLOW	EFF <input checked="" type="checkbox"/>	INF <input type="checkbox"/>	DAILY RATE	TEMPERATURE	pH	SETTLABLE MATTER	RESIDUAL CHLORINE	BOD5 20°C	COD	AMMONIA NITROGEN	TOTAL RESIDUE	TOTAL SUSPENDED RESIDUE	FECAL COLIFORM	DISSOLVED OXYGEN
			MGD	C°	UNIT	ML/L	MG/L	MG/L	MG/L	MG/L	MG/L	MG/L	/100 ML	MG/L	ENTER PARAMETER CODE ABOVE NAME AND UNITS BELOW		
108			.15745		6.4		5.3										
108			.20826		6.5		4.7										
108			.16841		6.6		7.5										
108 8			.16898		6.5		3.5	11				1				0	
108 8			.21021		6.5		2.6										
108 8			.16791		6.5		5.0	7				4				0	
108			.18303		6.5		3.7										
108			.17656		6.6		4.6										
108			.17939		6.5		5.7										
108			.16668		6.6		4.6										
108 8			.19379		6.5		4.5	6				5				0	
108			.19492		6.5		3.3										
108 8			.17085		6.6		3.3	6				2				0	
108			.31334		6.5		3.5										
108			.24216		6.5		5.1										
108			.23558		6.6		6.0										
108			.24358		6.5		6.0										
108 8			.22752		6.5		6.0	9				3				0	
108			.23485		6.5		3.0										
108 8			.25292		6.5		3.3	11				5				0	
108			.24064		6.5		4.9										
108			.22329		6.4		2.7										
108			.24004		6.3		5.5										
108			.20793		6.4		5.0										
108 8			.22723		6.4		4.2	8				6				10	
108			.23117		6.4		5.0										
108 8			.29699		6.6		4.0	11				4				2	
108			.16949		6.3		3.4										
108			.21338		6.3		7.4										
108			.19886		6.3		8.0										
108			.18992		6.3		8.0										
Average			.21082				4.8	9				4				1.6	
Max.			.31334		6.6		8.0	11				6				10	
Min.			.15745		6.3		2.6	6				1				0	
Comp.(C)/Grab(G)					G		G	C				C				G	
Monthly Limit					6-9			30				30				70	

Facility Status: (Please check one of the following)

All monthly averages and / or other limitation do meet permit monitoring requirements

(Compliant)

All monthly averages and / or other limitation do not meet permit monitoring requirements

(Noncompliant)

If the facility is noncompliant, please comment on corrective actions being taken in respect to equipment, operation, maintenance, etc. and a time table for improvements to be made.

(Attach additional sheets if necessary)

See cover letter for explanation.

I certify that this Report is accurate and complete to the best of my knowledge:

Signature of Permittee

PARAMETER CODES

00010 Temperature	00556 Oil and Grease	00950 Dissolved Fluoride	01077 Silver	39516 PCBS
00040 Stream Stage	00600 Total Nitrogen	01002 Total Arsenic	01087 Total Vanadium	39941 Roundup
00070 Turbidity	00610 Ammonia Nitrogen	01027 Cadmium	01092 Zinc	50047 Max. flow during 24-hr. period
00100 Dissolved Oxygen	00625 Total Kjeldahl Nitrogen	01032 Hexavalent Chromium	01105 Total Aluminum	50048 Min. flow during 24-hr. period
00310 TSS	00665 Total Phosphorous	01034 Chromium	01147 Total Selenium	50050 Flow
00320 TSS	00720 Cyanide	01037 Total Cobalt	31504 Total Coliform	50060 Total Residual Chlorine
00400 pH	00745 Total Sulfide	01042 Copper	31614 Fecal Coliform, MPN, Tube	71880 Formaldehyde
00500 Total Solids	00927 Total Magnesium	01045 Total Iron	31616 Fecal Coliform	71900 Mercury
00530 TSS	00929 Total Sodium	01051 Lead	32730 Total Phenolics	81318 Ferrocyanides
00540 Filterable Solids	00940 Total Chloride	01067 Nickel	38260 MBAS	85652 Time

The monthly average for fecal coliform is to be reported as a geometric MEAN.

If using alternate units for reporting data, please designate.

EFFLUENT

PDES PERMIT NO: NCO003239 DISCHARGE NO: 006 MONTH: March YEAR: 1986

FACILITY NAME: Courthouse Bay STP CLASS: II COUNTY: Onslow

OPERATOR IN RESPONSIBLE CHARGE (ORC): Mack D. Davis GRADE: IV

CERTIFIED LABORATORY: Water Quality Laboratory

PERSON(S) COLLECTING SAMPLES: STP Operators

CHECK BLOCK IF ORC HAS CHANGED

Mail original and one copy to
ATTN: Central Files
Division of Environmental Management
N.C. Department of NRCD
PO Box 27687
Raleigh, North Carolina 27611

I CERTIFY THAT THIS REPORT
IS ACCURATE AND COMPLETE TO
THE BEST OF MY KNOWLEDGE.

X

Signature of operator in responsible charge

DATE	TIME 2400 CLOCK	COMPOSITE TIME	50050	00010	00409	00545	50060	00310	00340	00610	00500	00530	31616	00300	ENTER PARAMETER CODE ABOVE NAME AND UNITS BELOW		
			FLOW	TEMPERATURE	pH	SETTLABLE MATTER	RESIDUAL CHLORINE	BOD5 20°C	COD	AMMONIA NITROGEN	TOTAL RESIDUE	TOTAL SUSPENDED RESIDUE	FECAL COLIFORM	DISSOLVED OXYGEN	TOTAL COLIFORM GEOMETRIC MEAN		
EFF <input checked="" type="checkbox"/>	CELSIUS	DAILY RATE	ML/L	MG/L												MG/L	MG/L
1	08		.25450		6.8		3.9										
2	08		.31430		6.8		2.7										
3	08		.46910		6.7		1.9										
4	08	8	.46340		6.7		2.0	13				3				0	
5	08		.44090		6.8		1.8										
6	08	8	.31212		6.9		1.6	13				7				N.S.	
7	08		.44714		6.7		2.9										
8	08		.45461		6.7		4.3										
9	08		.45408		6.7		4.0										
10	08		.45406		6.5		4.1										
11	08	8	.35794		6.7		2.8	13				12				0	
12	08		.56220		6.7		3.1										
13	08	8	.50620		6.6		1.9	8				4				0	
14	08		.48580		6.7		1.7										
15	08		.48380		6.7		1.8										
16	08		.48710		6.6		2.0										
17	08		.48560		6.7		2.0										
18	08	8	.44900		6.7		2.0	8				1				2	
19	08		.46550		6.6		2.4										
20	08	8	.48820		6.6		1.5	8				1				0	
21	08		.44360		6.7		2.0										
22	08		.44600		6.6		1.8										
23	08		.49230		6.6		3.3										
24	08		.33430		6.7		3.1										
25	08	8	.33210		6.8		1.8	7				10				20	
26	08		.30310		6.8		1.4									:	
27	08	8	.36300		6.8		2.4	11				9				0	
28	08		.36300		6.6		2.8										
29	08		.47130		6.9		2.9										
30	08		.21750		6.7		4.2										
31	08		.42430		6.8		2.1										
Average			.420195				2.5	10				6				1.6	
Max.			.56220		6.9		4.3	13				12				20	
Min.			.25450		5.5		1.4	7				1				0	
Comp. C/ Grab(G)					G		G	C				C				G	
Monthly Limit					6-9			30				30				70	

N.S. = No Sample

Facility Status: (Please check one of the following)

All monthly averages and / or other limitation do meet permit monitoring requirements

(Compliant)

All monthly averages and / or other limitation do not meet permit monitoring requirements

(Noncompliant)

If the facility is noncompliant, please comment on corrective actions
being taken in respect to equipment, operation, maintenance, etc. and
a time table for improvements to be made.

(Attach additional sheets if necessary)

I certify that this Report is accurate
and complete to the best of my knowledge:

Signature of Permittee

PARAMETER CODES

00010	Temperature	00556	Oil and Grease	00950	Dissolved Fluoride	01077	Silver	39516	PCBS
00065	Stream Stage	00600	Total Nitrogen	01002	Total Arsenic	01087	Total Vanadium	39941	Roundup
00076	Turbidity	00610	Ammonia Nitrogen	01027	Cadmium	01092	Zinc	50047	Max. flow during 24-hr. period
00300	Dissolved Oxygen	00625	Total Kjeldahl Nitrogen	01032	Hexavalent Chromium	01105	Total Aluminum	50048	Min. flow during 24-hr. period
00310	BOD	00665	Total Phosphorous	01034	Chromium	01147	Total Selenium	50050	Flow
00348	COD	00720	Cyanide	01037	Total Cobalt	31504	Total Coliform	50060	Total Residual Chlorine
00490	pH	00745	Total Sulfide	01042	Copper	31614	Fecal Coliform, MPN, Tube	71880	Formaldehyde
00500	Total Solids	00927	Total Magnesium	01045	Total Iron	31616	Fecal Coliform	71900	Mercury
00530	TSS	00929	Total Sodium	01051	Lead	32730	Total Phenolics	81318	Ferrocyanides
00540	Settleable Solids	00940	Total Chloride	01067	Nickel	38260	MBAS	85652	Time

The monthly average for fecal coliform is to be reported as a geometric MEAN.

If using alternate units for reporting data, please designate.

EFFLUENT

DES PERMIT NO: NCO003239 DISCHARGE NO: 007 MONTH: March YEAR: 1986

CILITY NAME: Onslow Beach STP CLASS: II COUNTY: Onslow

ERATOR IN RESPONSIBLE CHARGE (ORC): Mack D. Davis GRADE: IV

RTIFIED LABORATORY: Water Quality Control Laboratory

CHECK BLOCK IF ORC HAS CHANGED

Mail original and one copy to:
 411 Central Files
 Division of Environmental Management
 N.C. Department of NRCD
 P.O. Box 27687
 Raleigh, North Carolina 27611

PERSON(S) COLLECTING SAMPLES: STP Operators

I CERTIFY THAT THIS REPORT
 IS ACCURATE AND COMPLETE TO
 THE BEST OF MY KNOWLEDGE.

X _____
 Signature of operator in responsible charge

DATE	TIME 2400 CLOCK	COMPOSITE TIME	50050	00010	00409	00545	50060	00310	00340	00610	00500	00530	316'6	00300	3/5/86		
			FLOW EFF <input type="checkbox"/> INF <input checked="" type="checkbox"/>	TEMPERATURE CELSIUS	pH	SETTLABLE MATTER	RESIDUAL CHLORINE	BOD5 20°C	COD	AMMONIA NITROGEN	TOTAL RESIDUE	TOTAL SUSPENDED RESIDUE	FECAL COLIFORM Geometric Mean	DISSOLVED OXYGEN	ENTER PARAMETER CODE ABOVE NAME AND UNITS BELOW		
		HRS	MGD	°C	UNIT	ML/L	MG/L	MG/L	MG/L	MG/L	MG/L	MG/L	/100 ML	MG/L	TOTAL COLIFORM GEOMETRIC MEAN		
1	08		.08014		6.5		4.0										
2	08		.06952		6.5		4.0										
3	08		.09361		6.3		4.1										
4	08	8	.16695		6.3		4.0	12				2			0		
5	08		.17843		6.5		6.0										
6	08	8	.19118		6.6		5.0	18				5			12		
7	08		.13522		6.4		4.0										
8	08		.16887		6.4		5.0										
9	08		.19385		6.6		5.0										
10	08		.19194		6.4		4.0										
11	08	8	.14816		6.6		5.0	17				11			0		
12	08		.16713		6.5		4.0										
13	08	8	.10294		6.8		4.0	20				3			16		
14	08		.15870		6.5		5.0										
15	08		.12483		6.4		6.0										
16	08		.14401		6.6		5.0										
17	08		.15818		6.0		5.0										
18	08	8	.17512		6.3		5.0	26				J..E.			2		
19	08		.11620		6.6		5.0										
20	08	8	.13574		6.5		4.0	17				2			0		
21	08		.11039		6.5		5.0										
22	08		.11039		6.5		5.0										
23	08		.16561		6.4		4.0										
24	08		.10796		6.4		4.0										
25	08	8	.10464		6.5		6.0	9				6			10		
26	08		.08438		6.6		6.0										
27	08	8	.08438		6.4		5.0	15				1			0		
28	08		.06888		6.4		6.0										
29	08		.07661		6.4		4.0										
30	08		.09111		6.6		6.0										
31	08		.08146		7.0		4.0										
Average			.128597				4.8	17				4			2.8		
Max.			.19385		7.0		6.0	26				11			16		
Min.			.06888		6.0		4.0	9				1			0		
Comp (C)/ Grab (G)					G		G	C				C			C		
Monthly Limit					6-9			30				30			70		

Facility Status: (Please check one of the following)

All monthly averages and / or other limitation do meet permit monitoring requirements (Compliant)

All monthly averages and / or other limitation do not meet permit monitoring requirements (Noncompliant)

If the facility is noncompliant, please comment on corrective actions being taken in respect to equipment, operation, maintenance, etc. and a time table for improvements to be made.
(Attach additional sheets if necessary)

See cover letter for explanation.

I certify that this Report is accurate and complete to the best of my knowledge:

Signature of Permittee

PARAMETER CODES

00010	Temperature	00556	Oil and Grease	00950	Dissolved Fluoride	01077	Silver	39516	PCBS
00065	Stream Stage	00600	Total Nitrogen	01002	Total Arsenic	01087	Total Vanadium	39941	Roundup
00076	Turbidity	00610	Ammonia Nitrogen	01027	Cadmium	01092	Zinc	50047	Max. flow during 24-hr. period
00390	Dissolved Oxygen	00625	Total Kjeldahl Nitrogen	01032	Hexavalent Chromium	01105	Total Aluminum	50048	Min. flow during 24-hr. period
00310	pH	00665	Total Phosphorous	01034	Chromium	01147	Total Selenium	50050	Flow
00360	CO ₂	00720	Cyanide	01037	Total Cobalt	31504	Total Coliform	50060	Total Residual Chlorine
00400	pH	00745	Total Sulfide	01042	Copper	31614	Fecal Coliform, MPN, Tube	71880	Formaldehyde
00500	Total Solids	00927	Total Magnesium	01045	Total Iron	31616	Fecal Coliform	71900	Mercury
00540	TSS	00929	Total Sodium	01051	Lead	32730	Total Phenolics	81318	Ferrocyanides
00545	Settleable Solids	00940	Total Chloride	01067	Nickel	38260	MBAS	85652	Time

The monthly average for fecal coliform is to be reported as a geometric MEAN.

If using alternate units for reporting data, please designate.

EFFLUENT

DES PERMIT NO: N00003239 DISCHARGE NO: 014 MONTH: March YEAR: 1986

CILITY NAME: Onslow Beach Water Treatment Pond CLASS: NA COUNTY: Onslow

OPERATOR IN RESPONSIBLE CHARGE (ORC): Mack D. Davis GRADE: IV

CERTIFIED LABORATORY: Water Quality Control Laboratory

CHECK BLOCK IF ORC HAS CHANGED

Mail original and one copy to:
 ATT Central Files
 Division of Environmental Management
 NC Department of NRCD
 PO Box 27687
 Raleigh North Carolina 27611

PERSON(S) COLLECTING SAMPLES: WTP Operators

I CERTIFY THAT THIS REPORT
 IS ACCURATE AND COMPLETE TO
 THE BEST OF MY KNOWLEDGE.

X _____
 Signature of operator in responsible charge

DATE	TIME 2400 CLOCK	COMPOSITE TIME	50050	00010	00400	00545	50060	00310	00340	00610	00500	00530	31616	00300	ENTER PARAMETER CODE ABOVE NAME AND UNITS BELOW		
			FLOW	TEMPERATURE	pH	SETTLABLE MATTER	RESIDUAL CHLORINE	BOD5 20°C	COD	AMMONIA NITROGEN	TOTAL RESIDUE	TOTAL SUSPENDED RESIDUE	FECAL COLIFORM	DISSOLVED OXYGEN			
DAILY RATE	° CELSIUS	MG/L	MG/L	MG/L											MG/L	MG/L	MG/L
1																	
2																	
3																	
4	8				8.1							2.0					
5																	
6																	
7																	
8																	
9																	
10																	
11	8				8.1							6.0					
12																	
13																	
14																	
15																	
16																	
17																	
18	8				7.8							2.0					
19																	
20																	
21																	
22																	
23																	
24																	
25	8				8.2							2.3					
26																	
27																	
28																	
29																	
30																	
31																	
Average												3.1					
Max					8.2							6.0					
Min					7.8							2.0					
Comp (C)/Grab(G)					G							C					
Monthly Limit					6-10							30					

Facility Status: (Please check one of the following)

All monthly averages and / or other limitation do meet permit monitoring requirements

(Compliant)

All monthly averages and / or other limitation do not meet permit monitoring requirements

(Noncompliant)

If the facility is noncompliant, please comment on corrective actions being taken in respect to equipment, operation, maintenance, etc. and a time table for improvements to be made.

(Attach additional sheets if necessary)

I certify that this Report is accurate and complete to the best of my knowledge:

 Signature of Permittee

PARAMETER CODES

00010 Temperature	00556 Oil and Grease	00950 Dissolved Fluoride	01077 Silver	39516 PCBS
00065 Stream Stage	00600 Total Nitrogen	01002 Total Arsenic	01087 Total Vanadium	39941 Roundup
00076 Turbidity	00610 Ammonia Nitrogen	01027 Cadmium	01092 Zinc	50047 Max. flow during 24-hr. period
00300 Dissolved Oxygen	00625 Total Kjeldahl Nitrogen	01032 Hexavalent Chromium	01105 Total Aluminum	50048 Min. flow during 24-hr. period
00310 BOD	00665 Total Phosphorous	01034 Chromium	01147 Total Selenium	50050 Flow
00340 pH	00720 Cyanide	01037 Total Cobalt	31504 Total Coliform	50060 Total Residual Chlorine
00350 Solids	00745 Total Sulfide	01042 Copper	31614 Fecal Coliform, MPN, Tube	71880 Formaldehyde
00360 Suspended Solids	00927 Total Magnesium	01045 Total Iron	31616 Fecal Coliform	71900 Mercury
00370 Total Solids	00929 Total Sodium	01051 Lead	32730 Total Phenolics	81318 Ferrocyanides
00380 Filterable Solids	00940 Total Chloride	01067 Nickel	38260 MBAS	85652 Time

The monthly average for fecal coliform is to be reported as a geometric MEAN.

If using alternate units for reporting data, please designate.

Influent

NPDES NO: NC0003239 DISCHARGE NO: 001 MONTH: March YEAR: 1986

FACILITY NAME: Camp Geiger STP COUNTY: Onslow

		00400	00010	00545	00310	00610	00500	00530	00340	ENTER PARAMETER CODE ABOVE & NAME AND UNITS BELOW								
Time	Composite Time	PH	Temperature (Celsius)	Settleable Matter	BOD ₅ 20 °C	Ammonia Nitrogen	Total Residue	Total Suspended Residue	COD									
		STD UNITS	°C	ML/L	MG/L	MG/L	MG/L	MG/L	MG/L									
1																		
2																		
3	08	24			104			122										
4	08	24			120			110										
5	08	24			112			64										
6	08	24			144			78										
7	08	24			228			180										
8																		
9																		
10	08	24			120			104										
11	08	24			132			118										
12	08	24			124			94										
13	08	24			196			226										
14	08	24			168			168										
15																		
16																		
17	08	24			84			36										
18	08	24			72			18										
19	08	24			136			66										
20	08	24			84			60										
21	08	24			88			50										
22																		
23																		
24	08	24			92			53										
25	08	24			100			92										
26	08	24			52			92										
27	08	24			216			34										
28	08	24			140			82										
29																		
30																		
31	08	24			188			96										
AVERAGE					129			93										
MONTHLY MAXIMUM					228			226										
MONTHLY MINIMUM					52			18										
SAMPLE TYPE C or G					C			C										



Influent

NPDES NO: NC0003239 DISCHARGE NO: 002 MONTH: March YEAR: 1986

FACILITY NAME: Tarawa Terrace COUNTY: Onslow

		00400	00010	00545	00310	00610	00500	00530	00340	ENTER PARAMETER CODE ABOVE & NAME AND UNITS BELOW								
Time	Composite Time	PH	Temperature (Celsius)	Settleable Matter	BOD ₅ 20 °C	Ammonia Nitrogen	Total Residue	Total Suspended Residue	COD									
		STD UNITS	°C	ML/L	MG/L	MG/L	MG/L	MG/L	MG/L									
08	24				200			222										
08	24				152			398										
08	24				164			118										
08	24				140			112										
08	24				220			73										
08	24				176			93										
08	24				176			170										
08	24				164			94										
08	24				168			166										
08	24				136			396										
08	24				136			146										
08	24				136			183										
08	24				184			174										
08	24				148			178										
08	24				116			435										
08	24				168			124										
08	24				172			173										
08	24				152			132										
08	24				200			76										
08	24				228			170										
08	24				164			268										
AVERAGE								167										
MONTHLY MAXIMUM								228										
MONTHLY MINIMUM								116										
SAMPLE TYPE C or G								C										




Influent

NPDES NO: NC0003239 DISCHARGE NO: 003 MONTH: March YEAR: 1986

FACILITY NAME: Camp Johnson STP COUNTY: Onslow

		00400	00010	00545	00310	00610	00500	00530	00340	ENTER PARAMETER CODE ABOVE & NAME AND UNITS BELOW			
Time	Composite Time	PH	Temperature (Celsius)	Settleable Matter	BOD ₅ 20 °C	Ammonia Nitrogen	Total Residue	Total Suspended Residue	COD				
		HRS	STD UNITS	°C	MI/L	MG/L	MG/L	MG/L	MG/L	MG/L			
1	08	8			68			28					
2													
3													
4	08	8			112			93					
5													
6													
7													
8	08	8			188			148					
9													
0	08	8			160			64					
1													
2													
3													
4													
5	08	8			28			16					
6													
7	08	8			52			32					
8													
9													
0													
1	08	8			144			105					
2													
3													
4	08	8			80			46					
5													
6													
7													
8													
9													
0													
1													
AVERAGE					104			67					
MONTHLY MAXIMUM					188			148					
MONTHLY MINIMUM					28			16					
SAMPLE TYPE C or G					C			C					




Influent

NPDES NO: NC0003239 DISCHARGE NO: 004 MONTH: March YEAR: 1986

FACILITY NAME: Hadnot Point STP COUNTY: Onslow

		00400	00010	00545	00310	00610	00500	00530	00340	ENTER PARAMETER CODE ABOVE & NAME AND UNITS BELOW						
Date	Time	Composite Time	PH	Temperature (Celsius)	Settleable Matter	BOD ₅ 20 °C	Ammonia Nitrogen	Total Residue	Total Suspended Residue	COD						
		HRS	STD UNITS	°C	ML/L	MG/L	MG/L	MG/L	MG/L	MG/L						
2																
3	08	24				112			122							
4	08	24				136			96							
5	08	24				132			114							
6	08	24				96			58							
7	08	24				116			56							
8																
9																
10	08	24				156			160							
11	08	24				96			68							
12	08	24				112			64							
13	08	24				188			108							
14	08	24				244			325							
15																
16																
17	08	24				116			62							
18	08	24				144			162							
19	08	24				192			102							
20	08	24				108			108							
21	08	24				116			88							
22																
23																
24	08	24				116			102							
25	08	24				132			110							
26	08	24				136			150							
27	08	24				132			116							
28	08	24				128			100							
29																
30																
31	08	24				148			108							
AVERAGE						136			113							
MONTHLY MAXIMUM						244			325							
MONTHLY MINIMUM						96			56							
SAMPLE TYPE C or G						C			C							




Influent

NPDES NO: NC0003239 DISCHARGE NO: 005 MONTH: March YEAR: 1986

FACILITY NAME: Rifle Range STP COUNTY: Onslow

		00400	00010	00545	00310	00610	00500	00530	00340	ENTER PARAMETER CODE ABOVE & NAME AND UNITS BELOW					
Time	Composite Time	PH	Temperature (Celsius)	Settleable Matter	BOD ₅ 20 °C	Ammonia Nitrogen	Total Residue	Total Suspended Residue	COD						
	HRS	STD UNITS	°C	MI/L	MG/L	MG/L	MG/L	MG/L	MG/L						
1	08	8			44			48							
2															
3															
4	08	8			40			14							
5															
6															
7															
8															
9	08	8			20			38							
0															
1															
2	08	8			24			38							
3															
4															
5															
6															
7															
8	08	8			40			29							
9															
0	08	8			68			24							
1															
2															
3															
4															
5	08	8			64			33							
6															
7	08	8			80			110							
8															
9															
0															
1															
AVERAGE					48			42							
MONTHLY MAXIMUM					80			110							
MONTHLY MINIMUM					20			14							
SAMPLE TYPE C or G					C			C							




Influent

NPDES NO: NC0003239 DISCHARGE NO: 006 MONTH: March YEAR: 1986

FACILITY NAME: Courthouse Bay STP COUNTY: Onslow


Time	Composite Time	00400	00010	00545	00310	00610	00500	00530	00340	ENTER PARAMETER CODE ABOVE & NAME AND UNITS BELOW								
		PH	Temperature (Celsius)	Settleable Matter	BOD ₅ 20 °C	Ammonia Nitrogen	Total Residue	Total Suspended Residue	COD									
		STD UNITS	°C	MI/L	MG/L	MG/L	MG/L	MG/L	MG/L	MG/L								
08	8				60			52										
08	8				120			3550										
08	8				148			278										
08	8				172			100										
08	8				60			56										
08	8				84			28										
08	8				104			144										
08	8				100			70										
AVERAGE					106			535										
MONTHLY MAXIMUM					172			3550										
MONTHLY MINIMUM					60			28										
SAMPLE TYPE C or G					C			C										




Influent

NPDES NO: NCO003239 DISCHARGE NO: 007 MONTH: March YEAR: 1986
 FACILITY NAME: Onslow Beach STP COUNTY: Onslow

		00400	00010	00545	00310	00610	00500	00530	00340	ENTER PARAMETER CODE ABOVE & NAME AND UNITS BELOW				
Time	Composite Time	PH	Temperature (Celsius)	Settleable Matter	BOD ₅ 20 °C	Ammonia Nitrogen	Total Residue	Total Suspended Residue	COD					
	HRS	STD UNITS	°C	MI/L	MG/L	MG/L	MG/L	MG/L	MG/L					
1														
2														
3														
4	08	8			60			32						
5														
6	08	8			72			32						
7														
8														
9														
10														
11	08	8			64			26						
12														
13	08	8			88			13						
14														
15														
16														
17														
18	08	8			44			15						
19														
20	08	8			212			35						
21														
22														
23														
24														
25	08	8			92			26						
26														
27	08	8			100			44						
28														
29														
30														
31														
AVERAGE					92			28						
MONTHLY MAXIMUM					212			44						
MONTHLY MINIMUM					44			13						
SAMPLE TYPE C or G					C			C						





NPDES NO: NC0003239 DISCHARGE NO: 002 MONTH: March YEAR: 1986

FACILITY NAME: Tarawa Terrace STP COUNTY: Onslow

STREAM: Northeast Creek STREAM: Northeast Creek


LOCATION: RW02 - At Hwy 24 Bridge LOCATION: RW03 - Between Discharge 002 & 003

Upstream

Downstream

00010		00300		00400		00310		00340		31616		00556					
Time 2400 Clock	Temperature (Celsius)	Dissolved Oxygen	PH	BOD5 20°C	COD	Fecal Coliform *Geometric Mean	OIL & GREASE	Enter Parameter Code above Name and Units Below									
HRS	°C	MG/L	STD UNITS	MG/L	MG/L	100 ml	MG/L										
09	12	8.7	6.9	0.3		6	N.R.										
average	12	8.7		0.3		6*											
daily maximum	12	8.7	6.9	0.3		6											
daily minimum	12	8.7	6.9	0.3		6											

00010		00300		00400		00310		00340		31616		00556					
Time 2400 Clock	Temperature (Celsius)	Dissolved Oxygen	PH	BOD5 20°C	COD	Fecal Coliform *Geometric Mean	OIL & GREASE	Enter Parameter Code above Name and Units Below									
HRS	°C	MG/L	STD UNITS	MG/L	MG/L	100 ml	MG/L										
10	12	10.2	7.7	2.0		42	N.R.										
	12	10.2		2.0		42*											
	12	10.2	7.7	2.0		42											
	12	10.2	7.7	2.0		42											



NPDES NO: NC0003239 DISCHARGE NO: 003 MONTH: March YEAR: 1986

FACILITY NAME: Camp Johnson STP COUNTY: Onslow

STREAM: Northeast Creek STREAM: New River


LOCATION: RW03 - Between Discharge 002 & 003 LOCATION: RW04 - Hospital Point

Upstream

Downstream

00010		00300		00400		00310		00340		31616		00536	
Time 2400 Clock	Temperature (Celsius)	Dissolved Oxygen	PH	BOD5 20°C	COD	Fecal Coliform *Geometric Mean	Enter Parameter Code above Name and Units Below						
HRS	°C	MG/L	STD UNITS	MG/L	MG/L	100 ml							
10	12	10.2	7.7	2.0		42	N.R.						
Average	12	10.2		2.0		42							
Daily Maximum	12	10.2	7.7	2.0		42							
Daily Minimum	12	10.2	7.7	2.0		42							

00010		00300		00400		00310		00340		31616		00536	
Time 2400 Clock	Temperature (Celsius)	Dissolved Oxygen	PH	BOD5 20°C	COD	Fecal Coliform *Geometric Mean	Enter Parameter Code above Name and Units Below						
HRS	°C	MG/L	STD UNITS	MG/L	MG/L	100 ml							
10	12	11.0	8.1	2.9		64	N.R.						
Average	12	11.0		2.9		64							
Daily Maximum	12	11.0	8.1	2.9		64							
Daily Minimum	12	11.0	8.1	2.9		64							




NPDES NO: N00003239 DISCHARGE NO: 004 MONTH: March YEAR: 1986
 FACILITY NAME: Hadnot Point STP COUNTY: Onslow
 STREAM: New River STREAM: New River
 LOCATION: RW04 - Hospital Point LOCATION: RW05 - Marker #35


Upstream

Downstream

Time		00010	00300	00400	00310	00340	31616	00556	Enter Parameter Code above Name and Units Below	
2400 Clock	Temperature (Celsius)	Dissolved Oxygen	PH	BOD5 20°C	COD	Fecal Coliform *Geometric Mean	OIL g	GREASE		
HRS	°C	MG/L	STD UNITS	MG/L	MG/L	100ml	MG/L			
10	12	11.0	8.1	2.9		64	N.R.			
Average	12	11.0		2.9		64				
Monthly Maximum	12	11.0	8.1	2.9		64				
Monthly Minimum	12	11.0	8.1	2.9		64				

Time		00010	00300	00400	00310	00340	31616	00556	Enter Parameter Code above Name and Units Below	
2400 Clock	Temperature (Celsius)	Dissolved Oxygen	PH	BOD5 20°C	COD	Fecal Coliform *Geometric Mean	OIL g	GREASE		
HRS	°C	MG/L	STD UNITS	MG/L	MG/L	100 ml	MG/L			
10	12	11.4	8.1	3.6		0	N.R.			
	12	11.4		3.6		0				
	12	11.4	8.1	3.6		0				
	12	11.4	8.1	3.6		0				





NPDES NO: NC0003239 DISCHARGE NO: 006 MONTH: March YEAR: 1986

FACILITY NAME: Courthouse Bay STP COUNTY: Onslow

STREAM: New River STREAM: New River


LOCATION: RW06 - Outside Sneads Ferry Bridge LOCATION: RW07 - Mouth of Inlet


Upstream

Downstream

		00010	00300	00400	00310	00340	31616	00556	Enter Parameter Code above Name and Units Below		
Time	2400 Clock	Temperature (Celsius)	Dissolved Oxygen	PH	BOD ₅ 20°C	COD	Fecal Coliform *Geometric Mean	01-L	01-L	01-L	01-L
HRS	°C	MG/L	STD UNITS	MG/L	MG/L	100 ml	MG/L				
10	12	10.6	8.1	1.6		4	N.R.				
Average	12	10.6	8.1	1.6		4					
Monthly Maximum	12	10.6	8.1	1.6		4					
Monthly Minimum	12	10.6	8.1	1.6		4					

		00010	00300	00400	00310	00340	31616	00556	Enter Parameter Code above Name and Units Below		
Time	2400 Clock	Temperature (Celsius)	Dissolved Oxygen	PH	BOD ₅ 20°C	COD	Fecal Coliform *Geometric Mean	01-L	01-L	01-L	01-L
HRS	°C	MG/L	STD UNITS	MG/L	MG/L	100 ml	MG/L				
11	12	9.6	8.1	0.3		0	N.R.				
Average	12	9.6	8.1	0.3		0					
Monthly Maximum	12	9.6	8.1	0.3		0					
Monthly Minimum	12	9.6	8.1	0.3		0					





STORM DRAINS

NPDES NO: NCO003239

MONTH: March

YEAR: 1986

LOCATION: Marine Corps Base, Camp Lejeune, NC

COUNTY: Onslow

<u>STORM DRAIN NUMBER</u>	<u>DATE COLLECTED</u>	<u>FLOW 50050</u>	<u>pH 00400</u>	<u>TOTAL SUSPENDED RESIDUE 00530</u>	<u>OIL & GREASE 00556</u>
34	13 Mar 86	291,600	7.7	0	0
35	13 Mar 86	No Flow			
39	11 Mar 86	Dry			
40	11 Mar 86	109,350	8.0	3.8	0
41	11 Mar 86	874,800	7.6	3.4	3.0
42	11 Mar 86	387,244	7.8	204.8	0
43	11 Mar 86	193,622	7.7	45.6	0
44	11 Mar 86	4,272,523	7.6	66.4	0
45	11 Mar 86	971,028	7.5	2.6	0.6
46	11 Mar 86	145,800	7.4	6.8	1.5
47	11 Mar 86	192,456	7.7	2.4	1.5
67	3 Mar 86	69,984	7.3	0.8	1.5
68	3 Mar 86	1,154,736	7.1	0.8	2.9
69	3 Mar 86	1,166,400	6.7	1.6	0
70	3 Mar 86	Dry			
71	3 Mar 86	Dry			
72	3 Mar 86	23,328	7.0	1.2	1.0
73	13 Mar 86	12,101	7.9	22	0
74	13 Mar 86	48,600	7.1	5	3.0
75	13 Mar 86	Dry			
76	13 Mar 86	Dry			
77	13 Mar 86	Dry			
78	13 Mar 86	218,700	7.0	8	0.1
79	13 Mar 86	19,421	7.7	2	0.8
80	13 Mar 86	Dry			
81	3 Mar 86	2,916,000	6.5	0.8	1.0
82	3 Mar 86	699,840	7.0	2.4	3.1
83	3 Mar 86	15,396	7.4	1.6	0
84	3 Mar 86	No Flow			
85	3 Mar 86	Dry			
86	3 Mar 86	874,800	7.0	0.4	0
87	3 Mar 86	583,200	6.8	2.4	0
88	3 Mar 86	Dry			

<u>PARAMETER</u>	<u>UNITS</u>	<u>LIMITS</u>
Flow	GPD	None
pH	None	6 - 9
TSR	mg/l	50 mg/l
O&G	mg/l	15 mg/l

