



DISTRICT PUBLIC WORKS OFFICE
 NAVAL BASE NORFOLK, VA.

APPROVED

SUBJECT TO THE REQUIREMENTS OF
 CONTRACT NO. 934000-1000

APPROVAL OF MATERIALS AND METHODS OF
 INDICATES CONFORMANCE WITH SPECIFICATION
 REQUIREMENTS FOR THE INSTALLATION
 DIMENSIONS AND MAKE THE ABOVE PHYSICAL
 TRACES ETC. AS REQUIRED.

D. T. L-557

FRACTIONAL MACHINING TOLERANCES 1/64
 (Unless Otherwise Specified)

GENERAL NOTES

NOTE PUMP SHOULD BE SET AT SUCH AN ELEVATION THAT THE TOTAL SUCTION LEAK INCLUDING PIPE FRICTION WHEN PUMP IS DELIVERING ITS FULL CAPACITY WILL NOT EXCEED 15 FEET.

WHEN UNIT IS SET ON CONCRETE FOUNDATION BOLTS SHOULD BE SET IN BOXES OR TUBES ABOUT TWICE THE SIZE OF THE BOLT FLANGES ARE 2 1/2\"/>

BASE: D22418
 ENG. CONT. M363
 MOTOR: RS 4055
 ORDER NO.: ATLANTA 14621

THIS DRAWING CERTIFIED
 For Order No. 4621
FAIRBANKS, MORSE & CO.
 Per: J.F. Date: 2-26-52

REV. NO.	LOC.	SERIAL NUMBER	DATE	WAG
7				
6				
5				
4				
3				
2				
1				

RELEASE NUMBER: _____ DATE OF RELEASE: _____

FAIRBANKS, MORSE & CO.
 KANSAS CITY WORKS
 ENGINEERING DIVISION

DRAWN BY: D.W. DATE: 2-20-52
 CHECKED: H.B. DATE: 2-25-52
 APPROVED: _____ DATE: _____
 SCALE: _____

SETTING PLAN

5:5013 D.V. CON. PUMP

MATERIAL SPECIFICATION: _____

DWG. NO. 5025A57

