m. Pruce



MELLIS CORPORATION P.O. Box 357 / 101 West McIver St. / Angler, N.C. 27501 / 919-639-4100

July 29, 1986

Van Marshburn c/o Resident Engineers Office Building 1005 Marine Corps Base Camp Lejeune, NC 28542

Subject: Our Job #85-1589

Sludge Settling & Recycling System Pump & Lighting Co. REF#49007-12D

Gentlemen:

Recently we contacted you during a visit at Camp Lejeune at which time we investigated the new Limitorque Sluice Gate controls and connected up our panel to operate in conjunction with those controls. We found taking the right hand set of wires in the control cabinet as you face the control cabinet that we would call this Sluice Gate #1. Wires 1, 2, & 3 in that bundle are not connected but should be the 460 volt, 3 phase line going out and tying to the incoming line on the Sluice Gate. We also believe that a disconnect switch should be made available for this particular line at the entrance into the limitorque as well as the disconnect from the supply within the building.

Wire #4 we have connected within our panel, as you note, and it should go to the CL1 terminal on the terminal block in the limitorque.

Wire #6 should go to terminal #4 in the limitorque and it is hooked up in the control panel. Wire #7 should go to position #8 on the terminal block in the limitorque. Wire #5 should go to position CL2 in the limitorque. We have all of the wires connected within our panel as shown in very rough sketch on the limitorque wiring diagram. We are in the process of refining this drawing but thought you might want to get this in your hands as soon as possible for a future field connection in the event you put it in within the next few days.

We appreciate the opportunity to work with you and will get you any additional information you require.

Yours Very Truly MELLIS CORPORATION

lichael P.W. Ellis Michael P.W. Ellis mpure mo

enclosures: Limitorque Wiring Diagram





