

FILE FOLDER

DESCRIPTION ON TAB:

Wellhouse 2660

Outside/inside of actual folder did not contain hand written information

Outside/inside of actual folder did contain hand written information

***Scanned as next image**

WELLHOUSE 661 660

660
26 Jan

660

WELLHOUSE 660

660

SOURCE INFORMATION GROUND WATER

Date Form Completed

M M D D Y Y
0 1 2 4 9 5

PWSID
0467041

Owner Assigned Source Code

Well Name (If purchase, name of system)

Code

G=Ground
W=Purchase/G
Y=G w/direct influence
Z=W w/direct influence

Well Name: HADNOT POINT 660

Code: G

If Purchase, seller ID#

Source Begin Date

Source exempt— SWTR?

Direct Influence Date

Availability

P=Permanent
E=Emergency
S=Seasonal
I=Interim
O=Other

Source Begin Date: M M Y Y
SWTR? Y N

Availability: P

Location of well within the system (If purchase, location of master meter)

Location: HOLCOMB BLVD

T/R ABANDONED

Latitude (N)

Longitude (W)

How Determined

GPS Data

No. of Sats. Locked on

Latitude (N): Deg. Min. Sec.
3

Longitude (W): Deg. Min. Sec.
0

How Determined: G=GPS, M=Map, S=Surveyed

GPS Data: Q# or DOP #

No. of Sats. Locked on:

(If purchase, use seller's primary source lat/long)

Vulnerable (VOCs) Y N
Assessment Date: M M D D Y Y

ENTRY POINT INFORMATION

Use Code

Availability

C=Ground/Permanent
D=Ground/non-permanent

P=Year-round
E=Emergency
S=Seasonal
I=Interim
O=Other

Owner Assigned Entry Point Code

Entry Point Name

Entry Point Code: 100
Entry Point Name: HP 660

Location:

Well Site: Owned or controlled? (Y,N) Control Area (100' radius)? (Y,N) If no, explain:

Sources of pollution/distance:

Surface water within 200'? Y N If yes, actual distance feet If yes, bact. samples collected? (Y,N)

Adequate slope? (Y,N) Flooding? (Y,N) Maintenance:

Well House: Free of stored materials? (Y,N) Properly drained? (Y,N) Locked? (Y,N)

Condition of house: Type of freeze protection:

Well: Diameter: Type: Yield (gpm): 150 Properly sealed? (Y,N)

Properly vented? (Y,N) Casing depth ft. (If unknown, put 'UNK') Well depth: Meter available? Y (Y,N)

Concrete slab adequate? (Y,N) If no, explain: Size:

Size of blow-off: 4" (Y) Sample tap: Before treatment? (Y,N) After treatment? (Y,N)

Pumps: Capacity: GPM: 150 HP: 10 Pump intake depth: Auxiliary Power? Y (Y,N)

Type pump: VERTICAL TURBINE Height above floor (pump/casing): 8" /

Storage at well site: Elev: Hydro: Ground:

If hydroautomatic, air volume control? (Y,N) Safety valves? (Y,N) Coded? (Y,N)


High service pumps: 1. gpm hp 2. gpm hp 3. gpm hp Auxiliary Power? (Y,N)

Is the water treated at this well? Y N If yes, complete back of form.

If other wells are treated here, which ones? If treated elsewhere, where? HP-20 PLANT

If purchase, retreat? Y N If yes, complete back of form.

CONTAMINATED



file

CONTRACTOR'S SUBMITTAL TRANSMITTAL
SND LANTDIV 4-4355/3 (Rev. 6/76)

CONTRACT NO N62470-82-C-4551	TRANSMITTAL NO 15	DATE 9-08-83
PROJECT TITLE AND LOCATION Replacing Three (3) Water Wells, MCB Camp Lejeune, N. C. Well No. 601.		

FROM CONTRACTOR
East Coast Construction Co., Inc.

TO
ROICC

CONTRACTOR USE ONLY		REVIEWER USE ONLY
<p><i>*List only one specification division per form.</i></p> <p><i>List only one of the following categories on each transmittal form, and indicate which is being submitted</i></p> <p><input type="checkbox"/> Contractor Approved <input checked="" type="checkbox"/> OICC Approval <input type="checkbox"/> Deviation/Substitution For OICC Approval</p>		<p>**ACTION CODES</p> <p>A-Approved D-Disapproved AN-Approved as noted RA-Receipt acknowledged C-Comments R-Resubmit</p>

ITEM NO	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO.	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES	REVIEWER'S INITIALS CODE AND DATE
1	15201-6	Driller's Log	3	A	JAE 60
2	15201-6	Electric Log and Gamma Log	3		
3	15201-6	Water Analysis	3		9-8-83
4	15201-6	Sieve Analysis	3		
5	15201-6	Recommendation and Data Submittal	3	A	JAE 60

CONTRACTOR'S COMMENTS

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC

CONTRACTOR REPRESENTATIVE (Signature)
Ronald L. Eller

DATE RECEIVED BY REVIEWER	FROM (Reviewer)	TO


- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on **ONE COPY** of the transmittal form.

REVIEWER'S COMMENTS

Copy - Fred Contractor 9-8-83

COPIES TO: ROICC (2) LANTDIV (1) A-E (1)	DATE 9-8-83	SIGNATURE <i>JAE</i>
---	-----------------------	-------------------------

ROICC



ASSOCIATES, INC.

ROUTING ORDER INT

1	60	CR
2		
3		
4		
5		
6		
7		
8		
RETURN TO		02

August 15, 1983

Officer in Charge of Construction
Jacksonville North Carolina Area
Marine Corps Base
Camp LeJeune, North Carolina 28542

Subject: Replace Water Wells
Buildings 601, M-168, & BB-43
Construction Contract No. N62470-82-B-4551
Enwright Job No. 82005-00-2-01

Gentlemen:

We have reviewed the attached submittal and offer the following comments (Please refer to second paragraph of the three letters dated July 5, 1983 from East Coast Construction Company):

- The .30 inch slot for the stainless steel screens appears to be too large.
- All wells shall be packed with gravel having a uniformity coefficient of not more than 2.5. The contractor recommends course sand.
- Electric log for well number M-601 was not submitted.
- Well numbers M-168 and BB-43 do not meet specified yield.

We are requesting a resubmittal of the attached which should address the items mentioned above. Please advise as to acceptance or rejection of estimated yield for wells M-168 and BB-43.

Yours very truly,

ENWRIGHT ASSOCIATES, INC.

Thomas E. Sharpe, Jr.
Thomas E. Sharpe, Jr.
Project Manager


Sent 2 copies to East Coast

TES;jr/pdk

Attachment

cc: Mr. Fook-Kay Lee
File





EAST COAST CONSTRUCTION COMPANY, INC.

GENERAL CONTRACTORS

Post Office Box 5004

JACKSONVILLE, NORTH CAROLINA 28540

August 25, 1983

Officer in Charge of Construction
Building 1005
Camp Lejeune, N. C. 28542

Re: N62470-82-C-4551
Replace Three (3) Water Wells

Gentlemen:

As per our telephone discussion and attached letter from Enwright and Associates, we submit the following:


We are still recommending a .30 slot stainless steel screen and a course sand gravel pack. Sample attached. We base our recommendation on the attached sieve analysis from Johnson Company and our past experience in the development of water wells in this area.

We feel this method will offer the most efficient and productive well. As for the quantity of available water we base our recommendation on the attached gamma and electric logs and pumping test.


Should you have any questions please do not hesitate to contact us.

Yours very truly,

EAST COAST CONSTRUCTION CO., INC.


Ron Ellen

RRE/lm
Enclosures



July 05, 1983

Officer in Charge of Construction
Building 1005
Camp Lejeune, N. C. 28542

Re: N62470-82-C-4551
Replacing Three (3) Water Wells
Camp Lejeune, N. C.
Well No. 601-

Gentlemen:

We are enclosing six (6) copies of the Driller's Log, Electric Log, Gamma Log, Water Analysis and Sieve Analysis for your review. The test well was drilled 225 feet deep. Water samples were taken at the 92' to 97'; 132' to 137'; and 175' to 180' levels.

We recommend a line of .30-slot stainless steel screens set at the 94' to 99'; 108' to 140'; and 175' to 187' levels for a total of 49 VF of screens. The gravel pack recommended is a coarse sand. It is our best estimate that this well may yield 250 to 300 GPM.

Please review the data and advise if we are to proceed with developing a permanent well at this site.


Yours very truly,

EAST COAST CONSTRUCTION CO., INC.

W. H. Myers

WHM/lm
Enclosures

C
O
P
Y



COAST CONSTRUCTION COMPANY, INC.

GENERAL CONTRACTORS

Post Office Box 5004


JACKSONVILLE, NORTH CAROLINA 28540

CAMP LEJEUNE

601-

May 6, 1983

60	-	70	rock pieces and fine sand
70	-	80	fine sand with rock and shell
80	-	90	fine sand with rock and shell
90	-	100	fine to medium sand, shell and shale
100	-	110	fine to medium sand, shell, shale, some rock
110	-	120	fine to medium sand with rock pieces
120	-	130	fine to medium sand, shale fragments
130	-	140	fine to medium sand, shale and shells
140	-	150	fine sand, some shell
150	-	160	fine to medium sand
160	-	170	fine sand
170	-	180	fine sand
180	-	190	fine sand
190	-	200	very fine sand



SAND ANALYSIS (FINE)


MAILING ADDRESS: P.O. BOX 43118
ST. PAUL, MINNESOTA # 55164

Contract N62470-2-C-4551

Carolina Well & Pump

State _____ Zip _____ Date 6-27-83


Remarks: Well #601 Camp Sejeune, N.C.
For Gravel Pack Selection



SIEVE NO.	SEIVE OPENING INCHES	SEIVE OPENING MM	CUMULATIVE PERCENT RETAINED
6	.132	3.36	
8	.094	2.38	
12	.065	1.68	
15	.047	1.19	
20	.033	0.84	
30	.023	0.60	
40	.016	0.42	
50	.012	0.30	
70	.008	0.21	
100	.006	0.15	

Notes: _____
 Recommended Slot Opening: _____
 Recommended Screen: Dia. _____ in. Length _____ Ft.
 By: BPV

SO MANY CONSIDERATIONS ENTER INTO THE MAKING OF A GOOD WELL THAT WHILE WE BELIEVE SLOT SIZES FURNISHED OR RECOMMENDED FROM SAND SAMPLES ARE CORRECT WE ASSUME NO RESPONSIBILITY FOR THE SUCCESSFUL OPERATION OF JOHNSON WELL SCREENS.



SAND ANALYSIS

(FINE)


MAILING ADDRESS: P.O. BOX 43118
ST. PAUL MINNESOTA • 55164

55164
29-7451

State _____ Zip _____ Date _____

From well of _____

Remarks: well #601r



U.S. SIEVE NO.	SIEVE OPENING INCHES	SIEVE OPENING MM	CUMULATIVE PER CENT RETAINED
6	1.18	3.36	
8	.94	2.38	
12	.66	1.68	
16	.47	1.19	
20	.33	0.84	
30	.23	0.60	
40	.16	0.42	
50	.12	0.30	
70	.08	0.21	
100	.06	0.15	


Notes: _____

 Recommended Slot Opening: _____

 Recommended Screen: Dia. _____ in. Length _____ Ft.

 By: _____

SO MANY CONSIDERATIONS ENTER INTO THE MAKING OF A GOOD WELL THAT WHILE WE BELIEVE SLOT SIZES FURNISHED OR RECOMMENDED FROM SAND SAMPLES ARE CORRECT WE ASSUME NO RESPONSIBILITY FOR THE SUCCESSFUL OPERATION OF JOHNSON WELL SCREENS.



SAND ANALYSIS

(FINE)


MAILING ADDRESS: P.O. BOX 43118
ST. PAUL, MINNESOTA • 55164

55164
ex 29-7451

State _____ Zip _____ Date _____

From well of _____

Remarks: FOG



U.S. SIEVE NO.	SLOT OPENING INCHES	SLOT OPENING MM	CUMULATIVE PERCENT RETAINED
6	1.32	3.36	
8	0.94	2.38	
12	0.66	1.65	
16	0.47	1.19	
20	0.33	0.84	
30	0.25	0.60	
40	0.18	0.42	
50	0.12	0.30	
70	0.09	0.21	
100	0.06	0.15	


Notes: _____

Recommended Slot Opening: _____

Recommended Screen: Dia. _____ in. Length _____ Ft.

By: _____

SO MANY CONSIDERATIONS ENTER INTO THE MAKING OF A GOOD WELL THAT WHILE WE BELIEVE SLOT SIZES FURNISHED OR RECOMMENDED FROM SAND SAMPLES ARE CORRECT WE ASSUME NO RESPONSIBILITY FOR THE SUCCESSFUL OPERATION OF JOHNSON WELL SCREENS.



WATER ANALYSIS LABORATORY

802 HAMLET HIGHWAY
BENNETTSVILLE, SOUTH CAROLINA
29812

CONSULTANTS FOR:
INDUSTRY
MUNICIPALITIES
HOME OWNERS
DEVELOPERS
IRRIGATION
OTHERS

DATE: June 15, 1983

Contract N62470-82-C-4551

Report To: Carolina Well & Pump Co.
Sanford, N. C.

Date Analyzed: 6/15/83
Sample Number: Job 601-92'-97'

Analysis Results--Parts Per Million


<u>Determination</u>		<u>Determination</u>	
pH	<u>6.9</u>	Carbon Dioxide (CO ₂)	<u>5</u>
Iron (Fe)	<u>0.1</u>	Total Acidity (CaCO ₃)	<u>6</u>
Nitrate (NO ₃)	<u>Trace</u>	Calcium Hardness (CaCO ₃)	<u>208</u>
Fluoride (F)	<u>0.4</u>	Magnesium Hardness (CaCO ₃)	<u>34</u>
Manganese (Mn)	<u>Trace</u>	Carbonate Hardness (CaCO ₃)	<u>220</u>
Total Hardness (CaCO ₃)	<u>242</u>	Noncarbonate Hardness (CaCO ₃)	<u>22</u>
Chlorides (Cl)	<u>16</u>	Alkalinity (Phenolphthalein) (CaCO ₃)	<u>0</u>
Sulfate (SO ₄)	<u>32.6</u>	Carbonate Alkalinity (CaCO ₃)	<u>0</u>
Phosphate (PO ₄)	<u>0</u>	Bicarbonate Alkalinity (CaCO ₃)	<u>220</u>
Magnesium (Mg)	<u>8.4</u>	Total Alkalinity (CaCO ₃)	<u>220</u>
Calcium (Ca)	<u>83.2</u>	Total Dissolved Solids	<u>392</u>
Carbonate (CO ₃)	<u>0</u>	Specific Conductance (micromhos at 25°)	<u>560</u>
Bicarbonate (HCO ₃)	<u>268</u>	Appearance When Analyzed	<u>Clear</u>
Hydroxide (OH)	<u>0</u>	Odor When Analyzed	<u>Not Objectionable</u>

Water Analysis Laboratory

802 Hamlet Highway

SIGNED: _____
LABORATORY DIRECTOR

ANALYTICAL METHODS REFERENCES: 'STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTE WATER,' APHA, AWWA AND WPCF AND 'METHODS FOR COLLECTION AND ANALYSIS OF WATER SAMPLES,' WATER SUPPLY PAPER 1454 (1960), U. S. GEOLOGICAL SURVEY, WASHINGTON, D. C.



WATER ANALYSIS LABORATORY

802 HAMLET HIGHWAY
 BENNETTSVILLE, SOUTH CAROLINA
 29512

CONSULTANTS FOR:
 INDUSTRY
 MUNICIPALITIES
 HOME OWNERS
 DEVELOPERS
 IRRIGATION
 OTHERS

DATE: June 15, 1983

Report To: Carolina Well & Pump Co.
Sanford, North Carolina

Date Analyzed: 6/15/83
 Sample Number: Job 601-132'-137'

Analysis Results--Parts Per Million

<u>Determination</u>		<u>Determination</u>	
pH	<u>7.0</u>	Carbon Dioxide (CO ₂)	<u>2</u>
Iron (Fe)	<u>0.1</u>	Total Acidity (CaCO ₃)	<u>3</u>
Nitrate (NO ₃)	<u>Trace</u>	Calcium Hardness (CaCO ₃)	<u>152</u>
Fluoride (F)	<u>0.5</u>	Magnesium Hardness (CaCO ₃)	<u>23</u>
Manganese (Mn)	<u>Trace</u>	Carbonate Hardness (CaCO ₃)	<u>175</u>
Total Hardness (CaCO ₃)	<u>175</u>	Noncarbonate Hardness (CaCO ₃)	<u>0</u>
Chlorides (Cl)	<u>14</u>	Alkalinity (Phenolphthalein) (CaCO ₃)	<u>0</u>
Sulfate (SO ₄)	<u>6.2</u>	Carbonate Alkalinity (CaCO ₃)	<u>0</u>
Phosphate (PO ₄)	<u>0</u>	Bicarbonate Alkalinity (CaCO ₃)	<u>180</u>
Magnesium (Mg)	<u>5.6</u>	Total Alkalinity (CaCO ₃)	<u>180</u>
Calcium (Ca)	<u>60.8</u>	Total Dissolved Solids	<u>266</u>
Carbonate (CO ₃)	<u>0</u>	Specific Conductance (micromhos at 25°C)	<u>380</u>
Bicarbonate (HCO ₃)	<u>220</u>	Appearance When Analyzed	<u>Clear</u>
Hydroxide (OH)	<u>0</u>	Odor When Analyzed	<u>Not Objectionable</u>

Water Analysis Laboratory


802 Hamlet Highway

Bennettsville, South Carolina 29512

SIGNED _____

LABORATORY DIRECTOR

ANALYTICAL METHODS REFERENCES: 'STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTE-WATER,' APHA, AWWA AND WPCF AND 'METHODS FOR COLLECTION AND ANALYSIS OF WATER SAMPLES,' WATER SUPPLY PAPER 1454 (1960), U. S. GEOLOGICAL SURVEY, WASHINGTON, D. C.



WATER ANALYSIS LABORATORY

802 HAMLET HIGHWAY
 BENNETTSVILLE, SOUTH CAROLINA
 29312

CONSULTANTS FOR:
 INDUSTRY
 MUNICIPALITIES
 HOME OWNERS
 DEVELOPERS
 IRRIGATION
 OTHERS

DATE: June 15, 1983

Report To: Carolina Well & Pump Co.
Sanford, North Carolina

Date Analyzed: 6/15/83
 Sample Number: Job 601-175'-180'

Analysis Results--Parts Per Million

<u>Determination</u>		<u>Determination</u>	
pH	<u>7.2</u>	Carbon Dioxide (CO ₂)	<u>2</u>
Iron (Fe)	<u>.05</u>	Total Acidity (CaCO ₃)	<u>2</u>
Nitrate (NO ₃)	<u>Trace</u>	Calcium Hardness (CaCO ₃)	<u>146</u>
Fluoride (F)	<u>0.4</u>	Magnesium Hardness (CaCO ₃)	<u>16</u>
Manganese (Mn)	<u>Trace</u>	Carbonate Hardness (CaCO ₃)	<u>160</u>
Total Hardness (CaCO ₃)	<u>162</u>	Noncarbonate Hardness (CaCO ₃)	<u>2</u>
Chlorides (Cl)	<u>18</u>	Alkalinity (Phenolphthalein) (CaCO ₃)	<u>0</u>
Sulfate (SO ₄)	<u>7.1</u>	Carbonate Alkalinity (CaCO ₃)	<u>0</u>
Phosphate (PO ₄)	<u>0</u>	Bicarbonate Alkalinity (CaCO ₃)	<u>160</u>
Magnesium (Mg)	<u>3.8</u>	Total Alkalinity (CaCO ₃)	<u>160</u>
Calcium (Ca)	<u>58.4</u>	Total Dissolved Solids	<u>238</u>
Carbonate (CO ₃)	<u>0</u>	Specific Conductance (micromhos at 25°C)	<u>340</u>
Bicarbonate (HCO ₃)	<u>178</u>	Appearance When Analyzed	<u>Clear</u>
Hydroxide (OH)	<u>0</u>	Odor When Analyzed	<u>Not Objectionable</u>


Water Analysis Laboratory

802 Hamlet Highway

SIGNED:

Benjamin C. ...
 BENNETTSVILLE, SOUTH CAROLINA 29312
 LABORATORY DIRECTOR

ANALYTICAL METHODS REFERENCES: 'STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTE-WATER,' APHA, AWWA AND WPCF AND 'METHODS FOR COLLECTION AND ANALYSIS OF WATER SAMPLES,' WATER SUPPLY PAPER 1454 (1960), U. S. GEOLOGICAL SURVEY, WASHINGTON, D. C.



CONTRACTOR'S SUBMITTAL TRANSMITTAL
AND LANTDIV 4-4355/3 (Rev. 8/78)

CONTRACT NO. 82-C-4551	TRANSMITTAL NO.	DATE 12-6-83
PROJECT TITLE AND LOCATION Replacing three (3) Water Well Camp Lejeune NC Well N° BB-43 / Well N° 601		

FROM CONTRACTOR
EAST COAST CONSTRUCTION CO INC
 TO
ROICC

<p align="center">CONTRACTOR USE ONLY</p> <p align="center"><i>*List only one specification division per form.</i></p> <p align="center"><i>List only one of the following categories on each transmittal form, and indicate which is being submitted</i></p> <p> <input type="checkbox"/> Contractor Approved <input type="checkbox"/> OICC Approval <input type="checkbox"/> Deviation/Substitution For OICC Approval </p>	<p align="center">REVIEWER USE ONLY</p> <p align="center">**ACTION CODES</p> <p> A-Approved D-Disapproved AN-Approved as noted RA-Receipt acknowledged. C-Comments R-Resubmit </p>
---	---

ITEM NO.	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO. *	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES	REVIEWER'S INITIALS CODE AND DATE
	15201-7.3	24 hour Pumping Test	6	A	FKL.

RECEIVED

CONTRACTOR'S COMMENTS
**Well N° BB-43
 Pump Test DATA
 Should be Well N° 601**

DEC 19 1983

ENWRIGHT ASSOCIATES

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC _____

CONTRACTOR REPRESENTATIVE (Signature)
Ron Ellen


DATE RECEIVED BY REVIEWER _____ FROM (Reviewer) _____ TO _____

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on ONE COPY of the transmittal form.

REVIEWER'S COMMENTS

RECEIVED
 DEC 31 PM '83

COPIES TO: ROICC (2) LANTDIV (1) A-E (1)	DATE	SIGNATURE
---	------	-----------



PUMPING TEST DATA

Carolina Well & Pump Co.

Roger Thomas

Camp Lejeune

Address:

BB 43

Location: across blvd. from Steak House

County: Onslow

Observation Well Locations:

Should be 601

Airline Lengths: Pumped Well

Observation Wells


Remarks:

Pumping rate measured with: 3 x 4 orifice

Water levels measured with: electric tape

Pump Well Data

Date and Time	Elapsed Time Min.	Piezometer Tube Reading Inches	Pumping Rate GPM	Pump Discharge Pressure	Altitude Gauge Reading Feet	Feet to Water	Remarks
11/21/83						15' 5"	
12:50 PM						15' 5"	
1:00		13	151			62' 4"	
1:05	5 min.	"	"			63' 0"	
1:10	10	"	"			68' 5"	
1:15	15	"	"			72' 8"	
1:20	20	"	"			75' 0"	
1:25	25	"	"			76' 0"	
1:30	30	"	"			77' 8"	
1:35	35	"	"			77' 8"	
1:40	40	"	"			78' 3"	
1:45	45	"	"			79' 3"	
1:50	50	"	"			79' 3"	
1:55	55	"	"			79' 5"	
2:00	60	"	"			80' 0"	
2:05	65	"	"			80' 0"	
2:10	70	"	"			80' 0"	
2:15	75	"	"			80' 3"	
2:20	80	"	"			80' 9"	
2:25	85	"	"			80' 9"	
2:30	90	"	"			80' 9"	
2:35	95	"	"			80' 9"	
2:40	100	"	"			80' 9"	
2:45	105	"	"			80' 9"	
2:50	110	"	"			80' 9"	
2:55	115	"	"			80' 9"	
3:00	120	"	"			80' 9"	
3:10	130(10 min.)	"	"			80' 9"	
3:20	140	"	"			80' 9"	
3:30	150	"	"			80' 9"	
3:40	160	"	"			80' 9"	
3:50	170	"	"			80' 9"	
4:00	180	"	"			81' 0"	
4:15	195(15 min.)	"	"			81' 0"	
4:30	210	"	"			81' 0"	
5:00	240(30 min.)	"	"			81' 0"	
6:00	300(60 min.)	"	"			81' 0"	
7:00	360	"	"			81' 0"	
8:00	420	"	"			81' 0"	
9:00	480	"	"			81' 0"	
10:00	540	"	"			81' 0"	
11:00	600	"	"			81' 0"	
12:00	660	"	"			81' 0"	
1:00	720	"	"			81' 0"	
2:00	780	"	"			81' 0"	



EAST COAST CONSTRUCTION COMPANY, INC.

GENERAL CONTRACTORS

Post Office Box 5004

JACKSONVILLE, NORTH CAROLINA 28540

*60/ged
/02*

January 11, 1984

Officer in Charge of Construction
Building 1005
Camp Lejeune, N. C. 28540


Re: N62470-82-C-4551
Replacing Three (3) Water Wells
MCB, Camp Lejeune, N. C.
Well No. 601

Gentlemen:

Please note that the attached 24-hour Pumping Test should be for Well No. 601. It is incorrectly marked as BB-43.

Yours very truly,


EAST COAST CONSTRUCTION CO., INC.



Ron Ellen

RRE/lm

Attachment



FILE FOLDER

DESCRIPTION ON TAB:

New Well Replacement 666

Outside/inside of actual folder did not contain hand written information

Outside/inside of actual folder did contain hand written information

***Scanned as next image**

10

10

11


11

12

12

13

13



DATE 7-25-00
PWSID 04-67-041

WELL # HP 661
WELL NAME HADNOT POINT HP-20
BLDG. HP 661
CODE G
AVAILABILITY P
LOCATION SNEADS FERRY ROAD
LATITUDE 34.64391
LONGITUDE 77.30544
WELL DIAMETER 8"
WELL DEPTH ~~25~~ 140'
SCREEN INTERVAL _____
YIELD 151
STATIC LEVEL 23'
PUMPING LEVEL 44'
PUMP TYPE VERTICAL TURBINE
MOTOR HP _____
INTAKE DEPTH 70
DESIGN CAPACITY 175
ACTUAL GPM 175
SIZE OF CONCRETE SLAB _____
HEIGHT OF CASING 12"

10/11

SOURCE INFORMATION GROUND WATER

Date Form Completed

M M D D Y Y
0 1 2 5 9 5

PWSID
0467041

Owner Assigned
source Code

Well Name (If purchase, name of system)

661 HADNOT POINT 661

Code

G=Ground
W=Purchase/G
Y=G w/direct influence
Z=W w/direct influence

G

If Purchase, seller ID#

Source Begin Date

Source exempt—
SWTR?

Direct Influence Date

Availability

Source Begin Date: M M Y Y
Source exempt: Y N
Direct Influence Date: M M D D Y Y

P=Permanent
E=Emergency
S=Seasonal
I=Interim
O=Other

P

Location of well within the system (If purchase, location of master meter)

SNEADS FERRY ROAD

Latitude (N)

Longitude (W)

How Determined

GPS Data

No. of Sats. Locked on

34 38 41.1

07 7 18 20 9

G
G=GPS
M=Map
S=Surveyed

93
Q# or
DOP #

4

(If purchase, use seller's primary source lat/long)

Vulnerable (VOCs) Y N

Assessment Date

M M D D Y Y

ENTRY POINT INFORMATION

Use Code

Availability

Owner Assigned
Entry Point Code

Entry Point Name

C=Ground/Permanent
D=Ground/non-permanent

P=Year-round
E=Emergency
S=Seasonal
I=Interim
O=Other

100

HADNOT POINT WTP

Location:

Well Site: Owned or controlled? (Y,N) Control Area (100' radius)? (Y,N) If no, explain:

Sources of pollution/distance: Road @ 100'

Surface water within 200'? (Y,N) If yes, actual distance feet If yes, bact. samples collected? (Y,N)

Adequate slope? (Y,N) Flooding? (Y,N) Maintenance: OK

Well House: Free of stored materials? (Y,N) Properly drained? (Y,N) Locked? (Y,N)

Condition of house: OK Type of freeze protection: Electric heat

Well: Diameter: 8" Type: SCREENED Yield (gpm): 175 Properly sealed? (Y,N)

Properly vented? (Y,N) Casing depth 50 ft. (If unknown, put 'UNK') Well depth: 135' Meter available? (Y,N)

Concrete slab adequate? (Y,N) If no, explain: Size: 12x12

Size of blow-off: 4" (V) Sample tap: Before treatment? (Y,N) After treatment? (Y,N)

Pumps: Capacity: GPM: 175 122 HP: 15 Pump intake depth: 20 Auxiliary Power? (Y,N)

Type pump: VERTICAL TURBINE Height above floor (pump/casing): 12"

Storage at well site: Elev: Hydro: Ground:

If hydroautomatic, air volume control? (Y,N) Safety valves? (Y,N) Coded? (Y,N)


High service pumps: 1. gpm hp 2. gpm hp 3. gpm hp Auxiliary Power? (Y,N)


Is the water treated at this well? (Y,N) If yes, complete back of form.


If other wells are treated here, which ones? If treated elsewhere, where? HP-20 PLANT


If purchase, retreat? (Y,N) If yes, complete back of form.

- 1 Seal pump pedestal
- 2 well not in center of slab











NUMBER 661		BY THOMAS SARDINAS			DATE 2-9-89	
LINE	STATIC LEVEL	PUMPING LEVEL	DRAIN DOWN	DISCHARGE PRESSURE	GPM	START TIME
70	23	33	10	70	108	35
		37	14	65	140	45
		43	20	60	142	55
		45	22	55	180	05
		48	25	50	221	10
		50	27	45	239	15
		55	32	40	259	25
	left net →	60	37	35	275	33

Palled pump cleaned, blew & pisted well
 cleaned pump & installed one new parts used
 Pump dead @ 84 PSI
 left net @ 35 PSI 275 GPM

FACTURER	STAGE	S.N.	TOTAL HEAD	SIZE





NEW

WELL NUMBER		BY THOMAS / BROWN			DATE 10-26-84	
AIR LINE	STATIC LEVEL	PUMPING LEVEL	DRAIN DOWN	DISCHARGE PRESSURE	GPM	START TIME
90	29	38	9	81	104	0810
		42	13	76	122	0820
		44	15	72	130	0830
		46	17	68	149	0840
		50	21	64	167	0850
		52	23	60	185	0900
		57	28	54	212	0910
		60	31	49	232	0920
GPM RIG		65	36	40	259	0930
WATER METER		69	40	35	266	0940
		75	44	30	275	0950
REMARKS - left set at →		78	47	27	280	1000


27 PSI
280 GPM by meter

used GPM rig to 40" - 266 GPM - went to in line water meter

MANUFACTURER	STAGE	S.N.	TOTAL HEAD	SIZE
--------------	-------	------	------------	------

661 10-26-84 12-4-85

WELL DEPTH
PUMP SET
AIR LINE 90 AL 90
STATIC LEVEL 29 SL 32
PUMPING LEVEL 78 PL 63
DRAW DOWN 47 D-D 31
PSI 27 PSI 18
GPM 280 GPM 234
By meter



NEW

WELL NUMBER		BY			DATE	
627		THOMAS / BROWN			10-26-84	
AIR LINE	STATIC LEVEL	PUMPING LEVEL	DRAIN DOWN	DISCHARGE PRESSURE	GPM	START TIME
90	29	38	9	81	104	0810
		42	13	76	122	0820
		44	15	72	130	0830
		46	17	68	149	0840
		50	21	64	167	0850
		52	23	60	185	0900
		57	28	54	212	0910
		60	31	49	232	0920
GPM RIG		65	36	40	259	0930
WATER METER		69	40	35	266	0940
		75	44	30	275	0950
REMARKS - left set at ->		78	47	27	280	1000

27 PSI
280 GPM by meter

used GPM rig to 40" - 266 GPM - went to in line water meter

MANUFACTURER	STAGE	S.N.	TOTAL HEAD	SIZE



8 WATER WELLS - MINING CORP BASE - Camp Lejeune

ID	LOCATION	Pump Data		Pump Dia		6" Dia	4" Dia	1st Screen Setting	2nd Screen Setting	3rd Screen Setting	4th Screen Setting	5th Screen Setting	Ft. to Water		Pump Rate GPM
		Model	Stamps	Motor HP	Motor Dia								Static	Dynamic	
11	Barkley Manor	8MS	8	20	20	70	45	65-75	115-135	182-197	-	-	35	49	300
4	Stone Street	8MS	8	20	20	80	44	106-120	150-170	217-227	-	-	15	80	300
11	4006 MIDWAY PARK	8HL	8	30	40	80	42	90-119	116-139	-	-	-	25	70	450
21	Piney Green Rd	8MS	6	15	20	70	40	60-70	125-135	160-170	220-230	-	18"	54-9"	200
27	Speeds Ferry Rd	8MS	6	15	20	70	40	50-65	87-102	125-135	-	-	14	44	175
R 227	Rifle Range	8HL	8	25	40	80	35	190-210	223-233	242-247	-	-	23	58	300
638	TARAWA TERRACE	8MS	6	15	20	85	35	70-95	132-142	-	-	-	27	63	160
39	Speeds Ferry Rd	8MS	6	15	20	70	42	121-131	134-146	185-195	215-220	225-250	4	96	200

stone
tree
well — 10-10-84



CONSOLIDATED PUMP & EQUIPMENT, INC.

DISTRIBUTORS AND MANUFACTURER REPRESENTATIVES • WATER & WASTE WATER TREATMENT
POST OFFICE BOX 3188 • ROCK HILL, SOUTH CAROLINA 29730 • 803/328-1891

March 28, 1983

SUBMITTAL DATA

JOB:

Replace Water Wells
Camp Lejeune, N. C.

Engineer:

Peirson & Whitman, -Inc.


Contractor:

East Coast Construction Co.

Material Submitted:


- 8 - Jacuzzi Model 15-SMSA6 Verticle Turbine Pump consisting of 6 stage 8MS pump head, 10' - 6" suction pipe with cone strainer, 100' - 6" discharge column, 1" drive shaft, model L6A discharge head, model S-20 Combination Right Angle Gear Drive, 1 : 1 Ratio, and 15 HP V. H. S. motor.

Conditions of service 200 GPM @ 190.5' TDH



TURBINE PUMP CURVE

8MS
SECTION
2120
MAY 15, 1970



NUMBER OF BOWLS	CHANGE EFFICIENCY AS FOLLOWS
1	-4
2	-3
3	-2
4	-1

Change in efficiency may affect both head and horsepower

Bowl Dia.	7-1/2 In.
Bowl No.	3591-S, C.I., ENAM.
Impeller No.	3590, BRONZE
Eye Area	6.6 Sq. In.
Imp. Type	SEMI-OPEN K = 4.28

STAGE PERFORMANCE	
Curve No.	8M-172
R. P. M.	1760
Bowl	8MS

Performance based on pumping clear, fresh water at a temperature not over 85°F., and free of gas, air or abrasives, and with bowls properly adjusted and submerged.

BRAKE HORSEPOWER

3


2

1

0



Turbine Bowl




ALL DIMENSIONS IN INCHES.


Nom. Bowl Size	Bowl Figure Number	Bowl Dia. Max. O.D. STD. A	Bowl Dia. Turned ALT. A	B	C	E	F	Max. G	Suction Bell		W	O.L.			W.L.	Available Outer Column and Suction Pipe
									J	K		X	Y	Z		
6	6J, 6L	5 5/8		3/8	4 3/8	3 3/8	3 3/8	5	4	7 1/4	3	9 1/2	22	7 1/2		3, 4, 5
	1			4 3/8		4, 5, 6										
8	8J, 8L, 8K, 8M, 8H	7 7/8	7 1/2	1	6	5 5/8	4	5	4 1/2	9 1/4	3	9 1/2	22	7 1/2		4, 5, 6
	8Y	7 1/8		1 1/8		7 1/2										4, 5, 6
10	10L, 10M, 10H	9 1/2	9 1/4	1 1/2	8	7	6	4 1/8	5 1/4	11 1/4	3	9 1/2	22	7 1/2		4, 5, 6, 8
10	10W, 10Y, 10Z	9 3/8	9 1/2	1 1/8	8 1/2	8 1/2	6 1/2	5 1/8	7	14 1/4	3	9 1/2	22	7 1/2		6, 8, 10
12	12L, 12M, 12H, 12X	11 1/8	11 1/4	1 1/8	9	10 1/2	5 1/2	3 3/8	6	13 1/4	3	9 1/2	22	7 1/2		6, 8, 10
12	12W	12 3/8	12	1 1/8	9	11 1/4	5 1/2	3 3/8	6	13 1/4	3	9 1/2	22	7 1/2		6, 8, 10
14	14L, 14M 14H, 14X	13 3/8	13 1/4	1 5/8	9 3/8	12 1/2	7 3/8	5 1/8	8	15 1/4	3	9 1/2	22	7 1/2		8, 10, 12
14	14W	14 1/8	13 3/4	1 5/8	9 3/8	13 1/4	7 3/8	5 1/8	8	15 1/4	3	9 1/2	22	7 1/2		8, 10, 12
16	ALL	15 1/2	15 1/4	1 5/8	9 3/8	15	8	6 3/8	10	22	3	9 1/2	22	7 1/2		10, 12, 14
20	ALL	19 1/4	19 1/4	1 5/8	14	18	12	6 3/8	12 1/2	27	3	9 1/2	22	7 1/2		12, 14, 16
24	ALL	23 1/4	23 1/4	2 1/8	20	21	14	3 3/8	14	32	1	16 1/2	29	14 1/2		12, 14, 16, 18
28	ALL	27	27	2 1/8	24	24	15	3 3/8	16	38	1	16 1/2	29	14 1/2		14, 16, 18, 20, 22

* Note: Maximum Diameter for 24" Bowl is Discharge Column Flange at 25" and for 28" is 27 1/2".

D	Lineshaft Dia. & Pitch (L.H.)	3/8	1	1 1/8	1 1/2	1 5/8	1 3/4	2 1/8	2 1/4	2 3/8	2 1/2
		16P.	12P.	12P.	12P.	12P.	12P.	12P.	12P.	8P.	8P.
H	O.L. Inner Col. & Thread (R.H.)	1 1/8	1 1/2	2	2 1/2	3	3 1/2	3 3/4	4	5	5 1/2
		1 1/8-12P.	1 1/8-12P.	2 1/8-12P.	2 1/2-12P.	3 1/8-12P.	3 3/8-12P.	3 3/4-12P.	4-8P.	5-8P.	5-8P.




Turbine Bowl




Nom. Bowl Size	Bowl Figure Number	(M) = BOWL ASSEMBLY LENGTH W/SUCTION BELL - INCHES													
		NUMBER OF BOWLS													
		1	2	3	4	5	6	7	8	9	10	11	12	13	14
6	6L	18½	22	25½	29	32½	36	39½	43	46½	50	53½	57	60½	64
	6M,H,X,W,Y	19½	24½	29½	34	38½	43½	48½	53	57½	62½	67½	72	76½	81½
	8J,8L,8K,8M,8H	23½	28½	34½	40	45½	51½	56½	62½	68½	73½	79½	85	90½	96½
8	8Y	25	32½	40	47½	55	62½	70	77½	85	92½	100	107½	115	122½
10	10L,M,H	29½	36½	43½	50½	57½	64½	71½	78½	85½	92½	99½	106½	113½	120½
10	10W,Y,Z	34½	42½	51½	59½	68½	76½	85½	93½	102½	110½	119½	127½	136½	144½
12	12L, M, H, X	33½	44½	54½	65½	75½	86½	96½	107½	117½	128½	138½	149½	159½	170½
12	12W	34½	45½	57	68½	79½	90½	102	113½	124½	135½	147	158½	169½	180½
14	14L,M,H,X	40½	53½	65½	78½	90½	103½	115½	128½	140½	153½	165½	178½	190½	203½
14	14W	41½	54½	68	81½	94½	107½	121	134½	157½	160½	174	187½	200½	213½
16	ALL	46	61	76	91	106	121	136	151	166	181	196	211	226	241
20	ALL	59½	77½	95½	113½	131½	149½	167½	185½	203½	221½	239½			
24	ALL	70	91	112	133	154	175	196	217	238	259				
28	ALL	80	104	128	152	176	200	224	248	272					


Nom. Bowl Size	Bowl Figure Number	(N) = BOWL ASSEMBLY LENGTH W/SUCTION FLANGE - INCHES													
		NUMBER OF BOWLS													
		1	2	3	4	5	6	7	8	9	10	11	12	13	14
6	6L	19½	23	26½	30	33½	37	40½	44	47½	51	54½	58	61½	65
	6M,H,X,W	20½	25½	30½	35	39½	44½	49½	54	58½	63½	68½	73	77½	82½
8	8J,8L,8K,8M,8H	23½	29½	34½	40½	46½	51½	57½	63	68½	74½	79½	85½	91½	96½
8	8Y	25½	33	40½	48	55½	63	70½	78	85½	93	100½	108	115½	123
10	10L,M,H	28½	35½	42½	49½	56½	63½	70½	77½	84½	91½	98½	105½	112½	119½
10	10W,Y,Z	33½	41½	50½	58½	67½	75½	84½	92½	101½	109½	118½	126½	135½	143½
12	12L, M, H, X	31½	42	52½	63	73½	84	94½	105	115½	126	136½	147	157½	168
12	12W	32½	44½	55½	67	78½	89½	100½	112	123½	134½	145½	157	168½	179½
14	14L,M,H,X	38½	51½	63½	76½	88½	101½	113½	126½	138½	151½	163½	176½	188½	201½
14	14W	39½	52½	65½	79½	92½	105½	118½	132½	145½	158½	171½	185½	198½	211½
16	ALL	42½	57½	72½	87½	102½	117½	132½	147½	162½	177½	192½	207½	222½	237½
20	ALL	53½	71½	89½	107½	125½	143½	161½	179½	197½	215½	233½			
24	ALL	59½	80½	101½	122½	143½	164½	185½	206½	227½	248½				
28	ALL	67½	91½	115½	139½	163½	187½	211½	235½	259½					




Turbine Column – Water-Lube, Butt Joint




Nominal Column Size In.	A	B	L	M
3	4'11 1/2"	6 1/2"	9'11 1/2"	1/2"
4				
5	4'11 1/2"	5 1/4"	9'11 1/2"	3/4"
8				
10				
12				
14				
16				



Cast, Standard Discharge Heads




Head Fig. No.	Max. Size (In.) Disch.	Inner Col. (In.)	Outer Col. (In.)	DIMENSIONS INCHES																	
				A	B	C	D	E	F	G	H	J	K	L	M	N	P	R	S	T	Z
L5A L5AB	6	1½	5	10	9¾	8¾	¾	3¾	8¾	15¾	4¾	6¾	14¾	14¾	8¾	15¾	13¾	1	1¾	¾	2¾
L6A L6AB	6	1½	6	10	9¾	8¾	¾	3¾	8¾	15¾	4¾	6¾	14¾	14¾	8¾	15¾	13¾	1	1¾	¾	2¾
L8C L8CD	8	2	8	16¾	14¾	13¾	¾	3¾	7¾	15¾	4¾	6¾	16¾	17¾	9¾	18¾	15¾	1¾	1¾	1¾	3¾
L10C	10	2½	10	16¾	14¾	13¾	¾	4¾	9¾	18¾	5¾	6¾	16¾	18¾	10¾	19¾	16¾	1¾	1¾	1¾	3¾



Water Lubricated Turbine Pump

MATERIAL SPECIFICATIONS OF STANDARD CONSTRUCTION


KEY NO.	DESCRIPTION	MATERIAL	SPECIFICATION IF APPLICABLE	PART ORDER NUMBER
1	Discharge Head	Cast Iron	ASTM A48 CL.30	
2	Head Column Flange	Cast Iron	ASTM A48 CL.30	
3	Head Column Flange Gasket	Asbestos		
4	Studs (Hd. Column Flange Assy)	Steel	C1137	
5	Nuts (Used W/Key No. 4 Head Column Flange Assy)	Low Carbon Steel	ASTM A-307	
6	Head Discharge Flange	Cast Iron	ASTM A-128	
7	Head Discharge Flange Gasket	Asbestos		
8	Discharge Flg. Assy. Cap Scr.	Steel	ASTM A-301	
9	Discharge Flg. Assy. Nuts (Used with Key No. 8)	Low Carbon Steel	ASTM A-307	
10	Head Dsch. Flg. Assy. Studs	Steel	C1137	
11	Head Dsch. Flg. Assy. Nuts (Used With Key No. 10)	Low Carbon Steel	ASTM A-307	
14	Head Packing Housing W/Brg. Includes Key No. 32	Cast Iron (Pkg. Hsg.)	ASTM A48 CL.30	
15	"O" Ring	Buna-N		
16	Head Packing Housing Cap Scr.	S. Steel	300 Series	
18	W/L Headshaft	S. Steel	AISI 316	
19	Headshaft Flinger	Neoprene		
20	Headshaft Adj. Nut	Steel	C-1213	
21	Hd. Pkg. Hsg. Sand Shield	Bronze	SAE 660	
22	Packing (Set)	Asbestos		
23	Packing Follower	Bronze	SAE 40	
25	Hd. Pkg. Housing Grease Fittings	Steel		
26	Packing Follower Studs	S. Steel	AISI 416	
27	Packing Follower Retn. Nuts	S. Steel	300 Series	
28	Adapter Flange	Cast Iron	ASTM A48 CL45	
29	Adapter Flange O-Ring	Buna-N		
30	Adapter Flg. Assy. Cap Screws	S. Steel	300 Series	
32	W/L Headshaft Bearing	Bronze	SAE 660	
33	Headshaft Gib Key	Steel		
34	Adj. Nut Machine Screw	S. Plated		
67	Shaft Coupling (Hd. Shaft, Line Shaft, Bowl Shaf.)	Steel	C1137	
68	Shaft Adapter Coupling Hd/Sht, L/Sht, Bowl/Sht	Steel	C1137	
69	O/C Coupling	Blk. Steel	ASTM A-120-57T Grade B	
76	W/L O/C Section	Black Steel	ASTM A-120-57T Grade B	
77	W/L O/C Section	Black Steel	ASTM A-120-57T Grade B	
78	W/L L/S Bearing Spider	Brass		
79	W/L L/S Bearing	Rubber		




Water Lubricated Turbine Pump

MATERIAL SPECIFICATIONS OF STANDARD CONSTRUCTION


KEY NO.	DESCRIPTION	MATERIAL	SPECIFICATION IF APPLICABLE	PART ORDER NUMBER
80	W/L S/S Sleeve	S. Steel	304	
81	W/L L/S Extension 3' - 9 7/8" Lg.	Steel	C-1045	
82	W/S L/S Section (5' - 0" Lg.)	Steel	C-1045	
83	W/L L/S Section 10' - 0" Lg.	Steel	C-1045	
84	W/L Bowl Shaft	S. Steel	AISI 416	
90	W/L Discharge Housing Assy (Includes Key No. 91 & No. 92)	Cast Iron	ASTM A48 CL30	
91	W/L Upper Disch. Hsg. Brg.	Neoprene		
92	W/L Lower Disch. Hsg. Brg.	Neoprene		
93	W/L Disch. Hsg. Brg. Sand Cap	Bronze	SAE 40	
94	Sand Cap Set Screws (For K. No. 93)	S. Steel	300 Series	
103	Bowl Assy. (Closed Type) Includes Key No. 104	Cast Iron	ASTM A48 CL 30	
104	Bowl Bearing	Bronze	SAE 794	
105	Bowl Assy. (Semi-Open Type) Includes Key No. 104	Cast Iron	ASTM A48 CL30	
106	Impeller (Closed Type)	Bronze	SAE 40	
107	Impeller (Semi-Open Type)	Bronze	SAE 40	
108	Taper Lock	S. Steel	416 SS	
109	Brg. Stage Assy. (Closed Type) Includes Key No. 110	Cast Iron	ASTM A48 CL30	
110	Bearing Stg. Bearing	Bronze	SAE 660	
111	Brg. Stg. Assy. (Semi-Open) Includes Key No. 110	Cast Iron	ASTM A48 CL30	
112	Pipe Plug (For Key No. 109 & No. 111)	Galv. Steel		
113	Bearing Stage End Plug	Galv. Steel		
114	Bearing Stage Sand Cap	Bronze	SAE 40	
115	Sand Cap Set Screws (For K. No. 114)	S. Steel	300 Series	
116	Bowl Suction Flange	Cast Iron	ASTM A48 CL30	
117	Bowl Assy. Cap Screws	S. Steel	300 Series	
119	Suction Bell (Optional; Delete Key No. 116 if Suct. Bell is Used)	Cast Iron	ASTM A48 CL30	
152	W/L O/C Assy. T & C (Nom. 5' Lg.) (Assy of Key No. 69 & No. 76)	Black Steel	ASTM A-120-57T Grade B	
153	W/L O/C Assy T & C (Nom. 10' Lg.) (Assy of Key No. 69 & No. 77)	Black Steel	ASTM A-120-57T Grade B	





WATER LUBRICATED TURBINE PUMP PARTS DIAGRAM




TYPICAL STANDARD HEAD



TYPICAL HEAVY DUTY HEAD



BOWL ASSEMBLY



BOWL COLUMN FLANGE




TABLE 3

NOTE: Drives that are rated at 1760 RPM vertical speed ARE NOT LIMITED to 1760 RPM. See Table 1.

MODEL	Vertical Shaft RPM	H.P. Rating	DOWNTHRUST CAPACITY IN POUNDS													
			HOLLOW SHAFT						SOLID SHAFT						COMB.	
			Type SL		Type S		Type SH		Type SSL		Type SS		Type SSH		Type C	
			Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.
20	1160	15	0	978	797	2358	797	3680	0	978	0	2358			0	2358
	1460	18	0	901	760	2173	760	3392	0	901	0	2173			0	2173
	1760	20	0	850	700	2050	700	3200	0	850	0	2050			0	2050
	3460	30	0	680	534	1640	534	2560	0	680	0	1640			0	1640
40	1160	30	0	1495	1138	3565	1138	5520	0	1495	0	3565			0	3565
	1460	35	0	1378	1055	3286	1055	5088	0	1378	0	3286			0	3286
	1760	40	0	1300	1000	3100	1000	4800	0	1300	0	3100			0	3100
60	960	39	0	2074	1490	5002	1490	7320	0	2074	0	5002			0	5002
	1160	45	0	1955	1422	4715	1422	6900	0	1955	0	4715			0	4715
	1460	53	0	1802	1331	4346	1331	6360	0	1802	0	4346			0	4346
	1760	60	0	1700	1250	4100	1250	6000	0	1700	0	4100			0	4100
80	960	52	0	3904	2085	6954	2085	11224	0	3904	0	6954			0	6954
	1160	60	0	3680	1991	6555	1991	10580	0	3680	0	6555			0	6555
	1460	70	0	3392	1846	6042	1846	9752	0	3392	0	6042			0	6042
	1760	80	0	3200	1750	5700	1750	9200	0	3200	0	5700			0	5700
100	960	66	0	3904	2101	7198	2101	11224	0	3904	0	7198			0	7198
	1160	75	0	3680	1991	6785	1991	10580	0	3680	0	6785			0	6785
	1460	88	0	3392	1856	6254	1856	9752	0	3392	0	6254			0	6254
	1760	100	0	3200	1750	5900	1750	9200	0	3200	0	5900			0	5900
125	720	68	0	5535	3135	7965	3135	12420	0	5535	0	7965			0	7965
	960	83	0	5002	2722	7198	2722	11224	0	5002	0	7198			0	7198
	1160	94	0	4715	2560	6781	2560	10580	0	4715	0	6781			0	6781
	1460	110	0	4346	2387	6254	2387	9752	0	4346	0	6254			0	6254
150	720	80	0	6750	3520	9180	3520	14243	0	6750	0	9180	0	14243	0	9180
	960	98	0	6100	3234	8296	3234	12871	0	6100	0	8296	0	12871	0	8296
	1160	112	0	5750	3059	7820	3059	12133	0	5750	0	7820	0	12133	0	7820
	1460	132	0	5300	2864	7208	2864	11183	0	5300	0	7208	0	11183	0	7208
200	720	107	0	6750	3531	9180	3531	14243	0	6750	0	9180	0	14243	0	9180
	960	131	0	6100	3242	8296	3242	12871	0	6100	0	8296	0	12871	0	8296
	1160	150	0	5750	3072	7820	3072	12133	0	5750	0	7820	0	12133	0	7820
	1460	176	0	5300	2864	7208	2864	11183	0	5300	0	7208	0	11183	0	7208
275	720	147	0	8100	3920	17213	3920	25650	0	8100	0	13973	3920	25650		
	960	180	0	7320	3600	15555	3600	23180	0	7320	0	12627	3600	23180		
	1160	206	0	6900	3410	14663	3410	21850	0	6900	0	11903	3410	21850		CONSULT
	1460	241	0	6360	3169	13515	3169	20140	0	6360	0	10971	3169	20140		FACTORY
375	720	172	0	8700	4871	27550	4871	36250	0	8700	0	15008	4871	27550		
	960	201	0	8100	4586	25650	4586	33750	0	8100	0	13973	4586	25650		
	1160	246	0	7320	4209	23180	4209	30500	0	7320	0	12627	4209	23180		CONSULT
	1460	281	0	6900	3979	21850	3979	28750	0	6900	0	11903	3979	21850		FACTORY
450	720	207	0	8700	5583	27550	5583	36250	0	8700	0	15008	5583	27550		
	960	241	0	8100	5236	25650	5236	33750	0	8100	0	13973	5236	25650		
	1160	295	0	7320	4807	23180	4807	30500	0	7320	0	12627	4807	23180		CONSULT
	1460	337	0	6900	4545	21850	4545	28750	0	6900	0	11903	4545	21850		FACTORY
600	720	395	0	6360	4232	20140	4232	26500	0	6360	0	10971	4232	20140		
	960	450	0	6000	4000	19000	4000	25000	0	6000	0	10350	4000	19000		
	1160	580	0	11600	6259	36250			0	11600	0	15008	6259	36250		
	1460	720	0	10800	5885	33750			0	10800	0	13973	5885	33750		
750	720	321	0	10080	5568	31500			0	10080	0	13041	5568	31500		CONSULT
	960	367	0	9760	5404	30500	CONSULT		0	9760	0	12627	5404	30500		FACTORY
	1160	393	0	9200	5109	28750	CONSULT		0	9200	0	11903	5109	28750		FACTORY
	1460	449	0	8480	4765	26500	CONSULT		0	8480	0	10971	4765	26500		FACTORY
750	720	600	0	8000	4500	25000			0	8000	0	10350	4500	25000		
	960	344	0	11310	6959	36250			0	11310	0	15008	6259	36250		
	1160	401	0	10530	6535	33750			0	10530	0	13973	5885	33750		
	1460	458	0	9828	6177	31500	CONSULT		0	9828	0	13041	5568	31500		FACTORY
750	720	491	0	9516	6001	30500	CONSULT		0	9516	0	12627	5404	30500		FACTORY
	960	561	0	8970	5674	28750	CONSULT		0	8970	0	11903	5109	28750		FACTORY
	1160	659	0	8268	5296	26500	CONSULT		0	8268	0	10971	4765	26500		FACTORY
	1760	750	0	7800	5000	25000	CONSULT		0	7800	0	10350	4500	25000		FACTORY

Please see pages 13 and 14 for all information on Model 1200 Drives.





TABLE 4

NOTE: Drives that are rated at 1760 RPM vertical speed ARE NOT LIMITED to 1760 RPM. See Table 1.

MODEL	VERTICAL SHAFT RPM	ENGINE RPM											
		1:1	10:11	5:6	4:5	3:4	2:3	5:8	4:7	1:2	4:9	2:5	1:3*
20	1160	1160		967		870	773			580			387
	1460	1460		1217		1095	973			730			487
	1760	1760		1467		1320	1173			880			587
	3460	3460		2883		2595	2307			1730			1153
40	1160	1160		967		870	773		667	580			387
	1460	1460		1217		1095	973		840	730			487
	1760	1760		1467		1320	1173		1012	880			587
60	960	960	864	800	768	720	640	597	545	480		398	320
	1160	1160	1044	967	928	870	773	721	659	580		481	387
	1460	1460	1314	1217	1168	1095	973	908	830	730		605	487
	1760	1760	1584	1467	1408	1320	1173	1094	1000	880		730	587
80	960	960	864	800	768	720	640	597	545	480		398	320
	1160	1160	1044	967	928	870	773	721	659	580		481	387
	1460	1460	1314	1217	1168	1095	973	908	830	730		605	487
	1760	1760	1584	1467	1408	1320	1173	1094	1000	880		730	587
100	960	960	864	800	768	720	640	597	545	480		398	
	1160	1160	1044	967	928	870	773	721	659	580		481	
	1460	1460	1314	1217	1168	1095	973	908	830	730		605	
	1760	1760	1584	1467	1408	1320	1173	1094	1000	880		730	
125	720	720	650	600	576	540	480						
	960	960	867	800	768	720	640						
	1160	1160	1048	967	928	870	773						
	1460	1460	1319	1217	1168	1095	973						
1760	1760	1590	1467	1408	1320	1173							
150	720	720	650	597	576	540	480		409	360	320	293	240
	960	960	867	796	768	720	640		545	480	426	391	320
	1160	1160	1048	960	928	870	773		659	580	516	473	387
	1460	1460	1319	1210	1168	1095	973		830	730	649	595	487
1760	1760	1590	1458	1408	1320	1173		1000	880	782	717	587	
200	720	720	650	597	576	540	480		409	360	320	293	
	960	960	867	796	768	720	640		545	480	426	391	
	1160	1160	1048	960	928	870	773		659	580	516	473	
	1460	1460	1319	1210	1168	1095	973		830	730	649	595	
1760	1760	1590	1458	1408	1320	1173		1000	880	782	717		
275	720	720	656	623	576	540	480	450	409	352	318	291	
	960	960	875	830	768	720	640	600	546	470	425	388	CONSULT FACTORY
	1160	1160	1058	1003	928	870	773	725	660	568	513	468	
	1460	1460	1331	1263	1168	1095	973	913	830	715	646	590	
1760	1760	1605	1522	1408	1320	1173	1100	1000	862	778	711		
375	580	580	529	502	464	439	392	363	330	284			
	720	720	656	623	576	545	486	450	409	352			
	960	960	875	830	768	726	648	600	546	470			CONSULT FACTORY
	1160	1160	1058	1003	928	875	783	725	660	568			
1460	1460	1331	1263	1168	1105	985	913	830	715				
1760	1760	1605	1522	1408	1332	1188	1100	1000	862				
450	580	580	529	502	461	439	392	363	330	284			
	720	720	656	623	573	545	486	450	409	352			
	960	960	875	830	764	726	648	600	546	470			CONSULT FACTORY
	1160	1160	1058	1003	923	878	783	725	660	568			
1460	1460	1331	1263	1161	1105	985	913	830	715				
1760	1760	1605	1522	1400	1392	1188	1100	1000	862				
600	580	580			461	432	383	360	327	285			
	720	720			573	536	475	447	406	353			
	870	870			692	648	574	539	490	427			CONSULT FACTORY
	960	960			764	715	634	595	541	471			
1160	1160			923	864	766	719	654	569				
1460	1460			1161	1087	964	905	823	717				
1760	1760			1400	1311	1162	1091	992	864				
750	580	565		486		429	383		327	276			
	720	700		603		533	475		406	342			
	870	846		729		643	574		490	414			CONSULT FACTORY
	960	933		804		710	634		541	456			
1160	1128		972		858	766		654	551				
1460	1421		1223		1080	963		823	694				
1760	1712		1475		1302	1162		992	837				


*Model 20 1:3 ratio not available with Figure 2 or Figure 3 rotation.

Please see pages 13 and 14 for all information on Model 1200 Drives.



COMBINATION DRIVE

In response to the need for utmost reliability, a combination drive may be specified. This drive is normally installed with an electric motor top-mounted for constant service. In the event of power failure or motor failure the drive is simply converted for engine or turbine operation by lowering the integral sliding clutch into drive position. No additional pins or bolts are required for this conversion. These combination drives may be furnished with either solid or hollow shafts. Consult combination drive operation manual for installation instructions.



Combination Clutch — Sub-Assembly
Clutch Shown 'Disengaged'

TABLE OF DIMENSIONS — COMBINATION DRIVE
TABLE 7

MODEL	D	N	HORIZONTAL SHAFT U			AJ	AK	BB	BD	BE	BF	XA	XB	XC	XL	XM	XN	XO	XQ	XR	XS	XT	XAJ	XAK	XBD	XBF	BX BORE MAXIMUM
			NOM- INAL	ACTUAL	KEYWAY																						
C20	6 3/4	2 5/8	1 1/4	1.249	5/16 X 3/32	9/8	8.250	3/16	10	5/8	7/16	10 7/8			9/32	12 1/4	12 1/2	5 1/2	5 1/4	2	1 1/2	7/16					1 *
C40A	8 1/2	4 3/8	1 1/2	1.499	3/8 X 3/16	9/8	8.250	1/4	12	13/16	7/16	15 5/8			9/32	16 3/8	16	6 1/2	7	5/8	2	5/8					1 1/4
C40B	8 1/2	4 3/8	1 1/2	1.499	3/8 X 3/16	14 3/8	13.500	1/4	16 1/2	13/16	11/16	15 5/8			9/32	16 3/8	16	6 1/2	7	5/8	2	5/8					1 1/4
C60	11 1/2	4 1/4	1 1/2	1.499	3/8 X 3/16	14 3/8	13.500	1/4	16 1/2	3/4	11/16	16 3/4			9/32	20 1/4	18	7 13/16	7 3/4	3/4	2 1/4	3/4					1 1/2
C80	11 1/2	4 1/4	1 7/8	1.874	3/8 X 3/16	14 3/8	13.500	1/4	16 1/2	3/4	11/16	16 3/4			9/32	20 3/8	18	7 13/16	7 3/4	3/4	2 1/4	3/4					1 1/2
C100	11 1/2	4 1/4	1 7/8	1.874	3/8 X 3/16	14 3/8	13.500	1/4	16 1/2	3/4	11/16	16 3/4			9/32	20 3/8	18	7 13/16	7 3/4	3/4	2 1/4	3/4					1 1/2
C125	11 1/2	4 1/2	2 1/16	2.436	5/8 X 5/16	14 3/8	13.500	1/4	16 1/2	3/4	11/16	18 3/4			9/32	21 1/8	18	7 1/2	9	3/4	2 1/4	3/4					1 1/16
C150	13 1/4	5 1/4	2 1/16	2.436	5/8 X 5/16	18 1/4	13.500	1/4	20	1 1/8	11/16	20 3/4	14 5/8	5-11-NC	9/32	25 5/8	20	9	10	7/8	2 1/4	7/8					2 *
C200	13 3/4	5 1/4	2 1/16	2.436	5/8 X 5/16	18 1/4	13.500	1/4	20	1 1/8	11/16	20 3/4	14 5/8	5-11-NC	9/32	25 5/8	20	9	10	7/8	2 1/4	7/8					2
C275	16	6	2 15/16	2.936	3/4 X 3/8	23	13.500	1/4	24 1/2	1 1/8	13/16	25 1/2	14 5/8	5-11-NC	9/32	27	12 1/2	11 1/2	1 1/8	3 1/2	1						2 1/16
C375	16	6	2 15/16	2.936	3/4 X 3/8	23	13.500	1/4	24 1/2	1 1/8	13/16	25 1/2	14 5/8	5-11-NC	9/32	27	12 3/8	11 1/2	1 1/8	3 1/2	1						2 1/16
C450	16	6	3 3/4	3.749	7/8 X 1/2	23	13.500	1/4	24 1/2	1 1/8	13/16	25 1/2	14 5/8	5-11-NC	9/32	27	12 3/8	11 1/2	1 1/8	3 1/2	1						2 1/16
C600	18	6	3 3/4	3.749	7/8 X 1/2	23	13.500	1/4	24 1/2	1 1/8	13/16	26 1/4	14 5/8	5-11-NC	9/32	27	12 3/8	11 1/2	1 1/8	3 1/2	1						2 1/16
C750	21	8	4	3.998	1 X 1/2	28 1/2	22.000	1/4	30 1/2	1 1/4	13/16	36 1/8	26	4-10-NC	7/16	30	16 1/4	15	1 3/16	4	1 1/4						2 15/16

* Model C20, ratio 1:3, maximum clutch bore 7/8"; Model C150, ratio 1:3, maximum 1-11/16". Consult factory for maximum clutch bore for Fig. 2 and Fig. 3 rotation. Model C20, 1:3 ratio, not available with Fig. 2 or Fig. 3 rotation.

** Horizontal shaft dimensions shown for Model 450 apply to ratios in Table 4 only. Consult factory for dimensions of all others.

10 † "XA" dimensions shown apply to ratios in Table 4 and reducing ratios 11:10, 6:5 and 4:3 only. Consult factory for dimensions of all others.



FILE FOLDER

DESCRIPTION ON TAB:

New Well Replacement 662

Outside/inside of actual folder did not contain hand written information

Outside/inside of actual folder did contain hand written information

***Scanned as next image**

DATE 7-25-00

PWSID 04-67-041

WELL # HP 662

WELL NAME HAD NOT BOWS HP-20

BLDG. HP 662

CODE G

AVAILABILITY P

LOCATION SUGARS FERRY ROAD

LATITUDE 34.63758

LONGITUDE 77.30139

WELL DIAMETER 8"

WELL DEPTH 230'

SCREEN INTERVAL _____

YIELD 149

STATIC LEVEL 12'

PUMPING LEVEL 74'

PUMP TYPE VERTICAL PUMP

MOTOR HP 15


INTAKE DEPTH 80'

DESIGN CAPACITY 200

ACTUAL GPM 200

SIZE OF CONCRETE SLAB 12X12

HEIGHT OF CASING 12"



SOURCE INFORMATION GROUND WATER

Date Form Completed

M M D D Y Y
0 1 2 5 9 5

PWSID
0467041

Owner Assigned
source Code

Well Name (if purchase, name of system)

662 HADNOT POINT 662

Code

G

G=Ground
W=Purchase/G
Y=G w/direct influence
Z=W w/direct influence

If Purchase, seller ID#

Source Begin Date

Source exempt—
SWTR?

Direct Influence Date

Availability

Y
 N

P

P=Permanent
E=Emergency
S=Seasonal
I=Interim
O=Other

Location of well within the system (if purchase, location of master meter)

SNEADS PERRY ROAD

Latitude (N)

Longitude (W)

How Determined

GPS Data

No. of Sats. Locked on

343813.9

07718042

G

G=GPS
M=Map
S=Surveyed

Q3

Q# or
DOP #

4

(If purchase, use seller's primary source lat/long)

Vulnerable (VOCs) Y
 N

Assessment Date

ENTRY POINT INFORMATION

Use Code

Availability

Owner Assigned
Entry Point Code

Entry Point Name

C

C=Ground/Permanent
D=Ground/non-permanent

P

P=Year-round
E=Emergency
S=Seasonal
I=Interim
O=Other

100

HADNOT POINT WTP

Location:

Well Site: Owned or controlled? (Y,N) Control Area (100' radius)? (Y,N) If no, explain:

Sources of pollution/distance: 80' to Road

Surface water within 200'? Y N If yes, actual distance feet If yes, bact. samples collected? (Y,N)

Adequate slope? (Y,N) Flooding? (Y,N) Maintenance: OK

Well House: Free of stored materials? (Y,N) Properly drained? (Y,N) Locked? (Y,N)

Condition of house: OK Type of freeze protection: Elec Heat

Well: Diameter: 8" Type: SCREENED Yield (gpm): 200 Properly sealed? (Y,N)

Properly vented? (Y,N) Casing depth 50 ft. (If unknown, put 'UNK') Well depth: 130 Meter available? (Y,N)

Concrete slab adequate? (Y,N) If no, explain: well not in center of slab Size: 12x12

Size of blow-off: 4" (V) Sample tap: Before treatment? (Y,N) After treatment? (Y,N)

Pumps: Capacity: GPM: 200 146 HP: 15 Pump intake depth: 80 Auxiliary Power? (Y,N)

Type pump: VERTICAL TURBINE Height above floor (pump/casing): 12" /

Storage at well site: Elev: Hydro: Ground:


If hydroautomatic, air volume control? (Y,N) Safety valves? (Y,N) Coded? (Y,N)


High service pumps: 1. gpm hp 2. gpm hp 3. gpm hp Auxiliary Power? (Y,N)


Is the water treated at this well? Y N If yes, complete back of form.


If other wells are treated here, which ones? If treated elsewhere, where? HD-20 PLANT

If purchase, retreat? Y N If yes, complete back of form. 1 Seal pump pedestal 2










639 (NEW)

8-26-85

AL	SL	Pz	PO	PSI	GPM	Time
81	10	43	33	68	108	1350
		54	44	60	128	1400
		62	52	55	144	1410
		67	57	50	158	1420
		73	63	45	168	1430




8 WATER WELLS - MILLING CORP BRSC - CAMP

NO	LOCATION	Pump Data		PUMP DEPTH	GALLONS PER MINUTE	VISCOSITY	1 ST SCREEN SETTING	2 ND SCREEN SETTING	3 RD SCREEN SETTING	4 TH SCREEN SETTING	5 TH SCREEN SETTING	FT. TO WATER LEVELS		PUMP RATE GPM	
		MODEL	SIZE									STATIC	DOWN		
11	Barkley Manor	8MS	8	20	20	70	45	65-75	115-135	132-157	—	—	35	49	300
1	Stone Street	8MS	8	20	20	80	44	106-100	150-170	217-227	—	—	15	80	300
	#4006 MIDWAY PARK	8HL	8	30	40	80	42	90-114	116-134	—	—	—	25	70	450
21	Piney Green Rd	8MS	6	15	20	70	40	60-70	125-135	160-170	220-230	—	18.5"	54.9	200
27	Sneeds Ferry Rd	8MS	6	15	20	70	40	50-65	87-102	125-135	—	—	14	44	175
R 227	RIPLE RING C	8HL	8	25	40	80	35	190-210	223-233	242-247	—	—	23	58	300
638	TARAWA TERRACE	8MS	6	15	20	85	35	70-95	132-142	—	—	—	27	63	160
639	Sneeds Ferry Rd	8MS	6	15	20	70	42	121-131	134-146	185-195	215-220	225-230	4	96	200

662

these wells — 10-10-84



CONSOLIDATED PUMP & EQUIPMENT, INC.

DISTRIBUTORS AND MANUFACTURER REPRESENTATIVES • WATER & WASTE WATER TREATMENT
POST OFFICE BOX 3188 • ROCK HILL, SOUTH CAROLINA 29730 • 803/328-1891

March 28, 1983

SUBMITTAL DATA

JOB:

Replace Water Wells
Camp Lejeune, N. C.

Engineer:

Peirson & Whitman, Inc.


Contractor:

East Coast Construction Co.

Material Submitted:

- 8 - Jacuzzi Model 15-SMSA6 Verticle Turbine Pump consisting of 6 stage SMS pump head, 10' - 6" suction pipe with cone strainer, 100' - 6" discharge column, 1" drive shaft, model L6A discharge head, model S-20 Combination Right Angle Gear Drive, 1 : 1 Ratio, and 15 HP V. H. S. motor.

Conditions of service 200 GPM @ 190.5' TDH




TURBINE PUMP CURVE

MAY 15, 1970

SECTION
2120

BMS



NUMBER OF BOWLS	CHANGE EFFICIENCY AS FOLLOWS
1	-4
2	-3
3	-2
4	-1

Change in efficiency may affect both head and horsepower

Bowl Dia.	7-1/2 In.
Bowl No.	3591-S, C.I., ENAM.
Impeller No.	3590, BRONZE
Eye Area	6.6 Sq. In.
Imp. Type	SEMI-OPEN K = 4.28

STAGE PERFORMANCE

Curve No.	8M-172
R. P. M.	1780
Bowl	8MS


Performance based on pumping clear, fresh water at a temperature not over 85°F., and free of gas, air or abrasives, and with bowls properly adjusted and submerged.

BRAKE HORSEPOWER

3
2
1
0



Turbine Bowl



ALL DIMENSIONS IN INCHES


Nom. Bowl Size	Bowl Figure Number	Bowl Dia. Max. O.D. STD. A	Bowl Dia. Turned ALT. A	B	C	E	F	Max. G	Suction Bell			O.L.			W.L.	Available Outer Column and Suction Pipe
									J	K	W	X	Y	Z		
6	6J,6L	5 5/8		3/8	4 1/2	3 3/4	3 3/4	5	4	7 1/4	3	9 1/2	22	7 1/2		3, 4, 5
	1			4 1/4		4										
8	8J,8L,8K,8H,8Y	7 7/8	7 1/2	1	6	5 1/2	4	5	4 1/2	9 1/4	3	9 1/2	22	7 1/2		4, 5, 6
	7 1/8	1 1/8		7 1/2		4, 5, 6										
10	10L,10M,10H	9 1/2	9 1/4	1 1/2	8	7	6	4 1/8	5 1/4	11 1/4	3	9 1/2	22	7 1/2		4, 5, 6, 8
10	10W,10Y,10Z	9 3/4	9 1/2	1 1/8	8 1/2	8 1/2	6 1/4	5 1/8	7	14 1/4	3	9 1/2	22	7 1/2		6, 8, 10
12	12L, 12M, 12H, 12X	11 1/8	11 1/4	1 1/8	9	10 1/2	5 1/4	3 3/4	6	13 1/4	3	9 1/2	22	7 1/2		6, 8, 10
12	12W	12 1/8	12	1 1/8	9	11 1/4	5 1/4	3 3/4	6	13 1/4	3	9 1/2	22	7 1/2		6, 8, 10
14	14L,14M,14H,14X	13 1/2	13 1/4	1 5/8	9 5/8	12 1/2	7 3/8	5 1/8	8	15 1/4	3	9 1/2	22	7 1/2		8, 10, 12
14	14W	14 1/8	13 3/4	1 5/8	9 5/8	13 1/4	7 3/8	5 1/8	8	15 1/4	3	9 1/2	22	7 1/2		8, 10, 12
16	ALL	15 1/2	15 1/4	1 5/8	9 5/8	15	8	6 3/8	10	22	3	9 1/2	22	7 1/2		10, 12, 14
20	ALL	19 1/4	19 1/4	1 5/8	14	18	12	6 3/8	12 1/2	27	3	9 1/2	22	7 1/2		12, 14, 16
24	ALL	23 3/4	23 3/4	2 1/8	20	21	14	3 3/8	14	32	1	16 1/2	29	14 1/2		12, 14, 16, 18
28	ALL	27	27	2 5/8	24	24	15	3 3/8	16	38	1	16 1/2	29	14 1/2		14, 16, 18, 20, 22

* Note: Maximum Diameter for 24" Bowl is Discharge Column Flange at 25" and for 28" is 27 1/2".

D	Lineshaft Dia. & Pitch (L.H.)	3/8	1	1 1/8	1 1/2	1 5/8	1 3/4	2 1/8	2 1/4	2 3/8	2 1/2
		H	O.L. Inner Col. & Thread (R.H.)	1 1/4-12P.	1 1/2-12P.	2 1/8-12P.	2 1/2-12P.	3 1/8-12P.	3 3/8-12P.	3 7/8-12P.	4-8P.



Turbine Bowl




Nom. Bowl Size	Bowl Figure Number	(M) = BOWL ASSEMBLY LENGTH W/SUCTION BELL - INCHES													
		NUMBER OF BOWLS													
		1	2	3	4	5	6	7	8	9	10	11	12	13	14
6	6L	18½	22	25½	29	32½	36	39½	43	46½	50	53½	57	60½	64
	6M,H,X,W,Y	19½	24½	29½	34	38½	43½	48½	53	57½	62½	67½	72	76½	81½
	8J,8L,8K,8M,8H	23½	28½	34½	40	45½	51½	56½	62½	68½	73½	79½	85	90½	96½
8	8Y	25	32½	40	47½	55	62½	70	77½	85	92½	100	107½	115	122½
10	10L,M,H	29½	36½	43½	50½	57½	64½	71½	78½	85½	92½	99½	106½	113½	120½
10	10W,Y,Z	34½	42½	51½	59½	68½	76½	85½	93½	102½	110½	119½	127½	136½	144½
12	12L, M, H, X	33½	44½	54½	65½	75½	86½	96½	107½	117½	128½	138½	149½	159½	170½
12	12W	34½	45½	57	68½	79½	90½	102	113½	124½	135½	147	158½	169½	180½
14	14L,M,H,X	40½	53½	65½	78½	90½	103½	115½	128½	140½	153½	165½	178½	190½	203½
14	14W	41½	54½	68	81½	94½	107½	121	134½	157½	160½	174	187½	200½	213½
16	ALL	46	61	76	91	106	121	136	151	166	181	196	211	226	241
20	ALL	59½	77½	95½	113½	131½	149½	167½	185½	203½	221½	239½			
24	ALL	70	91	112	133	154	175	196	217	238	259				
28	ALL	80	104	128	152	176	200	224	248	272					


Nom. Bowl Size	Bowl Figure Number	(N) = BOWL ASSEMBLY LENGTH W/SUCTION FLANGE - INCHES													
		NUMBER OF BOWLS													
		1	2	3	4	5	6	7	8	9	10	11	12	13	14
6	6L	19½	23	26½	30	33½	37	40½	44	47½	51	54½	58	61½	65
	6M,H,X,W	20½	25½	30½	35	39½	44½	49½	54	58½	63½	68½	73	77½	82½
8	8J,8L,8K,8M,8H	23½	29½	34½	40½	46½	51½	57½	63	68½	74½	79½	85½	91½	96½
8	8Y	25½	33	40½	48	55½	63	70½	78	85½	93	100½	108	115½	123
10	10L,M,H	28½	35½	42½	49½	56½	63½	70½	77½	84½	91½	98½	105½	112½	119½
10	10W,Y,Z	33½	41½	50½	58½	67½	75½	84½	92½	101½	109½	118½	126½	135½	143½
12	12L, M, H, X	31½	42	52½	63	73½	84	94½	105	115½	126	136½	147	157½	168
12	12W	32½	44½	55½	67	78½	89½	100½	112	123½	134½	145½	157	168½	179½
14	14L,M,H,X	38½	51½	63½	76½	88½	101½	113½	126½	138½	151½	163½	176½	188½	201½
14	14W	39½	52½	65½	79½	92½	105½	118½	132½	145½	158½	171½	185½	198½	211½
16	ALL	42½	57½	72½	87½	102½	117½	132½	147½	162½	177½	192½	207½	222½	237½
20	ALL	53½	71½	89½	107½	125½	143½	161½	179½	197½	215½	233½			
24	ALL	59½	80½	101½	122½	143½	164½	185½	206½	227½	248½				
28	ALL	67½	91½	115½	139½	163½	187½	211½	235½	259½					




Turbine Column – Water-Lube, Butt Joint



Nominal Column Size In.	A	B	L	M
3	4'11 1/2"	6 1/2"	9'11 1/2"	1/2"
4		6 1/2"	9'11 1/2"	1/2"
5	4'11 1/2"	5 1/2"	9'11 1/2"	1/2"
8				
10				
12				
14				
16				



Cast, Standard Discharge Heads




Head Fig. No.	Max. Size (In.) Disch.	Inner Col. (In.)	Outer Col. (In.)	DIMENSIONS INCHES																	
				A	B	C	D	E	F	G	H	J	K	L	M	N	P	R	S	T	Z
L5A L5AB	6	1½	5	10	9¾	8¾	¾	3¾	8¾	15	4	6	14	14	8¾	15	13	1	1½	¾	2¾
L6A L6AB	6	1½	6	10	9¾	8¾	¾	3¾	8¾	15	4	6	14	14	8¾	15	13	1	1½	¾	2¾
L8C L8CD	8	2	8	16	14	13	¾	3¾	7	15	4	6	16	17	9	18	15	1	1½	1	3¾
L10C	10	2½	10	16	14	13	¾	4	9	18	5	6	16	18	10	19	16	1	1½	1	3¾



Water Lubricated Turbine Pump

MATERIAL SPECIFICATIONS OF STANDARD CONSTRUCTION

KEY NO.	DESCRIPTION	MATERIAL	SPECIFICATION IF APPLICABLE	PART ORDER NUMBER
1	Discharge Head	Cast Iron	ASTM A48 CL.30	
2	Head Column Flange	Cast Iron	ASTM A48 CL.30	
3	Head Column Flange Gasket	Asbestos		
4	Studs (Hd. Column Flange Assy)	Steel	C1137	
5	Nuts (Used W/Key No. 4 Head Column Flange Assy)	Low Carbon Steel	ASTM A-307	
6	Head Discharge Flange	Cast Iron	ASTM A-126	
7	Head Discharge Flange Gasket	Asbestos		
8	Discharge Flg. Assy. Cap Scr.	Steel	ASTM A-301	
9	Discharge Flg. Assy. Nuts (Used with Key No. 8)	Low Carbon Steel	ASTM A-307	
10	Head Dsch. Flg. Assy. Studs	Steel	C1137	
11	Head Dsch. Flg. Assy. Nuts (Used With Key No. 10)	Low Carbon Steel	ASTM A-307	
14	Head Packing Housing W/Brg. Includes Key No. 32	Cast Iron (Pkg. Hsg.)	ASTM A48 CL.30	
15	"O" Ring	Buna-N		
16	Head Packing Housing Cap Scr.	S. Steel	300 Series	
18	W/L Headshaft	S. Steel	AISI 316	
19	Headshaft Flinger	Neoprene		
20	Headshaft Adj. Nut	Steel	C-1213	
21	Hd. Pkg. Hsg. Sand Shield	Bronze	SAE 660	
22	Packing (Set)	Asbestos		
23	Packing Follower	Bronze	SAE 40	
25	Hd. Pkg. Housing Grease Fittings	Steel		
26	Packing Follower Studs	S. Steel	AISI 416	
27	Packing Follower Retn. Nuts	S. Steel	300 Series	
28	Adapter Flange	Cast Iron	ASTM A48 CL45	
29	Adapter Flange O-Ring	Buna-N		
30	Adapter Flg. Assy. Cap Screws	S. Steel	300 Series	
32	W/L Headshaft Bearing	Bronze	SAE 660	
33	Headshaft Gib Key	Steel		
34	Adj. Nut Machine Screw	S. Plated		
67	Shaft Coupling (Hd. Shaft, Line Shaft, Bowl Shaf.)	Steel	C1137	
68	Shaft Adapter Coupling Hd/Sht, L/Sht, Bowl/Sht	Steel	C1137	
69	O/C Coupling	Blk. Steel	ASTM A-120-57T Grade B	
76	W/L O/C Section	Black Steel	ASTM A-120-57T Grade B	
77	W/L O/C Section	Black Steel	ASTM A-120-57T Grade B	
78	W/L L/S Bearing Spider	Brass		
79	W/L L/S Bearing	Rubber		




June 1, 1974


Water Lubricated Turbine Pump

MATERIAL SPECIFICATIONS OF STANDARD CONSTRUCTION



KEY NO.	DESCRIPTION	MATERIAL	SPECIFICATION IF APPLICABLE	PART ORDER NUMBER
80	W/L S/S Sleeve	S. Steel	304	
81	W/L L/S Extension 3' - 9 7/8" Lg.	Steel	C-1045	
82	W/S L/S Section (5' - 0" Lg.)	Steel	C-1045	
83	W/L L/S Section 10' - 0" Lg.	Steel	C-1045	
84	W/L Bowl Shaft	S. Steel	AISI 416	
90	W/L Discharge Housing Assy (Includes Key No. 91 & No. 92)	Cast Iron	ASTM A48 CL30	
91	W/L Upper Disch. Hsg. Brg.	Neoprene		
92	W/L Lower Disch. Hsg. Brg.	Neoprene		
93	W/L Disch. Hsg. Brg. Sand Cap	Bronze	SAE 40	
94	Sand Cap Set Screws (For K. No. 93)	S. Steel	300 Series	
103	Bowl Assy. (Closed Type) Includes Key No. 104	Cast Iron	ASTM A48 CL 30	
104	Bowl Bearing	Bronze	SAE 794	
105	Bowl Assy. (Semi-Open Type) Includes Key No. 104	Cast Iron	ASTM A48 CL30	
106	Impeller (Closed Type)	Bronze	SAE 40	
107	Impeller (Semi-Open Type)	Bronze	SAE 40	
108	Taper Lock	S. Steel	416 SS	
109	Brg. Stage Assy. (Closed Type) Includes Key No. 110	Cast Iron	ASTM A48 CL30	
110	Bearing Stg. Bearing	Bronze	SAE 660	
111	Brg. Stg. Assy. (Semi-Open) Includes Key No. 110	Cast Iron	ASTM A48 CL30	
112	Pipe Plug (For Key No. 109 & No. 111)	Galv. Steel		
113	Bearing Stage End Plug	Galv. Steel		
114	Bearing Stage Sand Cap	Bronze	SAE 40	
115	Sand Cap Set Screws (For K. No. 114)	S. Steel	300 Series	
116	Bowl Suction Flange	Cast Iron	ASTM A48 CL30	
117	Bowl Assy. Cap Screws	S. Steel	300 Series	
119	Suction Bell (Optional; Delete Key No. 116 if Suct. Bell is Used)	Cast Iron	ASTM A48 CL30	
152	W/L O/C Assy. T & C (Nom. 5' Lg.) (Assy of Key No. 69 & No. 76)	Black Steel	ASTM A-120-57T Grade B	
153	W/L O/C Assy T & C (Nom. 10' Lg.) (Assy of Key No. 69 & No. 77)	Black Steel	ASTM A-120-57T Grade B	




WATER LUBRICATED TURBINE PUMP PARTS DIAGRAM




TYPICAL STANDARD HEAD



TYPICAL HEAVY DUTY HEAD



BOWL ASSEMBLY



BOWL COLUMN FLANGE




TABLE 3

NOTE: Drives that are rated at 1760 RPM vertical speed ARE NOT LIMITED to 1760 RPM. See Table 1.

MODEL	Vertical Shaft RPM	H.P. Rating	DOWNTHRUST CAPACITY IN POUNDS													
			HOLLOW SHAFT						SOLID SHAFT						COMB.	
			Type SL		Type S		Type SH		Type SSL		Type SS		Type SSH		Type C	
			Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.
20	1160	15	0	978	797	2358	797	3680	0	978	0	2358			0	2358
	1460	18	0	901	760	2173	760	3392	0	901	0	2173			0	2173
	1760	20	0	850	700	2050	700	3200	0	850	0	2050			0	2050
	3460	30	0	680	534	1640	534	2560	0	680	0	1640			0	1640
40	1160	30	0	1495	1138	3565	1138	5520	0	1495	0	3565			0	3565
	1460	35	0	1378	1055	3286	1055	5088	0	1378	0	3286			0	3286
	1760	40	0	1300	1000	3100	1000	4800	0	1300	0	3100			0	3100
60	960	39	0	2074	1490	5002	1490	7320	0	2074	0	5002			0	5002
	1160	45	0	1955	1422	4715	1422	6900	0	1955	0	4715			0	4715
	1460	53	0	1802	1331	4346	1331	6360	0	1802	0	4346			0	4346
	1760	60	0	1700	1250	4100	1250	6000	0	1700	0	4100			0	4100
80	960	52	0	3904	2085	6954	2085	11224	0	3904	0	6954			0	6954
	1160	60	0	3680	1991	6555	1991	10580	0	3680	0	6555			0	6555
	1460	70	0	3392	1846	6042	1846	9752	0	3392	0	6042			0	6042
	1760	80	0	3200	1750	5700	1750	9200	0	3200	0	5700			0	5700
100	960	66	0	3904	2101	7198	2101	11224	0	3904	0	7198			0	7198
	1160	75	0	3680	1991	6785	1991	10580	0	3680	0	6785			0	6785
	1460	88	0	3392	1856	6254	1856	9752	0	3392	0	6254			0	6254
	1760	100	0	3200	1750	5900	1750	9200	0	3200	0	5900			0	5900
125	720	68	0	5535	3135	7965	3135	12420	0	5535	0	7965			0	7965
	960	83	0	5002	2722	7198	2722	11224	0	5002	0	7198			0	7198
	1160	94	0	4715	2560	6781	2560	10580	0	4715	0	6781			0	6781
	1460	110	0	4346	2387	6254	2387	9752	0	4346	0	6254			0	6254
150	720	80	0	6750	3520	9180	3520	14243	0	6750	0	9180	0	14243	0	9180
	960	98	0	6100	3234	8296	3234	12871	0	6100	0	8296	0	12871	0	8296
	1160	112	0	5750	3059	7820	3059	12133	0	5750	0	7820	0	12133	0	7820
	1460	132	0	5300	2864	7208	2864	11183	0	5300	0	7208	0	11183	0	7208
200	720	80	0	6750	3520	9180	3520	14243	0	6750	0	9180	0	14243	0	9180
	960	98	0	6100	3234	8296	3234	12871	0	6100	0	8296	0	12871	0	8296
	1160	112	0	5750	3059	7820	3059	12133	0	5750	0	7820	0	12133	0	7820
	1460	132	0	5300	2864	7208	2864	11183	0	5300	0	7208	0	11183	0	7208
275	720	107	0	6750	3531	9180	3531	14243	0	6750	0	9180	0	14243	0	9180
	960	131	0	6100	3242	8296	3242	12871	0	6100	0	8296	0	12871	0	8296
	1160	150	0	5750	3072	7820	3072	12133	0	5750	0	7820	0	12133	0	7820
	1460	176	0	5300	2864	7208	2864	11183	0	5300	0	7208	0	11183	0	7208
375	720	147	0	8100	3920	12133	3920	25650	0	8100	0	13973	3920	25650		
	960	180	0	7320	3600	15555	3600	23180	0	7320	0	12627	3600	23180		
	1160	206	0	6900	3410	14663	3410	21850	0	6900	0	11903	3410	21850		
	1460	241	0	6360	3169	13515	3169	20140	0	6360	0	10971	3169	20140		
450	720	207	0	8700	4871	27550	4871	36250	0	8700	0	15008	4871	27550		
	960	246	0	7320	4209	23180	4209	30500	0	7320	0	12627	4209	23180		
	1160	281	0	6900	3979	21850	3979	28750	0	6900	0	11903	3979	21850		
	1460	329	0	6360	3702	20140	3702	26500	0	6360	0	10971	3702	20140		
600	580	275	0	11600	6259	36250			0	11600	0	15008	6259	36250		
	720	321	0	10800	5885	33750			0	10800	0	13973	5885	33750		
	870	367	0	10080	5568	31500			0	10080	0	13041	5568	31500		
	960	393	0	9760	5404	30500			0	9760	0	12627	5404	30500		
750	580	344	0	11310	6959	36250			0	11310	0	15008	6259	36250		
	720	401	0	10530	6535	33750			0	10530	0	13973	5885	33750		
	870	458	0	9828	6177	31500			0	9828	0	13041	5568	31500		
	960	491	0	9516	6001	30500			0	9516	0	12627	5404	30500		

Please see pages 13 and 14 for all information on Model 1200 Drives.





TABLE 4

NOTE: Drives that are rated at 1760 RPM vertical speed ARE NOT LIMITED to 1760 RPM. See Table 1.

MODEL	VERTICAL SHAFT RPM	ENGINE RPM											
		1:1	10:11	5:6	4:5	3:4	2:3	5:8	4:7	1:2	4:9	2:5	1:3*
20	1160	1160		967		870	773			580			387
	1460	1460		1217		1095	973			730			487
	1760	1760		1467		1320	1173			880			587
	3460	3460		2883		2595	2307			1730			1153
40	1160	1160		967		870	773		667	580			387
	1460	1460		1217		1095	973		840	730			487
	1760	1760		1467		1320	1173		1012	880			587
60	960	960	864	800	768	720	640	597	545	480		398	320
	1160	1160	1044	967	928	870	773	721	659	580		481	387
	1460	1460	1314	1217	1168	1095	973	908	830	730		605	487
	1760	1760	1584	1467	1408	1320	1173	1094	1000	880		730	587
80	960	960	864	800	768	720	640	597	545	480		398	320
	1160	1160	1044	967	928	870	773	721	659	580		481	387
	1460	1460	1314	1217	1168	1095	973	908	830	730		605	487
	1760	1760	1584	1467	1408	1320	1173	1094	1000	880		730	587
100	960	960	864	800	768	720	640	597	545	480		398	320
	1160	1160	1044	967	928	870	773	721	659	580		481	387
	1460	1460	1314	1217	1168	1095	973	908	830	730		605	487
	1760	1760	1584	1467	1408	1320	1173	1094	1000	880		730	587
125	720	720	650	600	576	540	480						
	960	960	867	800	768	720	640						
	1160	1160	1048	967	928	870	773						
	1460	1460	1319	1217	1168	1095	973						
1760	1760	1590	1467	1408	1320	1173							
150	720	720	650	597	576	540	480		409	360	320	293	240
	960	960	867	796	768	720	640		545	480	426	391	320
	1160	1160	1048	960	928	870	773		659	580	516	473	387
	1460	1460	1319	1210	1168	1095	973		830	730	649	595	487
1760	1760	1590	1458	1408	1320	1173		1000	880	782	717	587	
200	720	720	650	597	576	540	480		409	360	320	293	
	960	960	867	796	768	720	640		545	480	426	391	
	1160	1160	1048	960	928	870	773		659	580	516	473	
	1460	1460	1319	1210	1168	1095	973		830	730	649	595	
1760	1760	1590	1458	1408	1320	1173		1000	880	782	717		
275	720	720	656	623	576	540	480	450	409	352	318	291	
	960	960	875	830	768	720	640	600	546	470	425	388	CONSULT FACTORY
	1160	1160	1058	1003	928	870	773	725	660	568	513	468	
	1460	1460	1331	1263	1168	1095	973	913	830	715	646	590	
1760	1760	1605	1522	1408	1320	1173	1100	1000	862	778	711		
375	580	580	529	502	464	439	392	363	330	284			
	720	720	656	623	576	545	486	450	409	352			
	960	960	875	830	768	726	648	600	546	470			
	1160	1160	1058	1003	928	875	783	725	660	568			
1460	1460	1331	1263	1168	1105	985	913	830	715				
1760	1760	1605	1522	1408	1332	1188	1100	1000	862				
450	580	580	529	502	461	439	392	363	330	284			
	720	720	656	623	573	545	486	450	409	352			
	960	960	875	830	764	726	648	600	546	470			
	1160	1160	1058	1003	923	878	783	725	660	568			
1460	1460	1331	1263	1161	1105	985	913	830	715				
1760	1760	1605	1522	1400	1382	1188	1100	1000	862				
600	580	580			461	432	383	360	327	285			
	720	720			573	536	475	447	406	353			
	870	870			692	648	574	539	490	427			
	960	960			764	715	634	595	541	471			
1160	1160			923	864	766	719	654	569				
1460	1460			1161	1087	964	905	823	717				
1760	1760			1400	1311	1162	1091	992	864				
750	580	565		486		429	383		327	276			
	720	700		603		533	475		406	342			
	870	846		729		643	574		490	414			
	960	933		804		710	634		541	456			
1160	1128		972		858	766		654	551				
1460	1421		1223		1080	963		823	694				
1760	1712		1475		1302	1162		992	837				



*Model 20 1:3 ratio not available with Figure 2 or Figure 3 rotation.

Please see pages 13 and 14 for all information on Model 1200 Drives.



COMBINATION DRIVE

In response to the need for utmost reliability, a combination drive may be specified. This drive is normally installed with an electric motor top-mounted for constant service. In the event of power failure or motor failure the drive is simply converted for engine or turbine operation by lowering the integral sliding clutch into drive position. No additional pins or bolts are required for this conversion. These combination drives may be furnished with either solid or hollow shafts. Consult combination drive operation manual for installation instructions.



Combination Clutch — Sub-Assembly
Clutch Shown 'Disengaged'


TABLE OF DIMENSIONS — COMBINATION DRIVE
TABLE 7

MODEL	D	N	HORIZONTAL SHAFT U		AJ	AK	BB	BD	BE	BF	XA	XB	XC	XL	XM	XN	XO	XQ	XR	XS	XT	XAJ	XAK	XBD	XBF	BX BORE		
			NOM-INAL	ACTUAL																						KEYWAY	MAXIMUM	MINIMUM
C20	6 3/4	2 5/8	1 1/4	1.249	5 1/8 X 3/32	9 1/8	8.250	3 1/16	10	5 5/8	7 1/16	10 7/8				9 3/32	12 1/4	12 1/2	5 1/2	5 1/4	1 1/2	1 1/2	7 1/16					1 *
C40A	8 1/2	4 3/8	1 1/2	1.499	3 5/8 X 3/16	9 1/8	8.250	1 1/4	12	13 1/16	7 1/16	15 5/8			9 3/32	16 3/16	16	6 1/2	7	5 5/8	2	5 5/8					1 1/4	
C40B	8 1/2	4 3/8	1 1/2	1.499	3 5/8 X 3/16	14 3/4	13.500	1 1/4	16 1/2	13 1/16	11 1/16	15 5/8			9 3/32	16 3/16	16	6 1/2	7	5 5/8	2	5 5/8					1 1/4	
C60	11 1/2	4 1/4	1 1/2	1.499	3 5/8 X 3/16	14 3/4	13.500	1 1/4	16 1/2	3 1/4	11 1/16	16 3/4			9 3/32	20 1/4	18	7 13/16	7 3/4	3 3/4	2 1/4	3 3/4					1 1/2	
C80	11 1/2	4 1/4	1 1/8	1.874	3 5/8 X 3/16	14 3/4	13.500	1 1/4	16 1/2	3 1/4	11 1/16	16 3/4			9 3/32	20 3/8	18	7 13/16	7 3/4	3 3/4	2 1/4	3 3/4					1 1/2	
C100	11 1/2	4 1/4	1 1/8	1.874	3 5/8 X 3/16	14 3/4	13.500	1 1/4	16 1/2	3 1/4	11 1/16	16 3/4			9 3/32	20 3/8	18	7 13/16	7 3/4	3 3/4	2 1/4	3 3/4					1 1/2	
C125	11 1/2	4 1/2	2 7/16	2.436	3 5/8 X 5/16	14 3/4	13.500	1 1/4	16 1/2	3 1/4	11 1/16	18 3/4			9 3/32	21 1/8	18	7 1/2	9	3 3/4	2 1/4	3 3/4					1 1/16	
C150	13 1/4	5 1/4	2 1/16	2.436	3 5/8 X 5/16	18 1/4	13.500	1 1/4	20	18	11 1/16	20 3/4	14 3/8	5-11-NC	9 3/32	25 5/8	20	9	10	7 5/8	2 1/4	7 5/8					2 *	
C200	13 3/4	5 1/4	2 1/16	2.436	3 5/8 X 5/16	18 1/4	13.500	1 1/4	20	18	11 1/16	20 3/4	14 3/8	5-11-NC	9 3/32	25 5/8	20	9	10	7 5/8	2 1/4	7 5/8					2	
C275	16	6	2 15/16	2.936	3 1/2 X 3/8	23	13.500	1 1/4	24 1/2	18	13 1/16	25 1/2	14 3/8	5-11-NC	9 3/32		27	12 1/2	11 1/2	1 1/8	3 1/2	1					2 1/16	
C375	16	6	2 15/16	2.936	3 1/2 X 3/8	23	13.500	1 1/4	24 1/2	18	13 1/16	25 1/2	14 3/8	5-11-NC	9 3/32		27	12 3/8	11 1/2	1 1/8	3 1/2	1					2 1/16	
C450	16	6	3 3/4	3.749	3 1/2 X 1/2	23	13.500	1 1/4	24 1/2	18	13 1/16	25 1/2	14 3/8	5-11-NC	9 3/32		27	12 3/8	11 1/2	1 1/8	3 1/2	1					2 1/16	
C600	18	6	3 3/4	3.749	3 1/2 X 1/2	23	13.500	1 1/4	24 1/2	18	13 1/16	26 3/4	14 3/8	5-11-NC	9 3/32		27	12 3/8	11 1/2	1 1/8	3 1/2	1					2 1/16	
C750	21	8	4	3.998	1 X 1/2	28 1/2	22.000	1 1/4	30 1/2	14	13 1/16	36 3/8	26 3/4	10-NC	1 1/16		30	16 1/4	15	1 3/16	4	1 1/4					2 15/16	

* Model C20, ratio 1:3, maximum clutch bore 7/8"; Model C150, ratio 1:3, maximum 1-11/16". Consult factory for maximum clutch bore for Fig. 2 and Fig. 3 rotation. Model C20, 1:3 ratio, not available with Fig. 2 or Fig. 3 rotation.

** Horizontal shaft dimensions shown for Model 450 apply to ratios in Table 4 only. Consult factory for dimensions of all others.

10 † "XA" dimensions shown apply to ratios in Table 4 and reducing ratios 11:10, 6:5 and 4:3 only. Consult factory for dimensions of all others.



amarillo






MARMDN

RIGHT
ANGLE
GEAR
DRIVES



CATALOG NUMBER 30 • MARCH 1981

New Wells Repair These
639, LCH-4006, 621
627, 611, RR-227
614 - TT New Well
By Maint.







TABLE 3

NOTE: Drives that are rated at 1760 RPM vertical speed ARE NOT LIMITED to 1760 RPM. See Table 1.


MODEL	Vertical Shaft RPM	H.P. Rating	DOWNTHRUST CAPACITY IN POUNDS													
			HOLLOW SHAFT						SOLID SHAFT						COMB.	
			Type SL		Type S		Type SH		Type SSL		Type SS		Type SSH		Type C	
			Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.
20	1160	15	0	978	797	2358	797	3680	0	978	0	2358			0	2358
	1460	18	0	901	760	2173	760	3392	0	901	0	2173			0	2173
	1760	20	0	850	700	2050	700	3200	0	850	0	2050			0	2050
	3460	30	0	680	534	1640	534	2560	0	680	0	1640			0	1640
40	1160	30	0	1495	1138	3565	1138	5520	0	1495	0	3565			0	3565
	1460	35	0	1378	1055	3286	1055	5088	0	1378	0	3286			0	3286
	1760	40	0	1300	1000	3100	1000	4800	0	1300	0	3100			0	3100
60	960	39	0	2074	1490	5002	1490	7320	0	2074	0	5002			0	5002
	1160	45	0	1955	1422	4715	1422	6900	0	1955	0	4715			0	4715
	1460	53	0	1802	1331	4346	1331	6360	0	1802	0	4346			0	4346
	1760	60	0	1700	1250	4100	1250	6000	0	1700	0	4100			0	4100
80	960	52	0	3904	2085	6954	2085	11224	0	3904	0	6954			0	6954
	1160	60	0	3680	1991	6555	1991	10580	0	3680	0	6555			0	6555
	1460	70	0	3392	1846	6042	1846	9752	0	3392	0	6042			0	6042
	1760	80	0	3200	1750	5700	1750	9200	0	3200	0	5700			0	5700
100	960	66	0	3904	2101	7198	2101	11224	0	3904	0	7198			0	7198
	1160	75	0	3680	1991	6785	1991	10580	0	3680	0	6785			0	6785
	1460	88	0	3392	1856	6254	1856	9752	0	3392	0	6254			0	6254
	1760	100	0	3200	1750	5900	1750	9200	0	3200	0	5900			0	5900
125	720	68	0	5535	3135	7965	3135	12420	0	5535	0	7965			0	7965
	960	83	0	5002	2722	7198	2722	11224	0	5002	0	7198			0	7198
	1160	94	0	4715	2560	6781	2560	10580	0	4715	0	6781			0	6781
	1460	110	0	4346	2387	6254	2387	9752	0	4346	0	6254			0	6254
150	720	80	0	6750	3520	9180	3520	14243	0	6750	0	9180	0	14243	0	9180
	960	98	0	6100	3234	8296	3234	12871	0	6100	0	8296	0	12871	0	8296
	1160	112	0	5750	3059	7820	3059	12133	0	5750	0	7820	0	12133	0	7820
	1460	132	0	5300	2864	7208	2864	11183	0	5300	0	7208	0	11183	0	7208
200	720	107	0	6750	3531	9180	3531	14243	0	6750	0	9180	0	14243	0	9180
	960	131	0	6100	3242	8296	3242	12871	0	6100	0	8296	0	12871	0	8296
	1160	150	0	5750	3072	7820	3072	12133	0	5750	0	7820	0	12133	0	7820
	1460	176	0	5300	2864	7208	2864	11183	0	5300	0	7208	0	11183	0	7208
275	720	147	0	8100	3920	13973	3920	25650	0	8100	0	13973	3920	25650		
	960	180	0	7320	3600	12627	3600	23180	0	7320	0	12627	3600	23180		
	1160	206	0	6900	3410	11903	3410	21850	0	6900	0	11903	3410	21850		
	1460	241	0	6360	3169	10971	3169	20140	0	6360	0	10971	3169	20140		
375	720	201	0	8100	4586	25650	4586	33750	0	8100	0	13973	4586	25650		
	960	246	0	7320	4209	23180	4209	30500	0	7320	0	12627	4209	23180		
	1160	281	0	6900	3979	21850	3979	28750	0	6900	0	11903	3979	21850		
	1460	329	0	6360	3702	20140	3702	26500	0	6360	0	10971	3702	20140		
450	720	207	0	8700	5583	27550	5583	36250	0	8700	0	15008	5583	27550		
	960	295	0	7320	4807	23180	4807	30500	0	7320	0	12627	4807	23180		
	1160	337	0	6900	4545	21850	4545	28750	0	6900	0	11903	4545	21850		
	1460	395	0	6360	4232	20140	4232	26500	0	6360	0	10971	4232	20140		
600	720	275	0	11600	6259	36250	6259	44645	0	11600	0	15008	6259	36250		
	960	367	0	10080	5568	31500	5568	39532	0	10080	0	13041	5568	31500		
	1160	449	0	9200	5109	28750	5109	36263	0	9200	0	11903	5109	28750		
	1460	527	0	8480	4765	26500	4765	33845	0	8480	0	10971	4765	26500		
750	720	344	0	11310	6959	36250	6959	44645	0	11310	0	15008	6259	36250		
	960	491	0	9516	6001	30500	6001	38382	0	9516	0	12627	5404	30500		
	1160	561	0	8970	5674	28750	5674	36263	0	8920	0	11903	5109	28750		
	1460	659	0	8268	5296	26500	5296	33845	0	8268	0	10971	4765	26500		
1000G	720	535	0	10530	8719	33750	8719	43802	0	10530						
	960	654	0	9516	7994	30500	7994	40181	0	9516	CONSULT FACTORY	CONSULT FACTORY			CONSULT FACTORY	
	1160	747	0	8970	7556	28750	7556	37963	0	8920						
	1460	877	0	8268	7048	26500	7048	35432	0	8268						
1000G	720	535	0	10530	8719	33750	8719	43802	0	10530						
	960	654	0	9516	7994	30500	7994	40181	0	9516	CONSULT FACTORY	CONSULT FACTORY			CONSULT FACTORY	
	1160	747	0	8970	7556	28750	7556	37963	0	8920						
	1460	877	0	8268	7048	26500	7048	35432	0	8268						
1000G	720	535	0	10530	8719	33750	8719	43802	0	10530						
	960	654	0	9516	7994	30500	7994	40181	0	9516	CONSULT FACTORY	CONSULT FACTORY			CONSULT FACTORY	
	1160	747	0	8970	7556	28750	7556	37963	0	8920						
	1460	877	0	8268	7048	26500	7048	35432	0	8268						
1000G	720	535	0	10530	8719	33750	8719	43802	0	10530						
	960	654	0	9516	7994	30500	7994	40181	0	9516	CONSULT FACTORY	CONSULT FACTORY			CONSULT FACTORY	
	1160	747	0	8970	7556	28750	7556	37963	0	8920						
	1460	877	0	8268	7048	26500	7048	35432	0	8268						

Please see pages 12, 13 and 14 for all information on Models 1000A, 1200, 1500 and 1800.



COMBINATION DRIVE

In response to the need for utmost reliability, a combination drive may be specified. This drive is normally installed with an electric motor top-mounted for constant service. In the event of power failure or motor failure the drive is simply converted for engine or turbine operation by lowering the integral sliding clutch into drive position. No additional pins or bolts are required for this conversion. These combination drives may be furnished with either solid or hollow shafts. Consult combination drive operation manual for installation instructions.



Combination Clutch—Sub-Assembly
Clutch Shown Disengaged

TABLE OF DIMENSIONS — COMBINATION DRIVE
TABLE 7


Model	D	N	Horizontal Shaft U		AJ	AK	BB	BD	BE	BF	XA	XB	XC	XL	XM	XN	XO	XQ	XR	XS	XT	XAJ	XAK	XBD	XBF	BX Bore Maximum
			Nominal	Actual																						
C20	6 1/2	2 1/4	1 1/4	1.249	3/8 x 3/8	9 1/2	8.250	3/8	10	3/8	10 1/2		3/2	12 1/2	12 1/2	5 1/2	5 1/2	1 1/2	1 1/2	3/8						1"
C40A	8 1/2	4 1/4	1 1/2	1.499	3/8 x 3/8	9 1/2	8.250	3/8	12	3/8	15 1/2		3/2	16 1/2	16	6 1/2	7	3/8	2	3/8						1 1/4"
C40B	8 1/2	4 1/4	1 1/2	1.499	3/8 x 3/8	14 1/2	13.500	3/8	16 1/2	3/8	15 1/2		3/2	16 1/2	16	6 1/2	7	3/8	2	3/8						1 1/4"
C60	11 1/2	4 1/4	1 1/2	1.499	3/8 x 3/8	14 1/2	13.500	3/8	16 1/2	3/8	16 1/2		3/2	20 1/2	18	7 1/2	7 1/2	3/8	2 1/2	3/8						1 1/2"
C80	11 1/2	4 1/4	1 1/2	1.874	3/8 x 3/8	14 1/2	13.500	3/8	16 1/2	3/8	16 1/2		3/2	20 1/2	18	7 1/2	7 1/2	3/8	2 1/2	3/8						1 1/2"
C100	11 1/2	4 1/4	1 1/2	1.874	3/8 x 3/8	14 1/2	13.500	3/8	16 1/2	3/8	16 1/2		3/2	20 1/2	18	7 1/2	7 1/2	3/8	2 1/2	3/8						1 1/2"
C125	11 1/2	4 1/4	2 1/4	2.436	3/8 x 3/8	14 1/2	13.500	3/8	16 1/2	3/8	18 1/2		3/2	21 1/2	18	7 1/2	9	3/8	2 1/2	3/8						1 1/2"
C150	13 1/2	5 1/4	2 1/4	2.436	3/8 x 3/8	18 1/2	13.500	3/8	20	1 1/8	20 1/2	14 1/2	3/2	25 1/2	20	9	10	3/8	2 1/2	3/8						1 1/2"
U200	13 1/2	5 1/4	2 1/4	2.436	3/8 x 3/8	18 1/2	13.500	3/8	20	1 1/8	20 1/2	14 1/2	3/2	25 1/2	20	9	10	3/8	2 1/2	3/8						2
C275	16	6	2 1/4	2.936	3/8 x 3/8	23	13.500	3/8	24 1/2	1 1/8	25 1/2	14 1/2	3/2	32 1/2	27	12	11 1/2	1 1/8	3 1/2	1						2 1/8"
C375	16	6	2 1/4	2.936	3/8 x 3/8	23	13.500	3/8	24 1/2	1 1/8	25 1/2	14 1/2	3/2	32 1/2	27	12	11 1/2	1 1/8	3 1/2	1						2 1/8"
C450	16	6	3 1/4	3.749	3/8 x 3/8	23	13.500	3/8	24 1/2	1 1/8	25 1/2	14 1/2	3/2	32 1/2	27	12	11 1/2	1 1/8	3 1/2	1						2 1/8"
C600	18	6	3 1/4	3.749	3/8 x 3/8	23	13.500	3/8	24 1/2	1 1/8	26 1/2	14 1/2	3/2	34 1/2	27	12 1/2	11 1/2	1 1/8	3 1/2	1 1/4						2 1/8"
C750	21	8	4	3.998	1 x 1/2	28 1/2	22.000	3/8	30 1/2	1 1/8	36 1/2	26 1/2	3/2	42	30	16 1/2	15	1 1/8	4	1 1/4						2 1/8"
C1000G	21	8	4	3.998	1 x 1/2	28 1/2	22.000	3/8	30 1/2	1 1/8	36 1/2	26 1/2	3/2	42	30	16 1/2	15	1 1/8	4	1 1/4						2 1/8"

* Model C20, ratio 1:3, maximum clutch bore 7/8"; Model C150, ratio 1:3, maximum 1 1/8". Consult factory for maximum clutch bore for Fig. 2 and Fig. 3 rotation. Model C20, 1:3 ratio, not available with Fig. 2 or Fig. 3 rotation.

** Horizontal shaft dimensions shown for Model 450 apply to ratios in Table 4 only. Consult factory for dimensions of all others.

† "XA" dimensions shown apply to ratios in Table 4 only. Consult factory for dimensions of all others.

Please see pages 12, 13 and 14 for all information on Models 1000A, 1200, 1500 and 1800.



CUSTOMER NAME East Coast Const Co.
 CUST. ORD. NO. 1217
 U.S. ORD. NO.
 MARK: Camp Lejeune
 QTY. 1 HP 30 FRAME 286 TP PHASE 3
 HERTZ 60 R.P.M. 1800 VOLTS 208



Vertical Motors

Section 505
 Page 1



WPI-TYPE AU
 FRAMES 182 THRU 256TPA

HIGH THRUST
 VERTICAL HOLLOSHAFT
 NEMA P BASE


DIMENSIONS

FEATURES: 30 HP, 1800 rpm, frame 286 TP, 1.15 S.F. continuous duty

Building LCH4006



Conduit opening may be located in steps of 90°. Standard as shown with conduit down.



ALL DIMENSIONS ARE IN INCHES

FRAME	P*	T	AA	AB	AC	AF	AG	AJ DIA.	AK -.003	BB	BD	BE	BF TAP SIZE	BV	CD	XC	XG	UNIMOUNT BRKT. P/N
182TP 184TP	12-7/8	1-1/2	1	6-5/16	5-3/8	2-5/8	21-1/4	9-1/8	8-1/4	3/16	10	3/4	7/16	8	17-9/16	3-11/32	1-1/16	682186
213TP 215TP	12-7/8	1-1/2	1	7-9/16	6-7/16	3-5/16	21-1/4	9-1/8	8-1/4	3/16	10	3/4	7/16	8	17-9/16	3-11/32	1-1/16	682186
254TP 256TP	14	-	1-1/4	8-15/16	7-3/4	3-19/32	26-13/16	9-1/8	8-1/4	1/4	10	15/16	7/16	11-7/16	23-7/16	3-3/8	1-1/4	347107
254TPH 256TPH	14	-	1-1/4	8-15/16	7-3/4	3-19/32	26-13/16	9-1/8	8-1/4	1/4	12	15/16	7/16	11-7/16	23-7/16	3-3/8	1-1/4	347109
254TPA 256TPA	14	-	1-1/4	8-15/16	7-3/4	3-19/32	26-13/16	14-3/4	13-1/2	1/4	16-1/2	15/16	11/16	11-7/16	23-7/16	3-3/8	1-1/4	347111
284TP 286TP	14	-	1-1/2	9-3/16	7-5/8	4-7/16	28-3/16	9-1/8	8-1/4	1/4	10	15/16	7/16	12-1/4	24-13/16	3-3/8	1-1/4	347107
284TPA 286TPA	14	-	1-1/2	9-3/16	7-5/8	4-7/16	28-3/16	9-1/8	8-1/4	1/4	12	15/16	7/16	12-1/4	24-13/16	3-3/8	1-1/4	347109
284TPH 286TPH	14	-	1-1/2	9-3/16	7-5/8	4-7/16	28-3/16	14-3/4	13-1/2	1/4	16-1/2	15/16	11/16	12-1/4	24-13/16	3-3/8	1-1/4	347111

All rough casting dimensions may vary by 1/4" due to casting variations.

* Largest Motor Diameter


TOLERANCES: "AK" Dimension: +.003, Face Runout: .004 F.I.R.
 Permissible Eccentricity of Mounting Rabbet: .004 F.I.R.

All tapped holes are Unified National Course, right hand thread.

EMERSON U. S. ELECTRICAL MOTORS DIVISION
 EMERSON ELECTRIC CO.
 PRINTED IN U.S.A.

Effective: MAY 18, 1980
 Supersedes: FEBRUARY 3, 1980

If properly endorsed this print is correct
 for frame & assembly positions indicated
 By _____ Date _____





Vertical Motors

Section 504
Page 1


3 PHASE 60 CYCLES
230,460,575 VOLTS
40°C. AMBIENT-C.RISE WP-1

HOLLOSHAFT & SOLIDSHAFT
MOTORS
OPERATING CHARACTERISTICS

ENGINEERING DATA

HP	RPM		% EFFICIENCY			% POWER FACTOR			CURRENT IN AMPHERES 460 VOLTS		TORQUE AT FULL VOLTAGE			NEMA CODE
	NO LOAD	FULL LOAD	FULL LOAD	3/4 LOAD	1/2 LOAD	FULL LOAD	3/4 LOAD	1/2 LOAD	FULL LOAD	LOCKED (STARTING)	FULL LOAD TORQUE AT FULL LOAD SPEED (LB.FT.)	LOCKED	PULL OUT	
												(STARTING)	(BREAKDOWN)	
												PERCENT OF FULL LOAD		
2	900	860	75.0	74.5	70.0	68.0	60.0	47.5	3.9	18.0	12.2	130	210	J
	1800	1720	80.0	79.5	75.5	81.0	72.5	59.5	4.4	32.0	9.2	215	250	K
3	1200	1155	78.5	78.0	75.0	69.0	61.0	49.0	5.4	23.0	13.6	155	230	G
	900	860	78.5	79.0	75.5	67.5	59.0	46.0	5.8	30.5	18.3	130	205	K
	3600	3480	81.0	82.0	80.5	86.0	80.5	69.5	6.9	45.0	7.5	150	215	H
5	1800	1725	81.5	82.0	79.5	84.0	76.5	63.5	7.0	47.0	15.2	185	225	J
	1200	1160	81.0	81.0	78.0	71.0	62.5	50.0	8.5	40.0	22.6	150	215	G
	900	875	80.5	80.0	77.0	72.0	64.0	51.0	8.2	44.0	30.0	130	205	H
7-1/2	3600	3460	84.0	85.0	84.0	88.0	84.0	75.5	9.8	63.0	11.4	140	200	H
	1800	1740	83.5	84.0	82.5	84.0	80.0	71.5	10.4	63.5	22.6	175	215	H
	1200	1170	83.0	83.5	81.0	80.5	74.0	61.5	10.5	63.0	33.7	150	205	H
	900	875	80.5	80.5	77.5	71.5	63.0	50.5	12.5	63.0	45.0	125	200	K
10	3600	3500	83.5	84.0	83.0	87.0	84.0	76.5	13.4	79.0	15.0	135	200	H
	1800	1740	86.5	87.0	85.5	81.0	75.0	64.0	13.3	82.0	30.2	165	200	H
	1200	1165	82.5	82.5	80.0	78.5	70.0	57.0	14.0	80.0	45.1	150	200	H
	900	875	86.0	86.5	84.5	72.0	65.0	53.0	15.5	81.0	60.0	125	200	H
15	3600	3485	85.0	86.5	86.0	88.5	87.0	82.0	19.5	112.0	22.6	130	200	G
	1800	1765	85.5	86.5	85.0	81.0	73.5	61.5	20.5	112.0	44.5	160	200	G
	1200	1160	87.5	89.0	89.0	85.0	82.0	74.5	19.4	115.0	68.0	140	200	G
	900	870	86.0	87.5	86.5	75.5	69.5	58.5	22.5	116.0	90.6	125	200	G
20	3600	3515	85.5	87.0	87.0	89.0	87.5	82.5	25.4	145.0	29.9	130	200	G
	1800	1765	88.0	89.0	89.0	85.0	82.5	75.0	26.0	143.0	59.5	150	200	G
	1200	1160	88.0	89.5	89.0	85.0	81.5	74.0	25.8	145.0	90.5	135	200	G
	900	880	85.0	86.5	86.0	74.5	69.0	57.0	30.5	140.0	120.0	125	200	G
25	3600	3510	89.0	90.0	89.0	88.5	87.0	81.0	30.4	172.0	37.4	130	200	F
	1800	1755	88.5	90.0	89.5	83.0	78.5	68.5	32.5	180.0	74.8	150	200	G
	1200	1180	85.5	87.0	86.5	84.0	79.0	68.0	33.5	193.0	111.5	135	200	G
	900	880	86.0	88.0	87.5	77.0	72.0	61.0	36.5	175.0	150.0	125	200	G
30	3600	3510	89.5	90.5	89.5	87.5	85.0	78.0	37.0	218.0	44.9	130	200	G
	1800	1755	89.0	90.0	89.5	80.5	75.0	63.5	40.0	217.0	89.8	150	200	G
	1200	1175	86.5	88.5	89.5	86.0	84.0	78.0	38.5	215.0	134.0	135	200	G
	900	880	88.0	89.5	89.5	75.0	70.0	59.5	43.5	205.0	179.0	125	200	G
40	3600	3515	90.0	91.0	90.0	86.5	83.0	75.0	48.5	310.0	59.8	125	200	G
	1800	1770	88.0	89.5	89.0	86.0	82.0	73.0	51.0	292.5	119.0	140	200	G
	1200	1175	87.5	89.5	90.0	84.5	81.0	72.0	52.0	292.0	179.0	135	200	G
	900	875	88.0	90.0	90.0	76.0	71.5	61.0	57.5	280.0	240.0	125	200	F
50	3600	3540	88.0	89.5	89.0	87.0	84.5	78.0	63.0	350.0	74.2	120	200	G
	1800	1765	89.0	90.5	90.5	84.5	81.0	72.0	64.0	339.5	150.0	140	200	G
	1200	1170	88.0	90.5	91.0	85.0	83.0	76.5	64.0	370.0	224.5	135	200	G
	900	875	88.5	90.0	90.0	80.0	76.0	67.0	68.0	325.0	300.0	125	200	G
60	3600	3540	89.5	91.0	91.0	89.0	89.0	86.0	72.5	410.0	89.0	120	200	G
	1800	1770	90.0	91.0	91.0	86.0	83.0	75.0	75.0	454.5	178.0	140	200	G
	1200	1175	88.5	90.0	89.5	85.5	82.0	72.5	76.0	460.0	268.0	135	200	G
	900	875	89.0	90.5	90.5	80.5	77.0	68.0	80.5	410.0	360.0	125	200	G

See Page 2 for higher horsepowers and notes.



CUSTOMER NAME East Coast Const. Co.
 CUST. ORD. NO. 1217
 U.S. ORD. NO.
 MARK: Camp Lejeune
 QTY. 2 HP 20 FRAME 256 TP PHASE 3
 HERTZ 60 R.P.M. 1800 VOLTS 208



Vertical Motors

Section 505
 Page 1



WPI-TYPE AU
 FRAMES 182 THRU 256TPA

HIGH THRUST
 VERTICAL HOLLOSHAFT
 NEMA P BASE


DIMENSIONS

FEATURES: 20 HP, 1800 rpm, frame 256 TP, 1.15 S.F. continuous duty

Building 611 and 614



Conduit opening may be located in steps of 90°. Standard as shown with conduit down.



ALL DIMENSIONS ARE IN INCHES


FRAME	P*	T	AA	AB	AC	AF	AG	AJ DIA.	AK -.003	BB	BD	BE	BF TAP SIZE	BV	CD	XC	XG	UNIMOUNT BRKT. P/N
182TP 184TP	12-7/8	1-1/2	1	6-5/16	5-3/8	2-5/8	21-1/4	9-1/8	8-1/4	3/16	10	3/4	7/16	8	17-9/16	3-11/32	1-1/16	682186
213TP 215TP	12-7/8	1-1/2	1	7-9/16	6-7/16	3-5/16	21-1/4	9-1/8	8-1/4	3/16	10	3/4	7/16	8	17-9/16	3-11/32	1-1/16	682186
254TP 256TP	14	-	1-1/4	8-15/16	7-3/4	3-19/32	26-13/16	9-1/8	8-1/4	1/4	10	15/16	7/16	11-7/16	23-7/16	3-3/8	1-1/4	347107
254TPH 256TPH	14	-	1-1/4	8-15/16	7-3/4	3-19/32	26-13/16	9-1/8	8-1/4	1/4	12	15/16	7/16	11-7/16	23-7/16	3-3/8	1-1/4	347109
254TPA 256TPA	14	-	1-1/4	8-15/16	7-3/4	3-19/32	26-13/16	14-3/4	13-1/2	1/4	16-1/2	15/16	11/16	11-7/16	23-7/16	3-3/8	1-1/4	347111
284TP 286TP	14	-	1-1/2	9-3/16	7-5/8	4-7/16	28-3/16	9-1/8	8-1/4	1/4	10	15/16	7/16	12-1/4	24-13/16	3-3/8	1-1/4	347107
284TPA 286TPA	14	-	1-1/2	9-3/16	7-5/8	4-7/16	28-3/16	9-1/8	8-1/4	1/4	12	15/16	7/16	12-1/4	24-13/16	3-3/8	1-1/4	347109
284TPH 286TPH	14	-	1-1/2	9-3/16	7-5/8	4-7/16	28-3/16	14-3/4	13-1/2	1/4	16-1/2	15/16	11/16	12-1/4	24-13/16	3-3/8	1-1/4	347111

All rough casting dimensions may vary by 1/4" due to casting variations.

* Largest Motor Diameter

TOLERANCES: "AK" Dimension: +.003, Face Runout: .004 F.I.R.
 Permissible Eccentricity of Mounting Rabbet: .004 F.I.R.

All tapped holes are Unified National Course, right hand thread.



Effective: MAY 18, 1980
 Supersedes: FEBRUARY 3, 1980

If properly endorsed this print is correct
 for frame & assembly positions indicated.
 By _____ Date _____



Vertical Motors

Section 504
Page 1

3 PHASE 60 CYCLES
230,460,575 VOLTS
40°C. AMBIENT-C.RISE WP-1

HOLLOSHAFT & SOLIDSHAFT
MOTORS
OPERATING CHARACTERISTICS

ENGINEERING
DATA

HP	RPM		% EFFICIENCY			% POWER FACTOR			CURRENT IN AMPHERES 460 VOLTS		TORQUE AT FULL VOLTAGE			NEMA CODE
	NO LOAD	FULL LOAD	FULL LOAD	3/4 LOAD	1/2 LOAD	FULL LOAD	3/4 LOAD	1/2 LOAD	FULL LOAD	LOCKED (STARTING)	FULL LOAD TORQUE AT FULL LOAD SPEED (LB.FT.)	LOCKED	PULL OUT	
												(STARTING)	(BREAKDOWN)	
											PERCENT OF FULL LOAD			
2	900	860	75.0	74.5	70.0	68.0	60.0	47.5	3.9	18.0	12.2	130	210	J
	1800	1720	80.0	79.5	75.5	81.0	72.5	59.5	4.4	32.0	9.2	215	250	K
3	1200	1155	78.5	78.0	75.0	69.0	61.0	49.0	5.4	23.0	13.6	155	230	G
	900	860	78.5	79.0	75.5	67.5	59.0	46.0	5.8	30.5	18.3	130	205	K
	3600	3480	81.0	82.0	80.5	86.0	80.5	69.5	6.9	45.0	7.5	150	215	H
5	1800	1725	81.5	82.0	79.5	84.0	76.5	63.5	7.0	47.0	15.2	165	225	J
	1200	1160	81.0	81.0	78.0	71.0	62.5	50.0	8.5	40.0	22.6	150	215	G
	900	875	80.5	80.0	77.0	72.0	64.0	51.0	8.2	44.0	30.0	130	205	H
	3600	3460	84.0	85.0	84.0	88.0	84.0	75.5	9.8	63.0	11.4	140	200	H
7-1/2	1800	1740	83.5	84.0	82.5	84.0	80.0	71.5	10.4	63.5	22.6	175	215	H
	1200	1170	83.0	83.5	81.0	80.5	74.0	61.5	10.5	63.0	33.7	150	205	H
	900	875	80.5	80.5	77.5	71.5	63.0	50.5	12.5	63.0	45.0	125	200	K
	3600	3500	83.5	84.0	83.0	87.0	84.0	76.5	13.4	79.0	15.0	135	200	H
10	1800	1740	86.5	87.0	85.5	81.0	75.0	64.0	13.3	82.0	30.2	165	200	H
	1200	1165	82.5	82.5	80.0	78.5	70.0	57.0	14.0	80.0	45.1	150	200	H
	900	875	86.0	86.5	84.5	72.0	65.0	53.0	15.5	81.0	60.0	125	200	H
	3600	3485	85.0	86.5	86.0	88.5	87.0	82.0	19.5	112.0	22.6	130	200	G
15	1800	1765	85.5	86.5	85.0	81.0	73.5	61.5	20.5	112.0	44.5	160	200	G
	1200	1160	87.5	89.0	89.0	85.0	82.0	74.5	19.4	115.0	68.0	140	200	G
	900	870	86.0	87.5	86.5	75.5	69.5	58.5	22.5	116.0	90.6	125	200	G
	3600	3515	85.5	87.0	87.0	89.0	87.5	82.5	25.4	145.0	29.9	130	200	G
20	1800	1765	88.0	89.0	89.0	85.0	82.5	75.0	26.0	143.0	59.5	150	200	G
	1200	1160	88.0	89.5	89.0	85.0	81.5	74.0	25.8	145.0	90.5	135	200	G
	900	880	85.0	86.5	86.0	74.5	69.0	57.0	30.5	140.0	120.0	125	200	G
	3600	3510	89.0	90.0	89.0	88.5	87.0	81.0	30.4	172.0	37.4	130	200	F
25	1800	1755	88.5	90.0	89.5	83.0	78.5	68.5	32.5	180.0	74.8	150	200	G
	1200	1180	85.5	87.0	86.5	84.0	79.0	68.0	33.5	193.0	111.5	135	200	G
	900	880	86.0	88.0	87.5	77.0	72.0	61.0	36.5	175.0	150.0	125	200	G
	3600	3510	89.5	90.5	89.5	87.5	85.0	78.0	37.0	218.0	44.9	130	200	G
30	1800	1755	89.0	90.0	89.5	80.5	75.0	63.5	40.0	217.0	89.8	150	200	G
	1200	1175	86.5	88.5	89.5	86.0	84.0	78.0	38.5	215.0	134.0	135	200	G
	900	880	88.0	89.5	89.5	75.0	70.0	59.5	43.5	205.0	179.0	125	200	G
	3600	3515	90.0	91.0	90.0	86.5	83.0	75.0	48.5	310.0	59.8	125	200	G
40	1800	1770	88.0	89.5	89.0	86.0	82.0	73.0	51.0	292.5	119.0	140	200	G
	1200	1175	87.5	89.5	90.0	84.5	81.0	72.0	52.0	292.0	179.0	135	200	G
	900	875	88.0	90.0	90.0	76.0	71.5	61.0	57.5	280.0	240.0	125	200	F
	3600	3540	88.0	89.5	89.0	87.0	84.5	78.0	63.0	350.0	74.2	120	200	G
50	1800	1765	89.0	90.5	90.5	84.5	81.0	72.0	64.0	339.5	150.0	140	200	G
	1200	1170	88.0	90.5	91.0	85.0	83.0	76.5	64.0	370.0	224.5	135	200	G
	900	875	88.5	90.0	90.0	80.0	76.0	67.0	68.0	325.0	300.0	125	200	G
	3600	3540	89.5	91.0	91.0	89.0	89.0	86.0	72.5	410.0	89.0	120	200	G
60	1800	1770	90.0	91.0	91.0	86.0	83.0	75.0	75.0	454.5	178.0	140	200	G
	1200	1175	88.5	90.0	89.5	85.5	82.0	72.5	76.0	460.0	268.0	135	200	G
	900	875	89.0	90.5	90.5	80.5	77.0	68.0	80.5	410.0	360.0	125	200	G

See Page 2 for higher horsepowers and notes.

CUSTOMER NAME East Coast Const. Co.
 CUST. ORD. NO. 1217
 U.S. ORD. NO.
 MARK: Camp Lefeune
 QTY. 1 HP 25 FRAME 284 TP PHASE 3
 HERTZ 60 R.P.M. 1800 VOLTS 208



Vertical Motors

Section 505
 Page 1



WPI-TYPE AU
 FRAMES 182 THRU 256TPA

HIGH THRUST
 VERTICAL HOLLOSHAFT
 NEMA P BASE


DIMENSIONS

FEATURES: 25 HP, 1800 rpm, frame 284 TP, 1.15 S.F. continuous duty

Building 227



Conduit opening may be located in steps of 90°. Standard as shown with conduit down.



ALL DIMENSIONS ARE IN INCHES


FRAME	P*	T	AA	AB	AC	AF	AG	AJ DIA.	AK -.003	BB	BD	BE	BF TAP SIZE	BV	CD	XC	XG	UNIMOUNT BRKT. P/N
182TP 184TP	12-7/8	1-1/2	1	6-5/16	5-3/8	2-5/8	21-1/4	9-1/8	8-1/4	3/16	10	3/4	7/16	8	17-9/16	3-11/32	1-1/16	682186
213TP 215TP	12-7/8	1-1/2	1	7-9/16	6-7/16	3-5/16	21-1/4	9-1/8	8-1/4	3/16	10	3/4	7/16	8	17-9/16	3-11/32	1-1/16	682186
254TP 256TP	14	-	1-1/4	8-15/16	7-3/4	3-19/32	26-13/16	9-1/8	8-1/4	1/4	10	15/16	7/16	11-7/16	23-7/16	3-3/8	1-1/4	347107
254TPH 256TPH	14	-	1-1/4	8-15/16	7-3/4	3-19/32	26-13/16	9-1/8	8-1/4	1/4	12	15/16	7/16	11-7/16	23-7/16	3-3/8	1-1/4	347109
254TPA 256TPA	14	-	1-1/4	8-15/16	7-3/4	3-19/32	26-13/16	14-3/4	13-1/2	1/4	16-1/2	15/16	11/16	11-7/16	23-7/16	3-3/8	1-1/4	347111
284TP 286TP	14	-	1-1/2	9-3/16	7-5/8	4-7/16	28-3/16	9-1/8	8-1/4	1/4	10	15/16	7/16	12-1/4	24-13/16	3-3/8	1-1/4	347107
284TPA 286TPA	14	-	1-1/2	9-3/16	7-5/8	4-7/16	28-3/16	9-1/8	8-1/4	1/4	12	15/16	7/16	12-1/4	24-13/16	3-3/8	1-1/4	347109
284TPH 286TPH	14	-	1-1/2	9-3/16	7-5/8	4-7/16	28-3/16	14-3/4	13-1/2	1/4	16-1/2	15/16	11/16	12-1/4	24-13/16	3-3/8	1-1/4	347111

All rough casting dimensions may vary by 1/4" due to casting variations.

TOLERANCES: "AK" Dimension: +.003, Face Runout: .004 F.I.R.
 Permissible Eccentricity of Mounting Rabbet: .004 F.I.R.


* Largest Motor Diameter

All tapped holes are Unified National Course, right hand thread.



Effective: MAY 18, 1980
 Supersedes: FEBRUARY 3, 1980

If properly endorsed this print is correct
 for frame & assembly positions indicated
 By _____ Date _____





Vertical Motors

Section 504

Page 1


**3 PHASE 60 CYCLES
230,460,575 VOLTS
40°C. AMBIENT-C.RISE WP-1**

**HOLLOSHAFT & SOLIDSHAFT
MOTORS
OPERATING CHARACTERISTICS**

**ENGINEERING
DATA**

HP	RPM		% EFFICIENCY			% POWER FACTOR			CURRENT IN AMPHERES 460 VOLTS		TORQUE AT FULL VOLTAGE			NEMA CODE
	NO LOAD	FULL LOAD	FULL LOAD	3/4 LOAD	1/2 LOAD	FULL LOAD	3/4 LOAD	1/2 LOAD	FULL LOAD	LOCKED (STARTING)	FULL LOAD TORQUE AT FULL LOAD SPEED (LB.FT.)	LOCKED	PULL OUT	
												(STARTING) PERCENT OF FULL LOAD	(BREAKDOWN)	
2	900	860	75.0	74.5	70.0	68.0	60.0	47.5	3.9	18.0	12.2	130	210	J
	1800	1720	80.0	79.5	75.5	81.0	72.5	59.5	4.4	32.0	9.2	215	250	K
3	1200	1155	78.5	78.0	75.0	69.0	61.0	49.0	5.4	23.0	13.6	155	230	G
	900	860	78.5	79.0	75.5	67.5	59.0	46.0	5.8	30.5	18.3	130	205	K
	3600	3480	81.0	82.0	80.5	86.0	80.5	69.5	6.9	45.0	7.5	150	215	H
5	1800	1725	81.5	82.0	79.5	84.0	76.5	63.5	7.0	47.0	15.2	185	225	J
	1200	1160	81.0	81.0	78.0	71.0	62.5	50.0	8.5	40.0	22.8	150	215	G
	900	875	80.5	80.0	77.0	72.0	64.0	51.0	8.2	44.0	30.0	130	205	H
	3600	3460	84.0	85.0	84.0	88.0	84.0	75.5	9.8	63.0	11.4	140	200	H
7-1/2	1800	1740	83.5	84.0	82.5	84.0	80.0	71.5	10.4	63.5	22.6	175	215	H
	1200	1170	83.0	83.5	81.0	80.5	74.0	61.5	10.5	63.0	33.7	150	205	H
	900	875	80.5	80.5	77.5	71.5	63.0	50.5	12.5	63.0	45.0	125	200	K
	3600	3500	83.5	84.0	83.0	87.0	84.0	76.5	13.4	79.0	15.0	135	200	H
10	1800	1740	86.5	87.0	85.5	81.0	75.0	64.0	13.3	82.0	30.2	165	200	H
	1200	1165	82.5	82.5	80.0	78.5	70.0	57.0	14.0	80.0	45.1	150	200	H
	900	875	86.0	86.5	84.5	72.0	65.0	53.0	15.5	81.0	60.0	125	200	H
	3600	3485	85.0	86.5	86.0	88.5	87.0	82.0	19.5	112.0	22.6	130	200	G
15	1800	1765	85.5	86.5	85.0	81.0	73.5	61.5	20.5	112.0	44.5	160	200	G
	1200	1160	87.5	89.0	89.0	85.0	82.0	74.5	19.4	115.0	68.0	140	200	G
	900	870	86.0	87.5	86.5	75.5	69.5	58.5	22.5	116.0	90.6	125	200	G
	3600	3515	85.5	87.0	87.0	89.0	87.5	82.5	25.4	145.0	29.9	130	200	G
20	1800	1765	88.0	89.0	89.0	85.0	82.5	75.0	26.0	143.0	59.5	150	200	G
	1200	1160	88.0	89.5	89.0	85.0	81.5	74.0	25.8	145.0	90.5	135	200	G
	900	880	85.0	86.5	86.0	74.5	69.0	57.0	30.5	140.0	120.0	125	200	G
	3600	3510	89.0	90.0	89.0	88.5	87.0	81.0	30.4	172.0	37.4	130	200	F
25	1800	1755	88.5	90.0	89.5	83.0	78.5	68.5	32.5	180.0	74.8	150	200	G
	1200	1180	85.5	87.0	86.5	84.0	79.0	68.0	33.5	193.0	111.5	135	200	G
	900	880	86.0	88.0	87.5	77.0	72.0	61.0	36.5	175.0	150.0	125	200	G
	3600	3510	89.5	90.5	89.5	87.5	85.0	78.0	37.0	218.0	44.9	130	200	G
30	1800	1755	89.0	90.0	89.5	80.5	75.0	63.5	40.0	217.0	89.8	150	200	G
	1200	1175	86.5	88.5	89.5	86.0	84.0	78.0	38.5	215.0	134.0	135	200	G
	900	880	88.0	89.5	89.5	75.0	70.0	59.5	43.5	205.0	179.0	125	200	G
	3600	3515	90.0	91.0	90.0	86.5	83.0	75.0	48.5	310.0	59.8	125	200	G
40	1800	1770	88.0	89.5	89.0	86.0	82.0	73.0	51.0	292.5	119.0	140	200	G
	1200	1175	87.5	89.5	90.0	84.5	81.0	72.0	52.0	292.0	179.0	135	200	G
	900	875	88.0	90.0	90.0	76.0	71.5	61.0	57.5	280.0	240.0	125	200	F
	3600	3540	88.0	89.5	89.0	87.0	84.5	78.0	63.0	350.0	74.2	120	200	G
50	1800	1765	89.0	90.5	90.5	87.0	81.0	72.0	64.0	339.5	150.0	140	200	G
	1200	1170	88.0	90.5	91.0	85.0	83.0	76.5	64.0	370.0	224.5	135	200	G
	900	875	88.5	90.0	90.0	80.0	76.0	67.0	68.0	325.0	300.0	125	200	G
	3600	3540	89.5	91.0	91.0	89.0	89.0	86.0	72.5	410.0	89.0	120	200	G
60	1800	1770	90.0	91.0	91.0	86.0	83.0	75.0	75.0	454.5	178.0	140	200	G
	1200	1175	88.5	90.0	89.5	85.5	82.0	72.5	76.0	460.0	268.0	135	200	G
	900	875	89.0	90.5	90.5	80.5	77.0	68.0	80.5	410.0	360.0	125	200	G

See Page 2 for higher horsepowers and notes.



CUSTOMER NAME EAST COAST CONST. CO.
 CUST. ORD. NO. 1217
 U.S. ORD. NO.
 MAKE: CAMP LEJUNE
 QTY. 8 HP 15 FRAME 254 TCV PHASE 3
 HERTZ 60 R.P.M. 1800 VOLTS 208



Vertical Motors



Section 505
 Page 51

OPEN DRIPPROOF TYPE AV
 FRAMES 182TC THRU 286TCV

NORMAL THRUST:
 VERTICAL SOLID-SHAFT
 NEMA C BASE

DIMENSIONS

FEATURES: 15 HP, 1800 RPM, Frame 254TCV 1.15 SF²
 Continuous Duty



Conduit opening may be located in steps of 90 deg. Standard as shown with conduit down.


ALL DIMENSIONS ARE IN INCHES

FRAME	C	P*	U	V MIN.	AA	AB	AC	AF	AG	AH	AJ DIA.
182,184 TC	17-3/8	9-1/2	1-1/8	2-1/2	3/4	6-5/16	5-3/8	2-5/8	15-1/8	2-5/8	7-1/4
213,218 TCV	22-7/32	11-1/8	1-3/8	3-1/8	1	7-1/2	6-7/16	3-5/16	19-3/32	3-1/8	7-1/4
254,258 TCV	24-1/16	14	1-5/8	3-3/4	1-1/4	8-15/16	7-3/4	3-5/8	20-5/16	3-3/4	7-1/4
284,288 TCV	28-3/16	14	1-7/8	4-3/8	1-1/2	9-1/8	7-9/16	4-7/16	21-11/16	4-1/2	9
284,288 TCV	28-3/16	14	1-7/8	4-3/8	1-1/2	9-1/8	7-9/16	4-7/16	21-11/16	4-1/2	9

FRAME	AK	BB MIN.	BC	BD	BF - TAP	BV	XO	SQ. KEY	BASIC BRACKET PART NUMBER
182,184 TC	8-1/2	1/4	1/8	9	1/2-13 X 3/4	6-3/8	11-3/16	1/4 X 1-3/4	168101
213,218 TCV	8-1/2	1/4	1/8	9	1/2-13 X 3/4	8	12-3/4	5/16 X 2-3/8	168737
254,258 TCV	8-1/2	1/4	1/8	8-1/2	1/2-13 X 3/4	11-7/16	16-7/8	3/8 X 2-15/16	347101
284,288 TCV	10-1/2	1/4	1/8	10-1/2	1/2-13 X 3/4	12-1/4	16-7/8	1/2 X 3-5/16	347103
284,288 TCV	10-1/2	1/4	1/8	12-1/2	1/2-13 X 3/4	12-1/4	16-7/8	1/2 X 3-5/16	347108


All rough casting dimensions may vary by 1/4" due to casting variations.
 All tapped holes are Unified National Course, right hand thread.
 *Largest Motor Diameter

TOLERANCES:
 Face runout: .004 F.I.R.
 Shaft Extension Diameter: 1-1/8" thru 1-1/2" "U" Dia.: +.0000", -.0008"
 1-5/8" "U" Dia.: +.000", -.001"
 Permissible Eccentricity of Mounting Rabbet: .004" F.I.R.
 Permissible Shaft Runout: .002" F.I.R.
 "AK" Dimension +.000"; -.003"



Effective: JUNE 18, 1968
 Supersedes: MAY 22, 1979

If properly endorsed this print is correct
 for frame & assembly position indicated.
 By WRS Date 11/2/82





Vertical Motors

Section 504

Page 1


3 PHASE 60 CYCLES
208 VOLTS
40°C. AMBIENT-C.RISE WP-1

HOLLOSHAFT & SOLIDSHAFT
MOTORS
OPERATING CHARACTERISTICS

ENGINEERING DATA

HP	RPM		% EFFICIENCY			% POWER FACTOR			CURRENT IN AMPHERES 480 VOLTS		TORQUE AT FULL VOLTAGE			NEMA CODE
	NO LOAD	FULL LOAD	FULL LOAD	3/4 LOAD	1/2 LOAD	FULL LOAD	3/4 LOAD	1/2 LOAD	FULL LOAD	LOCKED (STARTING)	FULL LOAD TORQUE AT FULL LOAD SPEED (L.B.F.T.)	LOCKED (STARTING) (BREAKDOWN) PERCENT OF FULL LOAD		
												LOCKED	PULL OUT	
2	900	880	75.0	74.5	70.0	88.0	80.0	47.5	3.9	18.0	12.2	130	210	J
	1800	1720	80.0	79.5	75.5	81.0	72.5	59.5	4.4	32.0	9.2	215	250	K
3	1200	1155	78.5	78.0	75.0	89.0	81.0	49.0	5.4	23.0	13.8	155	230	G
	900	880	78.5	78.0	75.5	87.5	79.0	46.0	5.8	30.5	18.3	139	205	K
	1800	1725	81.0	82.0	80.5	89.0	80.5	69.5	6.9	45.0	7.8	160	215	H
5	1800	1725	81.5	82.0	79.5	84.5	78.5	63.5	7.0	47.0	15.2	185	225	J
	1200	1160	81.0	81.0	78.0	71.0	62.5	50.0	8.5	40.0	22.8	190	215	G
	900	875	80.5	80.0	77.0	72.0	64.0	51.0	8.2	44.0	30.0	130	205	H
7-1/2	3600	3460	84.0	85.0	84.0	88.0	84.0	75.5	9.8	63.0	11.4	140	200	H
	1800	1740	83.5	84.0	82.5	84.0	80.0	71.5	10.4	63.5	22.8	175	215	H
	1200	1170	83.0	83.5	81.0	80.5	74.0	61.5	10.8	63.0	33.7	150	205	H
	900	875	80.5	80.5	77.5	71.5	63.0	50.5	12.5	63.0	45.0	125	200	K
10	3600	3500	83.5	84.0	83.0	87.0	84.0	78.5	13.4	79.0	15.0	135	200	H
	1800	1740	86.5	87.0	85.5	81.0	75.0	64.0	13.3	82.0	30.2	165	200	H
	1200	1165	82.5	82.5	80.0	78.5	70.0	57.0	14.0	80.0	48.1	150	200	H
	900	875	88.0	88.5	84.5	72.0	65.0	53.0	15.5	81.0	60.0	125	200	H
15	3600	3485	85.0	86.5	86.0	88.5	87.0	82.0	19.5	112.0	22.6	130	200	G
	1800	1795	89.5	89.5	88.5	81.0	73.5	61.5	20.8	112.0	44.5	165	200	G
	1200	1180	87.5	89.0	89.0	85.0	82.0	74.5	18.4	115.0	68.0	140	200	G
	900	870	86.0	87.5	86.5	75.5	69.5	58.5	22.5	118.0	90.6	125	200	G
20	3600	3515	85.5	87.0	87.0	88.0	87.5	82.5	26.4	148.0	29.9	130	200	G
	1800	1765	88.0	88.0	88.0	85.0	82.5	75.0	28.0	143.0	58.5	150	200	G
	1200	1180	88.0	89.5	89.0	85.0	81.5	74.0	25.8	145.0	90.5	135	200	G
	900	880	85.0	86.5	86.0	74.5	69.0	57.0	30.5	140.0	120.0	125	200	G
25	3600	3510	89.0	90.0	89.0	88.5	87.0	81.0	30.4	172.0	37.4	130	200	F
	1800	1755	88.5	90.0	89.5	83.0	78.5	68.5	32.5	180.0	74.8	150	200	G
	1200	1180	85.5	87.0	86.5	84.0	79.0	68.0	33.5	193.0	111.5	135	200	G
	900	880	86.0	88.0	87.5	77.0	72.0	61.0	38.5	175.0	150.0	125	200	G
30	3600	3510	89.5	90.5	89.5	87.5	85.0	78.0	37.0	218.0	44.9	130	200	G
	1800	1755	89.0	90.0	89.5	80.5	75.0	63.5	40.0	217.0	89.8	150	200	G
	1200	1175	88.5	89.5	89.5	86.0	84.0	78.0	38.5	218.0	134.0	135	200	G
	900	880	88.0	89.5	89.5	75.0	70.0	59.5	43.5	205.0	179.0	125	200	G
40	3600	3515	90.0	91.0	90.0	88.5	83.0	75.0	48.5	310.0	59.8	125	200	G
	1800	1770	89.0	89.5	89.0	86.0	82.0	73.0	51.0	292.5	118.0	140	200	G
	1200	1175	87.5	88.5	90.0	84.5	81.0	72.0	52.0	292.0	178.0	135	200	G
	900	875	88.0	90.0	90.0	78.0	71.5	61.0	57.5	280.0	240.0	125	200	F
60	3600	3540	88.0	88.5	88.0	87.0	84.5	78.0	63.0	350.0	74.2	120	200	G
	1800	1765	88.0	90.5	90.5	84.5	81.0	72.0	64.0	339.5	150.0	140	200	G
	1200	1175	88.0	90.5	91.0	86.0	83.0	78.5	64.0	370.0	224.5	135	200	G
	900	875	88.5	90.0	90.0	80.0	78.0	67.0	68.0	325.0	300.0	125	200	G
60	3600	3540	89.5	91.0	91.0	89.0	89.0	88.0	72.5	410.0	88.0	120	200	G
	1800	1770	90.0	91.0	91.0	86.0	83.0	75.0	75.0	454.5	178.0	140	200	G
	1200	1175	88.5	90.0	89.5	86.5	82.0	72.5	76.0	400.0	268.0	135	200	G
900	875	89.0	90.5	90.5	80.5	77.0	68.0	80.5	410.0	390.0	125	200	G	

See Page 2 for higher horsepowers and notes.



U. S. ELECTRICAL MOTORS DIVISION
EMERSON ELECTRIC CO.

Effective: NOVEMBER 18, 1979
Supersedes: NOVEMBER 13, 1970

REFER TO COMPANY FOR CERTIFIED VALUES



1
2
3
4
5

FILE FOLDER

DESCRIPTION ON TAB:

Well # L6L3


Outside/inside of actual folder did not contain hand written information

Outside/inside of actual folder did contain hand written information

***Scanned as next image**


~~663~~

663



DATE 7-25-00
PWSID 04-67-041

WELL # HP663
WELL NAME HADNOT POINT HP20
BLDG. HP663
CODE G
AVAILABILITY P.
LOCATION D-LINE ROAD
LATITUDE 34.7071
LONGITUDE 77.30004
WELL DIAMETER 10"
WELL DEPTH 300
SCREEN INTERVAL _____
YIELD 210
STATIC LEVEL 18'
PUMPING LEVEL 80'
PUMP TYPE VERTICAL TURBINE
MOTOR HP 20
INTAKE DEPTH 95
DESIGN CAPACITY 300
ACTUAL GPM 300
SIZE OF CONCRETE SLAB 10X10
HEIGHT OF CASING 18"



SOURCE INFORMATION GROUND WATER

Date Form Completed

M M D D Y Y
0 1 2 5 9 5

PWSID
0467041

Owner Assigned
Source Code

Well Name (If purchase, name of system)

663

HADNOT POINT 663

Code

G

G=Ground
W=Purchase/G
Y=G w/direct influence
Z=W w/direct influence

If Purchase, seller ID#

Source Begin Date

Source exempt—
SWTR?

Direct Influence Date

Availability

Y
 N

P

P=Permanent
E=Emergency
S=Seasonal
I=Interim
O=Other

Location of well within the system (If purchase, location of master meter)

D-LINE ROAD

Latitude (N)

Longitude (W)

How Determined

GPS Data

No. of Sats. Locked on

3 4 4 2 2 5 9

0 7 7 1 8 0 0 2

G

G=GPS
M=Map
S=Surveyed

4 2

Q# or
DOP #

5

(If purchase, use seller's primary source lat/long)

Vulnerable (VOCs)

Y
 N

Assessment Date

ENTRY POINT INFORMATION

Use Code

Availability

Owner Assigned
Entry Point Code

C
C=Ground/Permanent
D=Ground/non-permanent

P
P=Year-round
E=Emergency
S=Seasonal
I=Interim
O=Other

100

Entry Point Name

HADNOT POINT WTP

Location:

Well Site: Owned or controlled? Y (Y,N) Control Area (100' radius)? Y (Y,N) If no, explain: _____

Sources of pollution/distance: none - woods

Surface water within 200'? Y N If yes, actual distance feet If yes, bact. samples collected? (Y,N)

Adequate slope? Y (Y,N) Flooding? N (Y,N) Maintenance: OK

Well House: Free of stored materials? Y (Y,N) Properly drained? Y (Y,N) Locked? Y (Y,N)

Condition of house: OK Type of freeze protection: Elec Heat

Well: Diameter: 10" Type: SCREENED Yield (gpm): 210 Properly sealed? Y (Y,N)

Properly vented? Y (Y,N) Casing depth 50 ft. (If unknown, put 'UNK') Well depth: 300 Meter available? Y (Y,N)

Concrete slab adequate? (Y,N) If no, explain: _____ Size: 10X10

Size of blow-off: 4" (N) Sample tap: Before treatment? Y (Y,N) After treatment? (Y,N)

Pumps: Capacity: GPM: 300 180 HP: 20 Pump intake depth: 95 Auxiliary Power? Y (Y,N)

Type pump: VERTICAL TURBINE Height above floor (pump/casing): 18"

Storage at well site: Elev: Hydro: Ground:

If hydroautomatic, air volume control? (Y,N) Safety valves? (Y,N) Coded? (Y,N)


High service pumps: 1. gpm hp 2. gpm hp 3. gpm hp Auxiliary Power? (Y,N)


Is the water treated at this well? Y N If yes, complete back of form.


If other wells are treated here, which ones? _____ If treated elsewhere, where? HP 20 PLANT




If purchase, retreat? Y N If yes, complete back of form.


① Repair vent
② seal pump pedestal











CAMP LEJEUNE No. 14 WELL

DEMING PUMP CO.

SALEM, OHIO, U.S.A.


240 HARRY PEPPER & ASSOC. S.O. 11635-21 P.O. C642-0001

CHARACTERISTIC CURVES

FIG. 4700 SIZE M 8 STAGES 7 IMPELLER 22665

DESIGNED RATING: G.P.M. 260 HEAD 160 R.P.M. 1770

OTHER CURVE POINTS AND GENERAL SHAPE OF CURVES ARE APPROXIMATE



GUARANTEED MIN. EFF. AT DESIGN POINT 71%

FOR APPROVAL FABRICATION PENDING

SERIAL NO. ****

U. S. GALLONS PER MINUTE

DATE 2-25-85

IMP. DIA. 5 1/2"



NO. Q23631

FOR APPLICATION BIDDING


NOV 1994 907

_____ H.P.
 _____ R.P.M.
 _____ MOTOR
 _____ FRAME

6" DISCHARGE
 8 - 3/4" CAPSCREWS ON
 9 1/2" BOLT CIRCLE




4 - 7/8" DRILLED HOLES



PLAN VIEW

4 7/8" FOUNDATION HOLES



PLAN VIEW FOR SUPPORT PLATE

FOR APPROVAL
 FABRICATION PENDING

7 STAGES

5 SUCTION PIPE
5 STRAINER

CAMP LEJEUNE
 NO. 14 WELL

T-82526

HARRY PEPPER & ASSOC. INC. S.O. 1635-21 P.O. C642-0001

DATE OF ISSUE	
2/25/85	
DESTROY ALL PREVIOUS PRINTS	
FIG. 4700	SIZE M8
DRAWING NO. 115-027	

THE DEMING CO. SALEM, OHIO	TITLE DIMENSION SHEET
HB	DATE 5-28-58
	SCALE -

FOR APPROVAL
FABRICATION PENDING

Hunt

CONTRACTOR'S SUBMITTAL TRANSMITTAL
LANTDIV NORFOLK 4-4355/3 (Rev. 11-80)

CONTRACT NO 81-C-1644	TRANSMITTAL NO 204	DATE 5-15-86
---------------------------------	------------------------------	------------------------

FROM CONTRACTOR
Harry Pepper & Associates, Inc.

TO
Henry Von Oesen & Associates, Inc.

PROJECT TITLE AND LOCATION
Holcomb Blvd Water Treatment Plant

MCB, Cp Lejeune, North Carolina

CONTRACTOR USE ONLY

REVIEWER USE ONLY

List only one specification division per form.

****ACTION CODES**

List only one of the following categories on each transmittal form, and indicate which is being submitted

- A-Approved
- D-Disapproved
- AN-Approved as noted
- RA-Receipt acknowledged.
- C-Comments
- R-Resubmit

- Contractor Approved OICC Approval Deviation/Substitution For OICC Approval

ITEM NO	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO. *	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES **	REVIEWER'S INITIALS CODE AND DATE
	02734	ROTARY DRILLED WATER WELLS WELL #14			
1	3.1.6	24 Hour Pump Test	7	A	JRB
2	3.1.6	2 Hour Recovery Test	7	A	JRB

CONTRACTOR'S COMMENTS

Contractor was advised by Title II Inspector to do pump test at 350 GPM.

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC
ONE COPY TO ROICC

CONTRACTOR REPRESENTATIVE (Signature)
Phil Reese *Phil Reese*

DATE RECEIVED BY REVIEWER: **5/20/86**

FROM (Reviewer): **Henry von Oesen & Assoc., Inc.**

TO:

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on **ONE COPY** of the transmittal form.

REVIEWER'S COMMENTS

COPIES TO ROICC (2), LANTDIV (1), A-E (1)

DATE: **5/23/86** (Stamp: 55 MAY 23 1986)

SIGNATURE: *[Signature]*

RENEWER USE ONLY

CONTRACTOR USE ONLY

RENEWAL DATE
RENEWAL MONTH
RENEWAL YEAR
RENEWAL DAY

CONTRACTOR USE ONLY
CONTRACTOR NAME
CONTRACTOR ADDRESS
CONTRACTOR CITY
CONTRACTOR STATE
CONTRACTOR ZIP

RENEWAL DATE
RENEWAL MONTH
RENEWAL YEAR
RENEWAL DAY

CONTRACTOR USE ONLY
CONTRACTOR NAME
CONTRACTOR ADDRESS
CONTRACTOR CITY
CONTRACTOR STATE
CONTRACTOR ZIP

CONTRACTOR USE ONLY
CONTRACTOR NAME
CONTRACTOR ADDRESS
CONTRACTOR CITY
CONTRACTOR STATE
CONTRACTOR ZIP

[Handwritten signature]

22 MAY 1988 23 53

24 HOUR PUMP TEST
WELL # 14

PUMPING RATE 350 GPM

ITEM # 1

TIME	PUMP SETTING 126'	STATIC 16'8"
	PUMPING LEVEL	DRAWDOWN
11:01	63'10	47'2
11:02	65'11	2'1
11:03	67'8	1'9
11:04	69'5	1'9
11:05	70'6	11''
11:06	71'3	9''
11:07	71'11	8''
11:08	72'8	9''
11:09	73'4	8''
11:10	73'10	6''
11:15	75'7	9''
11:20	75'11	4''
11:25	76'3	"
11:30	76'7	"
11:35	77'1	6''
11:40	77'6	5''
11:45	78'	6''
11:50	78'4	4''
11:55	78'9	5''
12:00	79'2	5''
1:00	80'4	1'2''
2:00	81'1	9''
3:00	81'11	10''
4:00	82'8	9''
5:00	83'6	10''
6:00	84'1	7''
7:00	84'7	6''
8:00	85'3	8''
9:00	85'11	"
10:00	86'7	"
11:00	87'2	7''
12:00	87'6	4''
1:00	87'11	5'
2:00	88'2	3''
3:00	88'5	3''
4:00	88'10	5''
5:00	89'1	3''
6:00	89'3	2''
7:00	89'3	-
8:00	89'6	3''
9:00	89'8	2''
10:00	89'11	3''
11:00	90'1	2''

ATLANTIC DIVISION
NAVAL FACILITIES ENGINEERING COMMAND
NORFOLK, VIRGINIA 23511

APPROVED _____
 APPROVED AS NOTED _____
 DISAPPROVED _____

SUBJECT TO THE REQUIREMENTS OF
 CONTRACT NO. N62470-81-C-1644
 APPROVAL OF A SUBMITTAL DOES NOT INCLUDE
 APPROVAL OF ANY DEVIATION FROM THE CON-
 TRACT REQUIREMENTS UNLESS THE CONTRAC-
 TOR CALLS ATTENTION TO IT. CONTRACTOR SUPPORTS THE
 DEVIATION --- THE CONTRACTOR SHALL BE RES-
 PONSIBLE FOR PROVIDING PROPER PHYSICAL
 DIMENSIONS & WEIGHTS, COORDINATION OF
 TRADES, ETC., AS REQUIRED.


REVIEWER *[Signature]* DATE MAY 22 1986

FOR OFFICER IN CHARGE OF CONSTRUCTION

I hereby certify that the (material) (equipment) shown and
 marked in this submittal, shop drawings, catalog cut (s), etc., and
 approved/proposed to be incorporated into Contract Number
 N62470-81-C-1644 is in compliance with the Contract Drawings
 and Specifications and can be installed in the allocated space,
 and is:

Approved for use.
 Submitted for Government approval.
 Approved for use subject to Government approval of
 specific deviation.


Authorized Reviewer _____ DATE _____
 Signature CQC Rep. *[Signature]* DATE 5-15-86



TWO HOUR RECOVERY
WELL # 14

ITEM # 2

11:01	47'3
11:02	39'1
11:03	36'11
11:04	32'9
11:05	30'5
11:06	29'2
11:07	27'10
11:08	25'3
11:09	24'6
11:10	22'9
11:15	21'1
11:20	20'
11:25	18'5
11:30	17'11
11:35	17'1
11:40	16'10
11:45	16'8"
11:50	"
11:55	"
12:00	"
1:00	"



4 sent

CONTRACTOR'S SUBMITTAL TRANSMITTAL
LANTDIV NORFOLK 4-4355/3 (Rev. 11-80)

CONTRACT NO 81-C-1644	TRANSMITTAL NO 185	DATE 3-19-86
PROJECT TITLE AND LOCATION Holcomb Blvd Water Treatment Plant		
MCB, Cp Lejeune, North Carolina		

FROM CONTRACTOR
Harry Pepper & Associates, Inc.

TO
Henry Von Oesen & Associates, Inc.

<p align="center">CONTRACTOR USE ONLY</p> <p align="center">*List only one specification division per form.</p> <p align="center">List only one of the following categories on each transmittal form, and indicate which is being submitted</p> <p><input type="checkbox"/> Contractor Approved <input checked="" type="checkbox"/> OICC Approval <input type="checkbox"/> Deviation/Substitution For OICC Approval</p>	<p align="center">REVIEWER USE ONLY</p> <p align="center">**ACTION CODES</p> <p>A-Approved D-Disapproved AN-Approved as noted RA-Receipt acknowledged. C-Comments R-Resubmit</p>
--	---

ITEM NO	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO. *	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES **	REVIEWER'S INITIALS CODE AND DATE
	02734	ROTARY DRILLED WATER WELLS WELL #14			
1	2.2.4	Recommendation and Data Submittal	7		
2	2.2	Driller's Log	7	A	JRB
3	2.2.3	Electric Log and Gamma Log	7	A	JRB
4	2.2.2	Water Analysis	7	A	JRB
5	2.2.2	Sieve Analysis	7	A	JRB
6	1.2.1	Shop Drawings	7	A	JRB
CONTRACTOR'S COMMENTS				A	JRB

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC

ONE COPY TO ROICC

CONTRACTOR REPRESENTATIVE (Signature)
Phil Reese *Phil Reese*

DATE RECEIVED BY REVIEWER: **3/24/86**

FROM (Reviewer): **Henry von Oesen & Assoc., Inc.**

TO: _____

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on ONE COPY of the transmittal form.

REVIEWER'S COMMENTS

Contractor's approval appears to be appropriate.

COPIES TO ROICC (2) LANTDIV (1) A-E (1)	DATE 4/2/86	SIGNATURE <i>[Signature]</i>
---	-----------------------	---------------------------------

Professional Association of...

North Carolina...

...

...

...

...

...

...

...

...

...

...

...

...

...

...

...

...

...

...

...

...

...

...

...

...

...

...

...

...

...

...

...

...

...

...

...

...

...

...

...

...

...

...

[Handwritten signature]

[Handwritten signature]

187



HARRY PEPPER & ASSOCIATES, INC.

ITEM # 1

ENGINEERING CONTRACTORS

March 19, 1986

Henry Von Oesen & Associates, Inc.
611 Princess Street
Wilmington, NC 28402

RE: N62470-81-C-1644
Expansion of Holcomb Blvd
Water Treatment Plant
Camp Lejeune, NC 28542
Well # 14


Gentlemen:

We are enclosing seven (7) copies of the Driller's Log, Gamma Log, Electric Log, Water and Sieve Analysis for your review. The test well was drilled at 250'. Water samples were taken at the 178' level.

We recommend a line of .030 slot stainless steel screen set at the 130-180' level for a total of 50VF of screen. The gravel pack recommended is 8-12. It is our best estimate that this well may field 260 GPM.

Please review the data and advise if we are to proceed with developing a permanent well at this site.

Very truly yours,
HARRY PEPPER & ASSOCIATES, INC.


Phil Reese
CQC Officer

Enclosures

It is hereby certified that the (material) (equipment) shown and marked in this submittal, shop drawings, catalog cut(s), etc., and approved/proposed to be incorporated into Contract Number N62470-81-C-1644 is in compliance with the Contract Drawings and Specifications and can be installed in the allocated space, and is:

____ Approved for use.

Submitted for Government approval.

____ Approved for use subject to Government approval of specific deviation.

Authorized Reviewer _____ DATE _____

Signature CQC Rep. Phil Reese DATE 3-19-86

ATLANTIC DIVISION
NAVAL FACILITIES ENGINEERING COMMAND
NORFOLK, VIRGINIA 23511

APPROVED _____
APPROVED AS NOTED _____
DISAPPROVED _____

SUBJECT TO THE REQUIREMENTS OF
CONTRACT NO. N62470-81-C-1644
APPROVAL OF A SUBMITTAL DOES NOT INCLUDE
APPROVAL OF ANY DEVIATION FROM THE CON-
TRACT REQUIREMENTS UNLESS THE CONTRAC-
TOR CALLS ATTENTION TO AND SUPPORTS THE
DEVIATION. THE CONTRACTOR SHALL BE RES-
PONSIBLE FOR PROVIDING PROPER PHYSICAL
DIMENSIONS & WEIGHTS, COORDINATION OF
TRADES, ETC., AS REQUIRED.


REVIEWER [Signature] DATE 02 1986

FOR OFFICER IN CHARGE OF CONSTRUCTION


WELL DRILLERS LOG
FOR MAGETTE WELL AND PUMP CO.


ITEM # 2

DEPTH IN FEET		MATERIAL SAMPLED	Well # 14
0	45	White Clay	
50	80	Fine Sand	
85	125	Shell and Fine Sand	
130	145	Limestone	
150	180	Strata Sand	
185	250	Fine Sand and Blue Clay	



Item # 3





LOW & COMPANY
Consulting and Analytical Chemists

ESTABLISHED 1903

Well # 663

Item # 4

Main Office
 1711 Castle Street
 P.O. Box 629
 Wilmington, N.C. 28402

REPORT DATE: 3-18-86

RICHARD SPIVEY, President
 919-762-7082 919-762-8956
 TWX 510-937-0280

MAJETTE WELL & PUMP COMPANY
 POST OFFICE BOX 908
 SMITHFIELD, VA. 23430
 ATTN: BUD KELLOG


DATE COLLECTED: 3-13-86
 DATE RECEIVED: 3-13-86
 COLLECTED BY: Bud Kellogg
 LAB I.D.# EW 3576

SAMPLE DESCRIPTION: WELL #14 178'

TESTS/SAMPLES	RESULTS	RESULTS
pH	7.8	POTASSIUM PPM 1.2
CARBON DIOXIDE PPM	0	CHLORIDE PPM 56
SULFIDES PPM	0	NITRATE NITROGEN PPM <.2
CHLORINE DEMAND PPM	.8	IRON PPM .80
COLOR APHA	20	MANGANESE PPM .03
TURBIDITY NTU	3	SILICON PPM 4.2
TOTAL ALKALINITY PPM	214	FLOURIDE PPM <.2
HYDROXIDE PPM	0	TEMP. (°F) 60°
BICARBONATE PPM	196	DISSOLVED OXYGEN MG/L 6
CARBONATE PPM	18	
TOTAL HARDNESS PPM	202	
NON-CARBONATE PPM	0	
CARBONATE PPM	202	
TOTAL DISSOLVED SOLIDS PPM	250	
SPECIFIC CONDUCTANCE UMHOS	350	
SULFATES PPM	4	
CALCIUM PPM	49	
MAGNESIUM PPM	1.2	
SODIUM PPM	7.6	

CHEMIST: Dolly Bidwan

TOTAL CHARGES: 180.00



Item #5

CONTACT...
 TELEPHONE...
 MARKS... WATER WELL
 RECOMMENDATIONS:
 GRAVEL SIZE...
 SCREEN SIZE...

HSSC


**HOWARD SMITH
 SCREEN COMPANY**

A Halliburton Company
 P.O. Box 666 • Houston, Texas 77001
 713-869-5771 • Telex: 77-4667

COMPANY... R.L. MASETTE COMPANY
 WELL..... #14
 DEPTH..... 130-180
 FIELD.....
 COUNTY.....
 STATE..... VA

SIEVE ANALYSIS REPORT


S	IN	MM	WT RET	CUM WT	CUM %
10	.0787	2.000	--	--	--
14	.0555	1.410	--	--	--
18	.0384	1.000	--	--	--
20	.0331	0.840	--	--	--
25	.0280	0.710	--	--	--
30	.0234	0.589	6.0	6.0	18.6
35	.0197	0.500	2.3	8.3	25.8
40	.0165	0.420	3.1	11.4	35.4
45	.0138	0.351	2.9	14.3	44.4
50	.0117	0.297	2.5	16.8	52.2
60	.0098	0.250	2.5	19.3	59.9
70	.0083	0.210	2.4	21.7	67.4
80	.0070	0.177	3.7	25.4	78.9
100	.0059	0.149	2.3	27.7	86.0
120	.0049	0.124	2.1	29.8	92.5
150	.0041	0.104	1.3	31.1	96.6
170	.0035	0.088	0.5	31.6	98.1
200	.0029	0.074	0.3	31.9	99.1
230	.0024	0.062	0.2	32.1	99.7
270	.0021	0.053	0.1	32.2	100.0
325	.0017	0.044	--	--	--
325			--	--	--



SIEVE OPENING MILLIMETERS		U.S. SIEVE NO.	
2.0	1.0	10	20
.8	.6	25	30
.5	.4	35	40
.3	.2	45	60
.1	.09	70	100
.08	.07	120	140
.06	.05	170	200
.04		230	270

8	10	12-20	16-30	20-40	40-60	50-70	120	170	230	325
12	16									

13-86
 JES E. JACKSON




FCR

R. L. MAGETTE COMPANY

WATER SUPPLY CONTRACTORS
DOMESTIC ; INDUSTRIAL ; MUNICIPAL

Wells, Pumps and Community Water Systems


Item #6




P. O. Box 908 Phone - 804 - 357-4103

Smithfield, Virginia 23430

WELL # 14





CONTRACTOR'S SUBMITTAL TRANSMITTAL
 LANTDIV NORFOLK 4-4355/3 (Rev. 11-80)

5/18/86
 /02

Hunt

FROM CONTRACTOR Harry Pepper & Associates, Inc.		CONTRACT NO 81-C-1644	TRANSMITTAL NO 204	DATE 5-15-86
TO Henry Von Oesen & Associates, Inc.		PROJECT TITLE AND LOCATION Holcomb Blvd Water Treatment Plant MCB, Cp Lejeune, North Carolina		

CONTRACTOR USE ONLY

*List only one specification division per form.

List only one of the following categories on each transmittal form, and indicate which is being submitted

- Contractor Approved
 OICC Approval
 Deviation/Substitution For OICC Approval

REVIEWER USE ONLY

****ACTION CODES**

- A-Approved
- D-Disapproved
- AN-Approved as noted
- RA-Receipt acknowledged.
- C-Comments
- R-Resubmit

ITEM NO	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO. *	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES **	REVIEWER'S INITIALS CODE AND DATE
	02734	ROTARY DRILLED WATER WELLS WELL #14			
1	3.1.6	24 Hour Pump Test	7	A	JRB
2	3.1.6	2 Hour Recovery Test	7	A	JRB

CONTRACTOR'S COMMENTS


Contractor was advised by Title II Inspector to do pump test at 350 GPM.

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC		CONTRACTOR REPRESENTATIVE (Signature)	
ONE COPY TO ROICC		Phil Reese <i>Phil Reese</i>	
DATE RECEIVED BY REVIEWER	FROM (Reviewer)	TO	
5/20/86	Henry von Oesen & Assoc., Inc.		

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on ONE COPY of the transmittal form.

REVIEWER'S COMMENTS

COPIES TO ROICC (2) LANTDIV (1) A-E (1)	DATE 5/23/86	SIGNATURE <i>Phil Reese</i>
---	-----------------	--------------------------------



24 HOUR PUMP TEST
WELL # 14

PUMPING RATE 350 GPM

ITEM # 1

TIME	PUMP SETTING 126'	STATIC 16'8"
	PUMPING LEVEL	DRAWDOWN
11:01	63'10	47'2
11:02	65'11	2'1
11:03	67'8	1'9
11:04	69'5	1'9
11:05	70'6	11''
11:06	71'3	9"
11:07	71'11	8"
11:08	72'8	9"
11:09	73'4	8"
11:10	73'10	6"
11:15	75'7	9"
11:20	75'11	4"
11:25	76'3	"
11:30	76'7	"
11:35	77'1	6"
11:40	77'6	5"
11:45	78'	6"
11:50	78'4	4"
11:55	78'9	5"
12:00	79'2	5"
1:00	80'4	1'2"
2:00	81'1	9"
3:00	81'11	10"
4:00	82'8	9"
5:00	83'6	10"
6:00	84'1	7"
7:00	84'7	6"
8:00	85'3	8"
9:00	85'11	"
10:00	86'7	"
11:00	87'2	7"
12:00	87'6	4"
1:00	87'11	5'
2:00	88'2	3"
3:00	88'5	3"
4:00	88'10	5"
5:00	89'1	3"
6:00	89'3	2"
7:00	89'3	-
8:00	89'6	3"
9:00	89'8	2"
10:00	89'11	3 "
11:00	90'1	2"

ATLANTIC DIVISION
NAVAL FACILITIES ENGINEERING COMMAND
NORFOLK VIRGINIA 23511

APPROVED _____
 APPROVED AS NOTED _____
 DISAPPROVED _____

SUBJECT TO THE REQUIREMENTS OF
 CONTRACT NO. N62470-81-C-1644
 APPROVAL OF A SHOP DRAWING DOES NOT INCLUDE
 APPROVAL OF ANY DEVIATION FROM THE CON-
 TRACT REQUIREMENTS UNLESS THE CONTRAC-
 TOR CALLS ATTENTION TO AND SUPPORTS THE
 DEVIATION --- THE CONTRACTOR SHALL BE RES-
 PONSIBLE FOR PROVIDING PROPER PHYSICAL
 DIMENSIONS & WEIGHTS, COORDINATION OF
 TRADES, ETC., AS REQUIRED.


REVIEWER *[Signature]* DATE MAY 22 1986

FOR OFFICER IN CHARGE OF CONSTRUCTION

I hereby certify that the material (equipment) shown on
 marked in this submittal, shop drawings, catalog cutlets, etc., and
 approved/proposed to be incorporated into Contract Number
 N62470-81-C-1644 is in compliance with the Contract Drawings
 and Specifications and can be installed in the allocated space,
 and is:

_____ Approved for use.
 Submitted for Government approval.
 _____ Approved for use subject to Government approval of
 specific deviation.


Authorized Reviewer _____ DATE _____
 Signature CQC Rep. *[Signature]* DATE 5-15-86



TWO HOUR RECOVERY
WELL # 14

ITEM # 2

11:01	47'3
11:02	39'1
11:03	36'11
11:04	32'9
11:05	30'5
11:06	29'2
11:07	27'10
11:08	25'3
11:09	24'6
11:10	22'9
11:15	21'1
11:20	20'
11:25	18'5
11:30	17'11
11:35	17'1
11:40	16'10
11:45	16'8"
11:50	"
11:55	"
12:00	"
1:00	"



Hunt

CONTRACTOR'S SUBMITTAL TRANSMITTAL
LANTDIV NORFOLK 4-4355/3 (Rev. 11-80)

CONTRACT NO 81-C-1644	TRANSMITTAL NO 201	DATE 5-8-86
--------------------------	-----------------------	----------------

FROM CONTRACTOR
Harry Pepper & Associates, Inc.

TO
Henry Von Oesen & Associates, Inc.

PROJECT TITLE AND LOCATION
Holcomb Blvd Water Treatment Plant

MCB, Cp Lejeune, North Carolina

CONTRACTOR USE ONLY

REVIEWER USE ONLY

*List only one specification division per form.

List only one of the following categories on each transmittal form,
and indicate which is being submitted

- Contractor Approved OICC Approval Deviation/Substitution
For OICC Approval

****ACTION CODES**
A-Approved
D-Disapproved
AN-Approved as noted
RA-Receipt acknowledged.
C-Comments
R-Resubmit

ITEM NO.	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO. *	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES **	REVIEWER'S INITIALS CODE AND DATE
	02734	ROTARY DRILLED WATER WELLS WELL # 14			
1		Step Test	7	A	JRB

CONTRACTOR'S COMMENTS

Contractor advised that Pumping Rate for 24 Hour test would be at 350 GPM.

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC

ONE COPY TO ROICC

CONTRACTOR REPRESENTATIVE (Signature)

Phil Reese *Phil Reese*

DATE RECEIVED BY REVIEWER

5/12/86

FROM (Reviewer)

HENRY VON OESEN & ASSOC., INC.

TO

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on ONE COPY of the transmittal form.

REVIEWER'S COMMENTS

COPIES TO
ROICC (2)
LANTDIV (1)
A-E (1)


DATE *12 MAY 1986*
5/14/86

SIGNATURE

Phil Reese

TIME	STATIC	PUMPING LEVEL	PUMPING RATE
8:00	16'8	92'5	350 GPM
8:15		98'5	400 GPM
8:30		100'	"
8:45		100'11	"
9:00		101'9	"
9:30		102'6	"
10:00		103'	"
10:30		103'5	"
11:00		103'8	"

APPROVED
DATE
BY
PROJECT NO.
SHEET NO.
TOTAL SHEETS
SCALE
DRAWN BY
CHECKED BY
DATE
PROJECT TITLE
SHEET NO.



Well # 14
 Step Test
 5/5/86

ITEM # 1

TIME	STATIC	PUMPING LEVEL	PUMPING RATE
2:05	16'8"	27'9	100 GPM
2:30		29'6	"
2:45		31'3	"
3:00		32'1	"
3:30		32'10	"
4:00		33'8	"
4:30		33'11	"
5:00		34'6	"
5:15		44'8	150 GPM
5:30		47'1	"
5:45		48'11	"
6:00		49'8	"
6:30		50'5	"
7:00		50'9	"
7:30		51'1	"
8:00		51'3	"
8:15		59'6	200 GPM
8:30		61'2	"
8:45		61'9	"
9:00		62'6	"
9:30		63'1	"
10:00		63'5	"
10:30		64'	"
11:00		64'6	"
11:15		65'2	250 GPM
11:30		65'9	"
11:45		65'11	"
12:00		66'5	"
12:00		66'5	
1:00		66'9	"
1:30		66'11	"
2:00		67'1	"
2:15		75'1	300 GPM=
2:30		76'11	"
2:45		77'9	"
3:00		78'4	"
3:30		78'11	"
4:00		79'5	"
4:30		79'10	"
5:00		80'3	"
5:15		87'11	350 GPM
5:30		89'2	"
5:45		90'1	"
6:00		90'10	"
6:30		91'5	"
7:00		92'11	"
7:30		92'3	"

ATLANTA
NAVAL FACILITIES ENGINEERING CENTER AND
NORFOLK, VIRGINIA 23511

APPROVED _____
APPROVED AS NOTED _____
DISAPPROVED _____

SUBJECT TO THE REQUIREMENTS OF
CONTRACT NO. NC2470-81-C-1644
APPROVAL OF A SUBMITTAL DOES NOT INCLUDE
APPROVAL OF ANY DEVIATION FROM THE CONTRACT
REQUIREMENTS UNLESS THE CONTRACTOR
CALLS ATTENTION TO AND SUPPORTS THE
DEVIATION --- THE CONTRACTOR SHALL BE RESPONSIBLE
FOR PROVIDING PROPER PHYSICAL
DIMENSIONS & WEIGHTS, COORDINATION OF
TRADES, ETC., AS REQUIRED.

REVIEWER [Signature] DATE MAY 14 1986

FOR OFFICER IN CHARGE OF CONSTRUCTION

"It is hereby certified that the (material) (equipment) shown and marked in this submittal, shop drawings, catalog cut (s), etc., and approved/proposed to be incorporated into Contract Number N62470-81-C-1644 is in compliance with the Contract Drawings and Specifications and can be installed in the allocated space, and is:

- Approved for use.
- Submitted for Government approval.
- Approved for use subject to Government approval of specific deviation.

Authorized Reviewer _____ DATE _____
Signature CQC Rep. [Signature] DATE 5-8-86