

DATE OF INSPECTION
 10-6-71

TYPE OF INSPECTION
 A INTERNAL & EXTERNAL B INTERNAL & EXTERNAL WITH PRESSURE TEST C OPERATIONAL

1. FROM Atlantic Division
 Naval Facilities Engineering Command
 2. TO Norfolk, Virginia 23511

14. CERTIFICATE ISSUED YES NO
 EXPIRE 5/27-72
 15. BOILER INSPECTOR

CAMP LEJEUNE ATTEN UTIL OFFICER

NAVY OR NATIONAL BOARD NO.

BOILER DATA

3. MANUFACTURER COMBUSTION ENG.
 4. PROPERTY NO. 83
 5. MFG. SERIAL NO. NB-110232
 6. MFG. MODEL NO. TYP-A

16. REASON FOR NOT ISSUING CERTIFICATE
 NAVFAC 122

7. BUILDING NO. T.C. 650
 8. YEAR BUILT 1969
 9. CAPACITY 40,000 #/HR

10. FUEL (Check) COAL OIL GAS
 11. PRESSURE
 DESIGNED 200 psi OPERATING 120 psi TEST psi

12. FEED WATER TREATMENT SATISFACTORY UNSATISFACTORY
 13. TYPE WATER TUBE FIRE TUBE C. I.

17. BOILER USE HEATING
 19. COMBUSTION 12.9 % CO₂ % EXCESS O₂

18. COMBUSTION CONTROL (Mfg. Name) CLEVELAND - BECKMAN
 20. FLUE GAS TEMPERATURE AFTER BOILER 540 °F ; AFTER HEAT TRAP °F

SAFETY DEVICES
 SAFETY VALVES

21. MANUFACTURER CONSOLIDATED
 22. NUMBER AND SIZE 2-2 1/2
 23. PSI SETTING 125-136
 24. CONDITION Good

STEAM PRESSURE GAUGE

25. MANUFACTURER ASHCROFT
 26. CORRECTIONS WATER LEG CONSTANT psi; OTHER psi

27. REASON IF NOT TESTED

FIRING EQUIPMENT

ITEM	IN SERVICE	ALTERNATE
MANUFACTURER	TODD	NONE
TYPE	GUN	
GRADE	#6	

INSPECTOR'S COMMENTS

SPECIAL COMMENTS

33. SIGNATURE VIRGIL O. RISSELL
 Head, Utilities Management
 Branch BY DIRECTION

