

JOB ORDER NO	DATE COMPLETED	COST	DESCRIPTION
0052	8-8-86 ✓	4162	INSTALL Air, water, & DRAN Lines for the Diesel Test Equip
3052	3-9-90	207	Disconnect Utilities from Transmission Tester.
3053	3-9-90	517	Disconnect @ pcs of Equipment
3385	10-17-90	9583	Rplc (22) flexible drops to vehicle bays.
8026	6-18-91	97	INSTALL 2 DUPLEX
3032	5-12-89	3907	Rplc existing Air Comp. in bldg
1012	2-3-89	2279	Construct shelter over Pol Stg area
0064	7-15-88	2430	Install Trans stand test equip
4553	2-1-88	5238	Reestablish ground around Bldg
1249	10-30-87	1502	Install Elec crants & correct dynometers
4536		4803	Replace rolling steel door PURGED 99
4473	7/28/00	3289	REPLACE ROLLING STEEL DOOR
1079	7/28/00	11,105	Mole #8 Inst. wiring system for body shop

JOB ORDER NO	DATE COMPLETED	COST	DESCRIPTION
1242	10-9-81	714	ERECT + INSTALL COMMODORE STALLS w DOORS
3139	11-20-81	804	Rpl. broken window
1281	8-4-82	8829	Const. Shelter w/concrete driveway on slot
4704	10-8-82	289	Rearrange exhaust lines
3857	Comp	3000	Procure contract to repair sun Generator / Alternator Test 190
3380	6-18-82	989	Reprs before Int. Paint Contract
5255	1-27-84	398	rpr rolling door
3683	5-13-83	2753	rpl A/compressor
3679	7-20-84	356	rpr overhead hoist
0051	12-24-85	2565	RPA acid Drain Sys. Bldg 1601
2034	1-10-86	642	INSTALL CIRCUIT FOR TESTING EQUIP
2122	7-27-85	1024	RELOCATE & INSTALL ELECT. CIRCUITS H+E SHOP
2149	8-8-86	582	INSTALL ELECT CIRCUITS & CONNECT (2)
2218	5-13-85	720	Procure contract to ser. & RPA (1) DYNAMOMETER
2221	6-13-85	584	Procure contract to ser. & RPA (1) DYNAMOMETER
2242	Compl	150	Procure contract to Rpr of encircling Alternator 3-5-85
2244	Compl	456	Procure contract Inspect, Ser. & DET. Rpl cot. 3-5-85
2377	10-10-85	660	ISSUE MATERIALS TO KEEP VEH. OUT OF UNWANTED AREAS
2372	5-24-85	1028	clean up contaminated soil from Acid spill vic. Bldg 1601
2401	8-28-85	1000	Procure contract to ser. & RPA. (1) Dynamometer
4228	Compl	638	RPA - OIL SEPARATOR & UNSEP FLOOR DRAINS 12-17-84
4248	12-12-86	925	Rpl (2) 100 AMP DISCONNECTS (HOT)
✓ 4330	12-21-84	1080	Rpl EXHAUST FAN in ROOF monitor window
4553	8-2-1-88	5238	Re - Establish Ground Around BLDG 1601
✓ 4471	11-11-85	285	STAIRS STEEL TANK RPA on Ticket
2083	COMP.	1162	Procure contract to ser. & Rpr minor Rpr
2372	10/10-85	660	Issue materials to keep vehicles out of unwanted areas

JOB ORDER NO	DATE COMPLETED	COST	DESCRIPTION
5804	9-21-76	398	Issue Material
5524	9-8-76	96	Pump out oil separator
4967	4967	931	Rpl roll up door
3521	11/15/76	728	Rpl (2) steam unit heaters
2438	9/22/76	383	Rpl cooling coil on degreaser
5033	3/17/76	944	Rpl roll up door curtain
Cont # 79-2624	Fy 80	1972	Ext. Paint
No 2470-78-C	814 12-17-80	12-17-80	Steam pit improvements for energy conservation
4538	20-Sept 80	471	fill in abandoned wheel pit with shell rock cap over w/ 4" concrete
3724	1-6-78	567	Repairs to pipe insulation on steam & return lines
4812	8-26-77	484	Repairs to pipe insulation
4237	9-30-77	4,085	Repair built up roof around monitor
3650	77'fy	777	Replace two (2) steam unit heaters in elec & fuel room with in op supply room
2742	Complete 8-22-78	850	Provide Service Cont. for repairs to dynamometer
3785	Complete 11-17-78	308	Procure contract to check engine dynamometer
2690	Complete 6-20-79	1572	" " to repair Sun Generator-Alternator
1326	8-25-78	123	Install 230 volt outlet & window A/C
3155	4-13-79	33,696	Rpr & paint Complete interior
3062	Comp	622	Replc overhead vit lead
2533	Comp	2781	Install solvent cleaner track
1076	5-16-80	4588	11 Paneling in operations
1063	4-11-80	1825	Install Dust collector
3496	5-9-80	1472	Repr. 2 large Roll up door
1072	80	340	Install window F&W
4232	81	1624	Repr 2 large Roll up doors
3229	80	1284	Remove 2 oil storage tanks
3609	11-7-80	340	Repairs to Exhaust fan
2144	7-11-80	870	Clean up oil spill

JOB ORDER NO	DATE COMPLETED signed	COST	DESCRIPTION
022-07212-620633	11/30/61		Relocate existing exhaust system (C 1-8-62)
022-07242-620518	3/23/62		Inst lighting (C 6/15/62)
022-07245-620418	3/26/62		Enlarge 3 doors (C 4/30/62)
023-03190-82	4/1/63		Paint exterior
023-03275-82	4/16/63		Renovate
Contract	6/10/66		Construct Battery Charging & Repair Shop
Contract	9/30/68	18,745.00	Reroof
3293	4-12-72	239	REPAIR ROLL UP DOOR
4259	12-5-72	531	REPAIR ROLL UP DOOR
1184	3-31-72		RELOCATE GLASS SANDING MACHINE
2691	6-2-72		PROCURE SERVICE CONTRACT
4126	10-17-73	373	REPAIR BIDG
123	12-5-72	429	REMOVE 4 LIGHTS & INSTALL 4 FLORES LIGHTS
3842	8-10-72	631	REPLACE CONDENSATE PUMP
3455	7-2-73	1602	PAINT GARAGE STOP
4292	12-14-73	546	REPAIR ROLL UP DOOR
1872	9-18-74	4632	INSTALL 6 EXHAUST FANS
4498	12-30-71	230	MINOR PLASTER WORK
3196	2-14-73	4,627	REPLACE 3 STEAM HEATERS
1072	9-18-74	4 906	INSTALL 6 EXHAUST FANS
3593	7-2-73	429	REPLACE SPRING ROLL UP DOOR
4898	4-25-75	770	Repair ext wall
2472	9-5-75	1201	Connect fuel injector testing equip
3680	9-19-75	395	Repair leak in barbit tank
5351		300	Repair engine dynameter PA #657108
3796	9-26-75	156	Repair door jamb, casing, hatch wall & paint