

Yellow

6240
NREAD
10 Sep 86

From: Commanding General, Marine Corps Base, Camp Lejeune
To: Defense Reutilization and Marketing Officer, Camp Lejeune

Subj: INSPECTION REPORT ON LONG TERM HAZARDOUS WASTE STORAGE FACILITIES AT BUILDINGS TP-451 and TP-463

Ref: (a) Onsite inspection by Mr. Becker, NREAD, and Mr. Eggers, DRMO
(b) CG MCB ltr FAC/REA/hf 6280 of 15 Jul 83

Encl: (1) Inspection Checklist for Long Term Hazardous Waste Storage Facilities at Buildings TP-451 and TP-463

1. The enclosure provides results of reference (a) as required by refernce (b). It was noted that four hazardous waste labels did not have EPA ID nos. or EPA Waste nos. on them. This discrepancy was corrected on the spot. Point of contact in this matter is Mr. Danny Becker, NREAD, extensions 5003/2083.

J. I. WOOTEN
By direction

Copy to:
AC/S FAC
BFIRECHIEF
SJA
BMO
BSAFETYMGR

1900



PARTICIPANTS Beckers, Barbee, Eggers

DATE: 10 Sep 1986

FACILITIES AND EQUIPMENT	SAT	UNSAT	COMMENTS
1. FACILITY GROUNDS	X		
2. FACILITY SECURITY (LOCKS, DOORS, SIGNS, ETC.)	X		
3. EMERGENCY TELEPHONE AND FIRE ALARMS	X		
4. LOADING PAD DRAIN VALVE	X		Dirt & sediment needs to be cleaned out
5. EXHAUST FANS	X		
6. INTERIOR LIGHTING AND ELECTRICAL OUTLETS	X		
7. SAFETY SHOWERS/ EYE LAVAGES	X		
8. CURBS, GRATES, OTHER FIXTURES	X		
9. NON-SPARKING SHOVELS (2)	X		
10. ABSORBENT (EQUIVALENT OF FOUR 55-GAL BARRELS)	X		
11. HAZ MAT PUMPS OR EQUIVALENT	X		
12. FIRE EXTINGUISHERS	X		
13. PROTECTIVE GEAR AND EQUIPMENT	X		
14. EMPTY CONTAINERS AND OVERPACK DRUMS	X		

ENCLOSURE (1)

OPERATIONAL CONSIDERATIONS	SAT	UNSAT	COMMENTS
1. Required operator inspections and Inspection Log	X		
2. Emergency Contingency Plan Posting & Operator Familiarity	X		
3. Fire Department Phone number posting	X		
4. Condition of containers in use	X		
5. Presence of odors/vapors, residues in sumps, deck, etc.	X		
6. Unloading Pad Valve Operation	X		
7. Compatibility of Material Storage	X		
8. Implementation of previously recommended corrective action	X		
9. Facility Operators since last inspection	X		George Eggers

ADDITIONAL COMMENTS, EXPLANATIONS, ETC:

Operator must ensure that Hazardous Waste labels are visible from isles. Operator must ensure that Hazardous Waste labels are completely filled out upon receipt.