

INSPECTION REPORT-BOILERS
 NAVFAC 9-11014/41 (3/67)
 Supersedes NAVDOCKS 3544
 S/N 0105-LF-004-0000

DATE OF INSPECTION
 29 OCT 1987

TYPE OF INSPECTION
 A INTERNAL & EXTERNAL B INTERNAL & EXTERNAL WITH PRESSURE TEST C OPERATIONAL

1. FROM
**BASE MAINT. OFFICER
 CAMP. LEJEUNE, N. C.**

2. TO
**NAVFACENGCOM
 NORFOLK, VA**

14. CERTIFICATE ISSUED YES NO

15. BOILER INSPECTOR
Thomas L. Lamer
 NAVY OR NATIONAL BOARD NO

BOILER DATA

3. MANUFACTURER
KEWANEE

4. PROPERTY NO. 18	5. MFG. SERIAL NO. HSB 97429	6. MFG. MODEL NO. C7-L-77
7. BUILDING NO. LCH 4014	8. YEAR BUILT 1945	9. CAPACITY 4,000 LB/HR.

10. FUEL (Check)
 COAL OIL GAS

11. PRESSURE
 DESIGNED **15** psi OPERATING **10** psi TEST **—** psi

12. FEED WATER TREATMENT
 SATISFACTORY UNSATISFACTORY

13. TYPE
 WATER TUBE FIRE TUBE C. I.

16. REASON FOR NOT ISSUING CERTIFICATE
**BOILER HAS BEEN
 REMOVED UNDER
 CONTRACT # 95-6439**

17. BOILER USE
HEATING

18. COMBUSTION CONTROL (Mfg. Name)
HONEYWELL

19. COMBUSTION
 % CO₂ _____ % EXCESS O₂ _____

20. FLUE GAS TEMPERATURE
 AFTER BOILER _____ °F AFTER HEAT TRAP _____ °F

**SAFETY DEVICES
 SAFETY VALVES**

21. MANUFACTURER
CONSOLIDATED

22. NUMBER AND SIZE
1-2"

23. PSI SETTING
15

24. CONDITION

STEAM PRESSURE GAUGE

25. MANUFACTURER
U.S. GAGE

26. CORRECTIONS
 WATER LEG CONSTANT _____ psi; OTHER _____ psi

27. REASON IF NOT TESTED

FIRING EQUIPMENT

ITEM	IN SERVICE	ALTERNATE
28. MANUFACTURER	WHIRL POWER	
29. TYPE	NOZZLE SPRAY	
30. FUEL GRADE	#2	

31. INSPECTOR'S COMMENTS

GONE - REMOVE FROM PROPERTY LIST.

32. ATTACHMENT(S) (Check)
 COPY OF INSPECTOR'S REPORT SPECIAL COMMENTS

33. SIGNATURE
Timothy J. [Signature] 11/2/87
 BY DIRECTION

INSPECTION REPORT-BOILERS
 NAVFAC 9-11014/41 (3/67)
 Supersedes NAVDOCKS 2544
 S/N 0105-004-0000

DATE OF INSPECTION
 1-3-77

TYPE OF INSPECTION
 A INTERNAL & EXTERNAL B INTERNAL & EXTERNAL WITH PRESSURE TEST C OTHER

1. FROM

Base Maint. Office Camp Lejeune NC.

2. TO

Commandant Ndytes Marine Corps (Code 411)

14. CERTIFICATE ISSUED YES NO
 EXPIRES 5-4-77
 15. BOILER INSPECTOR

E.B. M...
 NAVY OR NATIONAL GUARD NO.

BOILER DATA

3. MANUFACTURER

Kewanee

4. PROPERTY NO.

18

5. MFG. SERIAL NO.

NSG 97429

6. MFG. MODEL NO.

C-7-L-77

7. BUILDING NO.

4014

8. YEAR BUILT

1945

9. CAPACITY

4,000, lbs/hr.

10. FUEL (Check)

11. PRESSURE

DESIGNED

15 psi

OPERATING

10 psi

TEST

12. FEED WATER TREATMENT

COAL OIL GAS

13. TYPE

WATER TUBE

FIRE TUBE

C. I.

16. REASON FOR NOT ISSUING CERTIFICATE

17. BOILER USE

Heating

18. COMBUSTION CONTROL (Mfg. Name)

Honeywell

19. COMBUSTION

5.5 % CO₂

% EXCESS O₂

20. FLUE GAS TEMPERATURE

AFTER BOILER 500

°F : AFTER HEAT TRAP

SAFETY DEVICES

SAFETY VALVES

21. MANUFACTURER

Consolidated

22. NUMBER AND SIZE

1-1 1/2"

23. PSI SETTING

15

24. CONDITION

New.

STEAM PRESSURE GAUGE

25. MANUFACTURER

MARSH

26. CORRECTIONS

WATER LEG CONSTANT

psi; OTHER

psi

27. REASON IF NOT TESTED

FIRING EQUIPMENT

ITEM

IN SERVICE

ALTERNATE

28. MANUFACTURER

Petco

None

29. TYPE

Nozzle Spray Press. Atom.

30. FUEL GRADE

#2

31. INSPECTOR'S COMMENTS

O.K.

32. ATTACHMENT(S) (Check)

COPY OF INSPECTOR'S REPORT

SPECIAL COMMENTS

33. SIGNATURE

Daniel L. White

BY DIRECTION

DATE OF INSPECTION
 5-4-76 - 6-8-76

TYPE OF INSPECTION
 A INTERNAL & EXTERNAL B INTERNAL & EXTERNAL WITH PRESSURE TEST C OPERATIONAL

1. FROM
Base Maint Officer Camp Lejeune NC.
 2. TO
Commandant Hdqtrs Marine Corps (Code 4FF)

14. CERTIFICATE ISSUED YES NO
 Expires *2-3-77*
 15. BOILER INSPECTOR
E. D. Mehley
 NAVY OR NATIONAL BOARD NO.
NAVFAC 101

BOILER DATA

3. MANUFACTURER
Consolidated Kewanee
 4. PROPERTY NO. *18* 5. MFG. SERIAL NO. *MSB 97429* 6. MFG. MODEL NO. *C7-L-77*
 7. BUILDING NO. *4014* 8. YEAR BUILT *1945* 9. CAPACITY *4,000 H/H.R.*
 10. FUEL (Check) COAL OIL GAS 11. PRESSURE
 DESIGNED *15* psi OPERATING *8* psi TEST *22* psi
 12. FEED WATER TREATMENT SATISFACTORY UNSATISFACTORY 13. TYPE
 WATER TUBE FIRE TUBE C. I.

16. REASON FOR NOT ISSUING CERTIFICATE

17. BOILER USE
Heating 18. COMBUSTION CONTROL (Mfg. Name)
Honeywell
 19. COMBUSTION % CO₂ _____ % EXCESS O₂ _____ 20. FLUE GAS TEMPERATURE
 AFTER BOILER _____ °F ; AFTER HEAT TRAP _____ °F

SAFETY DEVICES

SAFETY VALVES

21. MANUFACTURER
Consolidated 22. NUMBER AND SIZE
1-3/4" 1-1/2" 23. PSI SETTING _____ 24. CONDITION _____
 25. MANUFACTURER
Marsh 26. CORRECTIONS
 WATER LEG CONSTANT _____ psi; OTHER _____ psi
 27. REASON IF NOT TESTED

FIRING EQUIPMENT

ITEM	IN SERVICE	ALTERNATE
28. MANUFACTURER	<i>Petro</i>	<i>NONE</i>
29. TYPE	<i>Nozzle, Spray Press. Atom.</i>	
30. FUEL GRADE	<i>#2</i>	

31. INSPECTOR'S COMMENTS
Replace Leaking Safety Valve
Replace Leaking Low Water Cut Off Blow Off Valve

32. ATTACHMENT(S) (Check)
 COPY OF INSPECTOR'S REPORT SPECIAL COMMENTS

33. SIGNATURE
Dan White
 BY DIRECTION

