

INSPECTION REPORT-BOILERS
 NAVFAC 9-11014/41 (3/67)
 Supersedes NAVDOCKS 2544
 S/N 0105-LF-004-0000

DATE OF INSPECTION

15 DEC 1978

TYPE OF INSPECTION

A

INTERNAL & EXTERNAL

B

INTERNAL & EXTERNAL WITH PRESSURE TEST

C

OPERATIONAL

1. FROM

BASE MAINT. OFFICER CAMP LEJEUNE NC.

2. TO

COMMANDANT Hdqtrs MARINE CORPS (CODE LF)

BOILER DATA

3. MANUFACTURER

U.S. RADIATOR

4. PROPERTY NO.

44

5. MFG. SERIAL NO.

134944

6. MFG. MODEL NO.

CO-18

7. BUILDING NO.

TC 200

8. YEAR BUILT

1945

9. CAPACITY

10. FUEL (Check)

COAL

OIL

GAS

11. PRESSURE

DESIGNED

30

psi

OPERATING

12

psi

TEST

psi

12. FEED WATER TREATMENT

SATISFACTORY

UNSATISFACTORY

13. TYPE

WATER TUBE

FIRE TUBE

C. I.

14.

CERTIFICATE ISSUED YES NO

15. BOILER INSPECTOR

Jesse T. Sellen

NAVY OR NATIONAL BOARD NO.

NAVFAC 225

16. REASON FOR NOT ISSUING CERTIFICATE

THIS BOILER HAS BEEN ABANDONED DUE TO Bldg. TC 200 BEING DESTROYED BY FIRE -

17. BOILER USE

HEATING

18. COMBUSTION CONTROL (Mfg. Name)

19. COMBUSTION

% CO₂

% EXCESS O₂

AFTER BOILER _____ °F ; AFTER HEAT TRAP _____ °F

SAFETY DEVICES

SAFETY VALVES

21. MANUFACTURER

22. NUMBER AND SIZE

23. PSI SETTING

24. CONDITION

STEAM PRESSURE GAUGE

25. MANUFACTURER

26. CORRECTIONS

WATER LEG CONSTANT _____ psi; OTHER _____ psi

27. REASON IF NOT TESTED

FIRING EQUIPMENT

ITEM	IN SERVICE	ALTERNATE
28. MANUFACTURER	ARCO FLAME	
29. TYPE	NOZZLE SPRAY	
30. FUEL GRADE	#2	

31. INSPECTOR'S COMMENTS

32. ATTACHMENT(S) (Check)

COPY OF INSPECTOR'S REPORT

SPECIAL COMMENTS

33. SIGNATURE

R.M. Sellen

BY DIRECTION

INSPECTION REPORT-BOILERS
 NAVFAC 9-11014/41 (3/67)
 Supersedes NAVDOCKS 2544
 S/N 0105-LF-004-0000

DATE OF INSPECTION
 3-2-77

TYPE OF INSPECTION
 A INTERNAL & EXTERNAL B INTERNAL & EXTERNAL WITH PRESSURE TEST C OPERATIONAL

1. FROM
 Base MAINT OFFICER Camp Lejeune N.C.
 2. TO
 Commandant Adytras Marine Corps (Code 172)

14. CERTIFICATE ISSUED YES NO
 EXPIRES 8-26-77
 15. BOILER INSPECTOR
 E.O. Mobley
 NAVY OR NATIONAL BOARD NO
 NAVFAC 101

BOILER DATA

3. MANUFACTURER
 U.S. Radiator

4. PROPERTY NO. 44	5. MFG. SERIAL NO. 134944	6. MFG. MODEL NO. CO-18
7. BUILDING NO. TC 206	8. YEAR BUILT 1945	9. CAPACITY 1

10. FUEL (Check)
 COAL OIL GAS

11. PRESSURE
 DESIGNED 30 psi OPERATING 12 psi TEST - psi

12. FEED WATER TREATMENT
 SATISFACTORY UNSATISFACTORY

13. TYPE
 WATER TUBE FIRE TUBE C. I.

16. REASON FOR NOT ISSUING CERTIFICATE

17. BOILER USE
 Heating

19. COMBUSTION
 7.0 % CO₂ _____ % EXCESS O₂

18. COMBUSTION CONTROL (Mfg. Name)
 Honeywell

20. FLUE GAS TEMPERATURE
 AFTER BOILER 600 °F ; AFTER HEAT TRAP _____ °F

SAFETY DEVICES
 SAFETY VALVES

21. MANUFACTURER WATTS	22. NUMBER AND SIZE 1-2"	23. PSI SETTING 30	24. CONDITION Good
---------------------------	-----------------------------	-----------------------	-----------------------

STEAM PRESSURE GAUGE

25. MANUFACTURER
 ASME STD

26. CORRECTIONS
 WATER LEG CONSTANT _____ psi; OTHER _____ psi

27. REASON IF NOT TESTED

FIRING EQUIPMENT

ITEM	IN SERVICE	ALTERNATE
28. MANUFACTURER	ARCO Flame	None
29. TYPE	Nozzle, Spray-Press Atom.	
30. FUEL GRADE	#2	

31. INSPECTOR'S COMMENTS
 OK.

32. ATTACHMENT(S) (Check)
 COPY OF INSPECTOR'S REPORT SPECIAL COMMENTS

33. SIGNATURE
 J. A. Davis
 BY DIRECTION

INSPECTION REPORT-BOILERS
 NAVFAC 9-11014/41 (3/67)
 Supersedes NAVDOCKS 2544
 S/N 0105-LF-004-0000

DATE OF INSPECTION
 8-26-76

TYPE OF INSPECTION
 A INTERNAL & EXTERNAL B INTERNAL & EXTERNAL WITH PRESSURE TEST C OPERATIONAL

1. FROM
 Base Maint. Officer Camp Lejeune NC.

14. CERTIFICATE ISSUED YES NO
 EXPIRES 11-12-76
 15. BOILER INSPECTOR

2. TO
 Commandant Hdqrs Marine Corps (Code LRF)

E.O. Morley
 NAVY OR NATIONAL BOARD NO.

BOILER DATA

3. MANUFACTURER
 U.S. Radiator

16. REASON FOR NOT ISSUING CERTIFICATE

4. PROPERTY NO. 44
 5. MFG. SERIAL NO. 134944
 6. MFG. MODEL NO. C018
 7. BUILDING NO. TC200
 8. YEAR BUILT 1945
 9. CAPACITY

10. FUEL (Check)
 COAL OIL GAS
 11. PRESSURE
 DESIGNED 30 psi OPERATING 12 psi TEST 45 psi

12. FEED WATER TREATMENT
 SATISFACTORY UNSATISFACTORY
 13. TYPE
 WATER TUBE FIRE TUBE C. I.

17. BOILER USE
 Heating
 19. COMBUSTION
 % CO₂ _____ % EXCESS O₂ _____

18. COMBUSTION CONTROL (Mfg. Name)
 Honeywell
 20. FLUE GAS TEMPERATURE
 AFTER BOILER _____ °F : AFTER HEAT TRAP _____ °F

SAFETY DEVICES
SAFETY VALVES

21. MANUFACTURER
 Mc Donnell Miller
 22. NUMBER AND SIZE
 1-1/2"
 23. PSI SETTING
 24. CONDITION

25. MANUFACTURER
 ASME STD.
 26. CORRECTIONS
 WATER LEG CONSTANT _____ psi; OTHER _____ psi
 27. REASON IF NOT TESTED

FIRING EQUIPMENT

ITEM	IN SERVICE	ALTERNATE
28. MANUFACTURER	Arco Flame	None
29. TYPE	Nozzle spray	
30. FUEL GRADE	#2	

31. INSPECTOR'S COMMENTS
 Rebuild Fire Box

32. ATTACHMENT(S) (Check)
 COPY OF INSPECTOR'S REPORT SPECIAL COMMENTS
 33. SIGNATURE
 Daniel L. White
 BY DIRECTION

