

INSPECTION REPORT-BOILERS
 NAVFAC 9-11014/41 (3/87)
 Supersedes NAVDOCKS 2544
 S/N 0105-LF-004-0000

DATE OF INSPECTION
 15 SEPT. 2 OCT 1986

TYPE OF INSPECTION
 A INTERNAL & EXTERNAL B INTERNAL & EXTERNAL WITH PRESSURE TEST C OPERATIONAL

1. FROM **BASE MAINT. OFFICER
 CAMP LEJEUNE, N. C.**
 2. TO **NAVFACENGCOM
 NORFOLK, VA.**

14. CERTIFICATE ISSUED YES NO
 EXPIRES 15 SEPT. 1987
 15. BOILER INSPECTOR

Thomas L. Lanier
 NAVY OR NATIONAL BOARD NO.

NAVFAC 239
 16. REASON FOR NOT ISSUING CERTIFICATE

BOILER DATA

3. MANUFACTURER
SUPERIOR BOILER WORKS

4. PROPERTY NO. 64	5. MFG. SERIAL NO. 7771	6. MFG. MODEL NO. 5-5-508
7. BUILDING NO. BA-106	8. YEAR BUILT 1977	9. CAPACITY 3,450 LB/HR
10. FUEL (Check) <input type="checkbox"/> COAL <input checked="" type="checkbox"/> OIL <input type="checkbox"/> GAS		11. PRESSURE DESIGNED 150 psi OPERATING 50 psi TEST 100 psi
12. FEED WATER TREATMENT <input checked="" type="checkbox"/> SATISFACTORY <input type="checkbox"/> UNSATISFACTORY		13. TYPE <input type="checkbox"/> WATER TUBE <input checked="" type="checkbox"/> FIRE TUBE <input type="checkbox"/> C. I.

17. BOILER USE
EXPORT

19. COMBUSTION
12.0 % CO₂ **8.0** % EXCESS O₂

18. COMBUSTION CONTROL (Mfg. Name)
HONEYWELL

20. FLUE GAS TEMPERATURE
 AFTER BOILER **400** °F : AFTER HEAT TRAP _____ °F

SAFETY DEVICES

21. MANUFACTURER
KUNKLE

22. NUMBER AND SIZE 1-1/2" 1-1/4"	23. PSI SETTING 65-60	24. CONDITION SAT.
---	---------------------------------	------------------------------

25. MANUFACTURER
MARSH

26. CORRECTIONS
 WATER LEG CONSTANT _____ psi; OTHER _____ psi

27. REASON IF NOT TESTED

FIRING EQUIPMENT

ITEM	IN SERVICE	ALTERNATE
28. MANUFACTURER	PEABODY GORDON & PIATT	
29. TYPE	NOZZLE SPRAY	
30. FUEL GRADE	#2	

31. INSPECTOR'S COMMENTS
 (1) W/S MEDIUM SCALE (HARD) & PITTING, TUBE ENDS ARE THINNED FROM ROLLING AND COMBUSTION GASES, RECOMMEND REPLACING TUBES IN THE (2) TWO YEARS. (2) INSTALL COVER ON HIGH LIMIT CUT OUT CONTROL.

32. ATTACHMENT(S) (Check)
 COPY OF INSPECTOR'S REPORT SPECIAL COMMENTS

33. SIGNATURE
M. O. Haragan
 BY DIRECTION

DATE OF INSPECTION
 26 DEC 1979

TYPE OF INSPECTION
 A INTERNAL & EXTERNAL B INTERNAL & EXTERNAL WITH PRESSURE TEST C OPERATIONAL

1. FROM BASE MAINT. OFFICER
 CAMP LEJEUNE, N. C.

2. TO NAVFACENCOM
 NORFOLK, VA

14. CERTIFICATE ISSUED YES NO
 EXPIRES 22 MAY 1980
 15. BOILER INSPECTOR

Jesse L. Sellers
 NAVY OR NATIONAL BOARD NO.
 NAVFAC 225
 16. REASON FOR NOT ISSUING CERTIFICATE

BOILER DATA

3. MANUFACTURER SUPERIOR BOILER WORKS

4. PROPERTY NO. 64
 5. MFG. SERIAL NO. 7771
 6. MFG. MODEL NO. 5-5-508
 7. BUILDING NO. RA-106
 8. YEAR BUILT 1977
 9. CAPACITY 3,450 lbs/HR
 10. FUEL (Check)

11. PRESSURE DESIGNED 150 psi OPERATING 50 psi TEST — psi
 COAL OIL GAS
 12. FEED WATER TREATMENT SATISFACTORY UNSATISFACTORY
 13. TYPE WATER TUBE FIRE TUBE C. I.

17. BOILER USE EXPORT
 19. COMBUSTION 12.0 % CO₂ % EXCESS O₂

18. COMBUSTION CONTROL (Mfg. Name) HONEYWELL
 20. FLUE GAS TEMPERATURE AFTER BOILER 300 °F : AFTER HEAT TRAP °F

SAFETY DEVICES
 SAFETY VALVES


21. MANUFACTURER KUNKIE
 22. NUMBER AND SIZE 1-1/2" 1-1/4"
 23. PSI SETTING 60
 24. CONDITION GOOD


25. MANUFACTURER MARSH
 26. CORRECTIONS WATER LEG CONSTANT psi; OTHER psi
 27. REASON IF NOT TESTED

ITEM	FIRING EQUIPMENT	
	IN SERVICE	ALTERNATE
28. MANUFACTURER	PEABODY GORDON & PINTH	
29. TYPE	NOZZLE SPRAY	
30. FUEL GRADE	#2	
31. INSPECTOR'S COMMENTS OK		

32. ATTACHMENT(S) (Check)
 COPY OF INSPECTOR'S REPORT SPECIAL COMMENTS

33. SIGNATURE R.M. Dutton
 BY DIRECTION





FACTORY FIRETEST REPORT
OIL FIRING

BA-106 #56
64

Representative: POWER & HEAT Date: 11/23/1977
 Name: CAMP LEJEUNE National Board NO: 7771
 Burner Model: 5-5-508-S150-G.P. Burner Model: S10.1-0-30
 (s) #2 Oil Type of Firing: Modulation
 Stage and Phase: 240-60-3 Damper: Manual Auto
72 Energy Extractors Installed Combustion Control Type: GP-301

	Low Fire	High Fire
Firing Rate GPH	<u>13.3</u>	<u>30</u>
Flame Signal Pilot <u>2.5 UA</u>	<u>3 UA</u>	<u>3 UA</u>
Gas Pressure Supply		
Gas Pressure Nozzle		
Gas Temp. F. #2		
Primary Preheater		
Secondary Preheater		
Atomizer Nozzle		
Gas Pressure Pump <u>310 Psi</u>		
Gas Pressure Nozzle	<u>300 Psi</u>	<u>310 Psi</u>
Gas Pressure Return	<u>102 Psi</u>	<u>172 Psi</u>
Water Pressure or Temp.	<u>100 Psi</u>	<u>100 Psi</u>
Flame Box Pressure Inches W.C.	<u>.3</u>	<u>1.8</u>
Flame Box Temperature Degree F.	<u>345</u>	<u>400</u>
Flame Box Ambient Temp. Degree F. <u>60</u>		
Flame Losses Percent	<u>13.5</u>	<u>13</u>
Flame Losses - Bacharach	<u>0</u>	<u>0</u>
Combustion Efficiency Percent	<u>87.1</u>	<u>85.7</u>
Flame Losses Percent <u>1.5</u>		
Overall to Steam Efficiency Percent	<u>85.6</u>	<u>84.2</u>

Test Conducted BY Ed Nather

Report Approved by Quality Control Fred Galstering

Reverse Side for Control Checks

High Limit	Set at----	100 Psi	----	Checked	<input checked="" type="checkbox"/>
Operation Limit	Set at----	95 Psi	----	Checked	<input checked="" type="checkbox"/>
Modulating Control	Set at----	90 Psi	----	Checked	<input checked="" type="checkbox"/>
High Oil Press Switch	Set at----		----	Checked	<input type="checkbox"/>
Low Oil Press Switch	Set at----		----	Checked	<input type="checkbox"/>
High Oil Temp. Switch	Set at----		----	Checked	<input type="checkbox"/>
Low Oil Temp Switch	Set at----		----	Checked	<input type="checkbox"/>
Primary LWCO-----				Checked	<input checked="" type="checkbox"/>
Auxillary LWCO-----				Checked	<input checked="" type="checkbox"/>
Air Flow Switch-----				Checked	<input checked="" type="checkbox"/>
Burner Door Switch-----				Checked	<input type="checkbox"/>
Oil System Checked for Leaks-----				Checked	<input checked="" type="checkbox"/>
Doors & Burner Checked for Leaks-----				Checked	<input checked="" type="checkbox"/>
Dielectric Test-----				Checked	<input type="checkbox"/>
Blower Motor Amps		<u>7.5/6.5/8.5</u>			



BOILER SPECIFICATION SHEET

DATE RECEIVED: 8-17-77
 JOB NAME: Camp Lejeune
 REPRESENTATIVE: Power & Heat P.O. # _____
 SOLD TO: _____ P.O. # _____

SHIPPING DATE (WK. OF) 11-15-77

PAGE 2 OF 2
 SALES ORDER NO. 256

SHIP TO: _____
 SHIPPING INST.: _____
 CALL _____ AT _____
 A.C. _____ HRS. BEFORE DELIVERY
 DATE RELEASED: _____

REVISIONS			
REV.	DATE	BY	REVISION OR CHANGE
A			
B			
C			
D			

MANUALS: REQ'D 6 MAILED _____ ON _____ BY _____
 SUBMITTAL: 10 SETS REQ'D ON _____ CERTIFIED
 BURNER GAS PIPING DIAG. OIL PIPING DIAG. COMPONENT LIST
 SUBMITTAL# _____
 MAILED _____ ON _____ BY _____

COMBUSTION - EQUIPMENT

BOILER-BURNER W.D.: _____
 GAS PIPING DIAG.: _____
 AVAILABLE GAS PRESS.: _____ PSI ALTITUDE _____ FT.
 MFG.: Griffin & Pratt MODEL: S10.1 - 0 - 20 - GP 301ccc - F77-UL-MIL SERIAL NO. _____
 FUEL(S): 7 2 oil OPERATION(S) Modulation
 FIRING RATE: _____ CFM OIL 30 GPM
 FLAME SAFEGUARD CONTROL: GP 301 CCC (L) SERIAL NO.: _____
 FLAME DETECTOR: GAS OIL GAS-OIL - C7027
 GAS PILOT: 216
 PILOT GAS PRESSURE REGULATOR: PV30 SIZE 3/2"
 PILOT SHUT-OFF COCK: S-2M3C SIZE 3/4"
 PILOT SOLENOID VALVE: K3R SIZE 3/8"
 PILOT SAFETY SOLENOID VALVE: K3R SIZE 3/8"
 PILOT W.O. VENT VALVE: _____ SIZE _____
 PILOT GAS PRESSURE GAUGE: _____ SIZE _____
 LEAK TEST COCK: _____ SIZE _____
 MAIN SHUT-OFF COCK: _____ SIZE _____
 GAS STRAINER: _____ SIZE _____
 MAIN GAS PRESSURE REGULATOR: _____ SIZE _____
 SPRING RANGE: _____ ORIFICE SIZE _____
 AUTOMATIC GAS VALVE: _____ SIZE _____
 SAFETY GAS VALVE: _____ SIZE _____
 W.O. VENT VALVE: _____ SIZE _____
 FIRING RATE VALVE: _____ SIZE _____
 FIRING COCK: _____ SIZE _____
 LOW GAS PRESSURE SWITCH: _____ RANGE _____ "W.C. ()
 HIGH GAS PRESSURE SWITCH: _____ RANGE _____ "W.C. ()
 GAS PRESSURE GAUGE () _____ RANGE _____ "W.C.
 AIR FLOW SWITCH Cleveland AIR PRESSURE SWITCH
 LOW DRAFT SWITCH: _____
 FIRING RATE MOTOR: HI-LO MOD M954C
 LOW FIRE INTERLOCK: INCH
 CONTROL PANEL: MFD BURNER BOILER REMOTE
 DEAD FRONT PANEL DRAFT GAUGE D.C. VOLTMETER
 POWER ON SWITCH FUEL CHANGE-OVER SWITCH
 MANUAL FIRING RATE CONTROL: GP
 INDICATING LIGHTS 5 STD. OIL TIGHT
 POWER ON
 MAIN FUEL GREEN HIGH GAS PRESS.
 CALL FOR HEAT LOW GAS PRESS.
 IGNITION ON
 FLAME FAILURE RED
 LOW WATER

CONTROL SYSTEM NO.: _____
 OIL PIPING DIAG. _____
 BURNER W.D.: _____
 BLOWER MOTOR VOLTAGE: 240-60-3⁴ H.P. 3
 STARTER AH SIZE 0 HEATER INCL
 OIL PUMP MOTOR VOLTAGE: _____ H.P. _____
 STARTER _____ SIZE _____ HEATER _____
 OIL METERING PUMP MOTOR VOLTAGE: _____ H.P. _____
 STARTER _____ SIZE _____ HEATER _____
 AIR COMPRESSOR MOTOR STARTER VOLTAGE: _____ H.P. _____
 STARTER _____ SIZE _____ HEATER _____
 OIL PUMP: INTEGRAL Webster
 REMOTE ()
 OIL STRAINER: _____ SIZE _____
 OIL FILTER: _____ SIZE _____
 BY-PASS OIL RELIEF VALVE: _____ SIZE _____
 PRESSURE _____ PSI
 MAIN OIL VALVE: 8263 A210 SIZE 3/8"
 SAFETY OIL VALVE: 8263 A210 SIZE 3/8"
 BY-PASS OIL SOLENOID VALVE: _____ SIZE _____
 3 WAY OIL VALVE: _____ SIZE _____
 LOW FIRE OIL VALVE: _____ SIZE _____
 HIGH FIRE OIL VALVE: _____ SIZE _____
 OIL METERING VALVE: Hauck SIZE _____
 OIL PRESSURE SWITCH: HI LOW L404V RANGE 0-50 PSI
 OIL PRESSURE GAUGE (2) GP 1/2" Dial RANGE 0-50 PSI
 OIL TEMPERATURE SWITCH: _____ RANGE _____ °F
 OIL TEMPERATURE GAUGE () _____ RANGE _____ °F
 OIL HEATER: (INTEGRAL ELEC.) _____ VOLTAGE _____
 GAS IGNITION TRANSFORMER: GP 6000 V
 OIL IGNITION TRANSFORMER: _____ V
 CONTROL CIRCUIT STEP DOWN TRANSFORMER: T4296 - 240-115 V
 AUTO-MANUAL FAN SWITCH
 ALARMS REQ'D TO SOUND ALARM:
 FLAME FAILURE HIGH GAS PRESS
 LOW WATER LOW GAS PRESS
 LOW DRAFT LOW WATER PRESS
 ALARM: BELL L11 HORN REMOTE
 W/SILENCING SWITCH W/MOMENTARY CONTACT SILENCING SWITCH
 BURNER TO MEET THE FOLLOWING CODES: UL FIA FM 13770C
 SPECIAL INSTRUCTIONS: _____

COMPLETED BY: _____ DATE _____ (L) SHIPPED LOOSE
 SALES: _____ (M) SHIPPED MOUNTED
 SCHEDULING: _____

DATE RECEIVED: 5-11-77
 JOB NAME: Camp Hejeune
 REPRESENTATIVE: Power Heat P.O. #
 SOLD TO: Industrial Boiler P.O. # A 5862
 SHIP TO:
 SHIPPING INST.
 CALL _____ AT
 A.C. _____ HRS. BEFORE DELIVERY
 DATE RELEASED:

SHIPPING DATE (WK. OF): 11-15-77

SALES ORDER NO. 2563
 NAT'L BOARD NO. 7771
 SERIAL NO.

REVISIONS			
REV.	DATE	BY	REVISION OR CHANGE
A	9-26-77	DWB	Add Kunitz
B			+ Trim
C	10-15-77	DWB	Change design
D			add let to 300"

MANUALS: REQ'D 6 MAILED 5 ON 12-30-77 BY
 SUBMITTALS: 10 SETS REQ'D ON _____ CERTIFIED
 BOILER R & D W.D. S.W.D.
 SUBMITTALS: _____
 MAILED _____ ON _____ BY _____

MODEL NO. 5-5-508-5150-GP
 DESIGN PRESSURE 150 PSI STEAM WATER HI-TEMP WATER
 PER SECTION I ASME BOILER/P.V. CODE
 STEAM NOZZLE: STD. SPL. 4" 300# Flg
 WATER SUPPLY: STD. SPL.
 RETURN: STD. SPL.
 SAFETY VALVE CONNECTIONS SIZES: STD. SPL.
 () ()
 () ()
 SKIMMER COUPLING: STD. SPL.
 CONTINUOUS BLOWDOWN COUPLING: STD. SPL.
 W/DIP TUBE W/INTERNAL PIPING
 SPECIAL CONNECTIONS: T.C. R.S. B.C. L.S. 45°
 () ()
 () ()
 TUBES: ROLLED ROLLED/FLARED ROLLED/BEADED ROLLED/WELDED
 ROLLED/BEADED W/SEAL WELD OTHER


NAME PLATE Azee PAINT Blue
 HTC. SURFACE 508 SQ. FT. OUTPUT 3347 M.B.H.
 OPERATING PRESS. _____ PSI OPERATING TEMP. _____ °F
 SKID: STD. SPL.
 STACK CONNECTION: STD. SPL. 16"
 DAMPER W/LOCKING QUAD. W/BEARINGS MOTORIZED
 HINGE DAVIT SWING: RIGHT SIDE LEFT SIDE
 OBSERVATION PORT: STD. MOVEABLE FRONT REAR
 EXPLOSION DOORS: FRONT REAR SPL.
 INSULATION: STD. FIBERGLASS OTHER
 JACKET: STD. WEATHERPROOF OTHER
 WALKWAY: STD. SPL.
 HANDHOLES: STD. SPL.
 MANWAY: STD. SPL.
 BURNER MOUNT: S101-0-30 Gordon & Puff
 BURNER FACTORY MOUNTED FIELD MOUNTED
 BURNER MOTOR VOLTAGE 240-60-3+ HP 3

CONTROL CIRCUIT: S.W.D. _____ VOLTAGE 115-60-1
 CONDUIT: STD. LIQUID TIGHT RIGID WEATHERPROFF (SYSTEM)
 W.C.O.: RS LS W/GAUGE GLASS - TRI-COCKS
MM #157 (M)
 UR. L.W.C.O.: RS LS 16100w w/3004 holder (M)
 WATER COLUMN: RS LS W/GAUGE GLASS - TRI-COCKS
 WATER FEEDER: RS LS
 OPERATING CONTROL GROUP: RS LS RANGE _____
 GAUGE: 6" Marshalltown 0-300# (M)
 W/GAUGE COCK W/TEST COCK
 OPERATING CONTROL L404A 1396 10-150# (M)
 LIMIT CONTROL: L404C 1162(MR) 10-150# (M)
 NIGHT LIMIT W/SWITCH: _____
 FIRING RATE CONTROL L91A 1052 5-150# (M)
 BACK THERMOMETER: 5" STEM LGTH 6" 100-800° (M)
 ARM ISOLATING RELAY

SAFETY VALVE(S): MFG. Kunitz (L)
 (1) Fig 6000 SIZE 1 1/4 x 1 1/2 SET @ 60 PSI
 (1) Fig 6000 SIZE 1 1/2 x 2 SET @ 60 PSI
 () SIZE _____ SET @ _____ PSI
 BOILER FEED VALVES: RS LS (L)
 GATE 9300 O.B. SIZE 1 1/2"
 CHECK #50 4.B. SIZE 1 1/2"
 AUTOMATIC: ELEC. OTHER MOD 2 POS
 BOILER BLOWDOWN VALVE(S): RS LS FRONT REAR
 (1) URBY # 225 T5 SIZE 1 1/4" (L)
 (1) Fig 4000 SIZE 1 1/4"
 WATER COLUMN BLOWDOWN VALVE(S): RS LS RS (M)
 (1) URBY = 225 T5 SIZE 1"
 CONTINUOUS BLOWDOWN VALVE(S): RS LS ()
 _____ SIZE _____
 INJECTOR: RS LS SIZE _____ ()
 W () GATE VALVES _____ SIZE _____ ()
 CHECK VALVE _____ SIZE _____ ()

ORDER TO MEET THE FOLLOWING CODE(S) _____
 FACTORY FIRETEST W/REPORT ASME SHORT FORM
 FACTORY START-UP W/ _____ DAY(S) SUPERVISION
 COMPLETED BY: DWB DATE 4-14-77 (L) SHIPPED LOOSE
 LES: DW 4-14-77 (M) SHIPPED MOUNTED
 SCHEDULED BY: DPC 4-14-77 (P) PREPARED/SHIPPED LOOSE
 RCW: J.L. 4-14-77
 DES FOR: ENC. SALES DEPT. QUALITY CONTROL PLANT MGR.
 SCHED. PURCHASING FINAL ASSY. STOCK ROOM

SPECIAL INSTRUCTIONS:
 TURBULATORS: Full - 2 DIA. DIVERS _____ LGTH.
 SPRAY PAINT: _____ CAN(S) FLUE BRUSH: _____ DIA.
 BOILER: STOCK (PRINTS IN SHOP)
 HYDROSTATIC TEST



SPECIFICATIONS AND DIMENSIONS

BOILER MODEL	2-51	2-76	2-101	2-125	5-156	5-205	5-253	5-304	5-353	5-402	5-508
Horsepower (Nominal)	10	15	20	25	30	40	50	60	70	80	100
MBH	335	502	670	838	1004	1339	1673	2008	2343	2678	3347
lb. Per Hour From and At 212°—Lbs./Hr.	345	517	680	862	1035	1380	1725	2070	2415	2760	3450
Rate:											
1000 BTU—MBH	420	630	840	1050	1260	1680	2100	2520	2940	3360	4200
100 MBH—GPH	3.0	4.5	6.0	7.5	9.0	12	15	18	21	24	30
100 MBH—GPH	Not Available				8.4	11.2	14	16.8	19.6	22.4	28
Heating Surface (A. S. M. E.)—Sq. Ft.	51	76	101	125	156	205	253	304	353	402	508
Water Volume (Firetube Only)—Cu. Ft.	3.1	4.6	6.2	7.6	8.46	11.23	14.02	16.83	19.59	22.2	28.0
Heat Release (Firetube Only)—BTU/Cu. Ft.	135,483	134,385	134,421	137,165	148,936	149,599	149,786	149,732	150,000	150,000	150,000
Water Capacity at N. W. L.—Gal.	73	116	137	171	283	380	438	497	488	560	714
Water Capacity Full—Gal.	80	126	152	190	325	437	495	603	595	681	870
Estimated Shipping Weight—Lbs. (Boiler only)	1750	2245	2975	3300	4200	5300	6000	7000	8500	10000	11500

Dimensions:											
Overall Length	86	106	107	121	114	135	137	155	143	155	181
Overall Width	43	43	47	47	62	62	66	66	74	74	74
Overall Height w/o Safety Valves	53	53	60½	60½	69	69	72	72	81	81	81
Head Length	81	101	102	116	88	101	109	128	110	118	132
Head Width	30	30	34	34	38	38	40	40	50	50	50
Shell Diameter	30	30	34	34	48	48	52	52	60	60	60
Stack (Outside) Diameter	8	8	8	8	10	10	12	12	16	16	16
Furnace (Outside) Diameter	14	14	16	16	18	18	20	20	24	24	24
Steam Supply Size—Low Pressure	2	2½	2½	3	4	4	6*	6*	6*	6*	6*
—High Pressure	1½	1½	1½	1½	2	2	2½	2½	4*	4*	4*
Water Supply and Return Size	2	2	3	3	3	3	4	4	4	4	4
Feedwater Connection—Steam Only	1	1	1	1	1	1	1	1	1½	1½	1½
Blowdown Connection	1	1	1	1	1½	1½	1½	1½	1½	1½	1½
Open to Normal Water Line	45½	45½	49½	49½	56¼	56¼	58¼	58¼	65½	65½	65½

BOILER MODEL	5-625	5-751	5-1024	5-1276	5-1506	5-1758	5-2007	5-2506	5-3004	5-3502	5-3753
Horsepower (Nominal)	125	150	200	250	300	350	400	500	600	700	750
MBH	4184	5021	6695	8368	10042	11716	13390	16737	20085	23450	25140
lb. Per Hour From and At 212°—Lbs./Hr.	4312	5175	6900	8625	10350	12075	13800	17250	20700	24150	25875
Rate:											
1000 BTU—MBH	5250	6300	8400	10500	12600	14700	16800	21000	25200	29400	31500
100 MBH—GPH	37.5	45	60	75	90	105	120	150	180	210	225
100 MBH—GPH	35.0	42	56	70	84	98	112	140	168	196	210
Heating Surface (A. S. M. E.)—Sq. Ft.	625	751	1024	1276	1506	1758	2007	2506	3004	3502	3753
Water Volume (Firetube Only)—Cu. Ft.	39.33	47.52	56.05	70.08	93.58	109.48	112.55	141.10	170.92	196.1	210.48
Heat Release (Firetube Only)—BTU/Cu. Ft.	133,485	132,575	149,866	149,828	134,644	134,271	149,266	148,830	147,437	149,854	149,657
Water Capacity at N. W. L.—Gal.	919	1111	1100	1375	1593	1864	2433	3050	3216	4133	4747
Water Capacity Full—Gal.	1118	1351	1368	1710	2019	2362	2965	3717	4012	5107	5861
Estimated Shipping Weight—Lbs. (Boiler only)	13000	15000	18000	21500	26000	30000	35000	40000	45000	52000	55000

Dimensions:											
Overall Length	174	198	184	213	235	262	234	275	274	284	282
Overall Width	81	81	91	91	97	97	108	108	114	122	130
Overall Height w/o Safety Valves	90	90	99	99	106	106	117	117	123	132	138
Head Length	134	158	143	170	190	217	185	226	228	233	234
Head Width	50½	50½	65½	65½	70½	70½	80	80	87	87	87
Shell Diameter	67	67	77	77	83	83	94	94	100	108	116
Stack (Outside) Diameter	18	18	20	20	24	24	24	24	26	26	26
Furnace (Outside) Diameter	30	30	34	34	38	38	42	42	46	48	50
Steam Supply Size—Low Pressure	8*	8*	10*	10*	10*	10*	12*	12*	12*	12*	12*
—High Pressure	4*	4*	6*	6*	6*	6*	8*	8*	8*	8*	8*
Water Supply and Return Size	6*	6*	6*	6*	8*	8*	10*	10*	10*	10*	10*
Feedwater Connection—Steam Only	2	2	2	2	2	2	2½	2½	2½	3	3
Blowdown Connection	(2) 2**	(2) 2**	(2) 2**	(2) 2**	(2) 2**	(2) 2**	(2) 2**	(2) 2**	(2) 2**	(2) 2**	(2) 2**
Open to Normal Water Line	70¼	70¼	79	79	83¾	83¾	93	93	97	103¼	107¼

Flange ** 2 Blow Downs on Models Above 5-625 Only
 sections threaded as noted

Manway on High Pressure Units Only . . . Handhole on Low Pressure Units

Manway Standard on High & Low Pressure Units

DATE OF SHEET 10/18/88	MANUFACTURER GENERAL ELECTRIC	MFG. MODEL NO. 08-101-900	MFG. SERIAL NO. 1-8292
DATE SOLD 3/28/89	OPERATION USE	PLANT NAME CO. F.	W. C. (F. I.)

AUTOMATIC