

DATE OF INSPECTION
 22 FEB 1985

TYPE OF INSPECTION
 A INTERNAL & EXTERNAL B INTERNAL & EXTERNAL WITH PRESSURE TEST C OPERATIONAL

1 FROM BASE MAINT. OFFICER
 CAMP LEJUNE, N. C.
 2 TO NAVFACENGCOM
 NORFOLK, VA

14. CERTIFICATE ISSUED YES NO
 EXPIRES 22 FEB. 1987
 15. BOILER INSPECTOR
 Thomas L. Lanier
 NAVY OR NATIONAL BOARD NO.

3. MANUFACTURER
 KARGARD

4. PROPERTY NO. PV-26 5. MFG. SERIAL NO. 464602 6. MFG. MODEL NO. 10B. 494826

7. BUILDING NO. TT-41 8. YEAR BUILT 1970 9. CAPACITY 7 cu. FT. VOL.

10. FUEL (Check) 11. PRESSURE
 COAL OIL GAS
 DESIGNED 200 psi OPERATING 140 psi TEST AIR 170 psi

12. FEED WATER TREATMENT 13. TYPE
 SATISFACTORY UNSATISFACTORY
 WATER TUBE FIRE TUBE C. I.

16. REASON FOR NOT ISSUING CERTIFICATE
 NAVFAC 239

17. BOILER USE
 AIR RECEIVER
 19. COMBUSTION
 % CO₂ _____ % EXCESS O₂ _____

18. COMBUSTION CONTROL (Mfg. Name)
 20. FLUE GAS TEMPERATURE
 AFTER BOILER _____ °F ; AFTER HEAT TRAP _____ °F

SAFETY DEVICES
 SAFETY VALVES

21. MANUFACTURER WILLIAMS VALVE CO. 22. NUMBER AND SIZE 1-1/4" 23. PSI SETTING 200 24. CONDITION GOOD

STEAM PRESSURE GAUGE

25. MANUFACTURER U.S. GAGE 26. CORRECTIONS
 WATER LEG CONSTANT _____ psi; OTHER _____ psi
 27. REASON IF NOT TESTED

FIRING EQUIPMENT

ITEM	IN SERVICE	ALTERNATE
28. MANUFACTURER		
29. TYPE		
30. FUEL GRADE		

31. INSPECTOR'S COMMENTS

START & MAINTAIN P.M. LOG.

32. ATTACHMENT(S) (Check)
 COPY OF INSPECTOR'S REPORT SPECIAL COMMENTS

33. SIGNATURE
 J. J. Seller
 BY DIRECTION

DATE OF INSPECTION
 28 Sept. 1982

TYPE OF INSPECTION
 A INTERNAL & EXTERNAL B INTERNAL & EXTERNAL WITH PRESSURE TEST C OPERATIONAL

1. FROM
 BASE MAINT. OFFICER
 CAMP LEJEUNE, N. C.
 2. TO
 NAVFACENGCOM
 NORFOLK, VA

14. CERTIFICATE ISSUED YES NO
 EXPIRES 28 Sept. 1984
 15. BOILER INSPECTOR

Thomas L. Lanier
 NAVY OR NATIONAL BOARD NO.

NAVFAC 239
 16. REASON FOR NOT ISSUING CERTIFICATE

BOILER DATA

3. MANUFACTURER
 KARGARD

4. PROPERTY NO. PV-26	5. MFG. SERIAL NO.	6. MFG. MODEL NO. NB-494826
7. BUILDING NO. IT-41	8. YEAR BUILT 1970	9. CAPACITY 764 FT VOLUME
10. FUEL (Check) <input type="checkbox"/> COAL <input type="checkbox"/> OIL <input type="checkbox"/> GAS		11. PRESSURE DESIGNED 200 psi OPERATING 160 psi TEST 300 psi
12. FEED WATER TREATMENT <input type="checkbox"/> SATISFACTORY <input type="checkbox"/> UNSATISFACTORY		13. TYPE <input type="checkbox"/> WATER TUBE <input type="checkbox"/> FIRE TUBE <input type="checkbox"/> C. I.

17. BOILER USE
 AIR RECEIVER
 18. COMBUSTION CONTROL (Mfg. Name)
 19. COMBUSTION
 _____ % CO₂ _____ % EXCESS O₂
 20. FLUE GAS TEMPERATURE
 AFTER BOILER _____ °F : AFTER HEAT TRAP _____ °F

SAFETY DEVICES

SAFETY VALVES

21. MANUFACTURER
 WILLIAMS VALVE CO.
 22. NUMBER AND SIZE
 1-1/4"
 23. PSI SETTING
 200
 24. CONDITION
 GOOD

25. MANUFACTURER
 U S GAGE
 26. CORRECTIONS
 WATER LEG CONSTANT _____ psi; OTHER _____ psi
 27. REASON IF NOT TESTED

FIRING EQUIPMENT

ITEM	IN SERVICE	ALTERNATE
28. MANUFACTURER		
29. TYPE		
30. FUEL GRADE		

31. INSPECTOR'S COMMENTS
 REPLACED PRESSURE GAGE

32. ATTACHMENT(S) (Check)
 COPY OF INSPECTOR'S REPORT SPECIAL COMMENTS
 33. SIGNATURE
 R.M. Oiler
 BY DIRECTION

DATE OF INSPECTION
 14 AUG 1979

TYPE OF INSPECTION
 A INTERNAL & EXTERNAL B INTERNAL & EXTERNAL WITH PRESSURE TEST C OPERATIONAL

1. FROM BASE MAINT. OFFICER
 CAMP LEJEUNE, N. C.
 2. TO NAVFACENGCOM
 NORFOLK, VA

14. CERTIFICATE ISSUED YES NO
 EXPIRES 14 AUG 1981
 15. BOILER INSPECTOR
 Jesse L. Sellen
 NAVY OR NATIONAL BOARD NO.
 NAUFAC 225
 16. REASON FOR NOT ISSUING CERTIFICATE

BOILER DATA

3. MANUFACTURER
 KARGARD
 4. PROPERTY NO. PV-26
 5. MFG. SERIAL NO. —
 6. MFG. MODEL NO. NB-494826
 7. BUILDING NO. TT-41
 8. YEAR BUILT 1970
 9. CAPACITY 7 CU. FT. VOLUME
 10. FUEL (Check)
 COAL OIL GAS
 11. PRESSURE
 DESIGNED 200 psi OPERATING 160 psi TEST 200 AIR psi
 12. FEED WATER TREATMENT
 SATISFACTORY UNSATISFACTORY
 13. TYPE
 WATER TUBE FIRE TUBE C. I.

17. BOILER USE
 AIR RECEIVER
 18. COMBUSTION CONTROL (Mfg. Name)
 19. COMBUSTION
 % CO₂ _____ % EXCESS O₂ _____
 20. FLUE GAS TEMPERATURE
 AFTER BOILER _____ °F : AFTER HEAT TRAP _____ °F

SAFETY DEVICES
 SAFETY VALVES

21. MANUFACTURER
 WILLIAMS VALVE CO.
 22. NUMBER AND SIZE 1-1/4"
 23. PSI SETTING 200
 24. CONDITION GOOD
 25. MANUFACTURER
 U.S. GAGE
 26. CORRECTIONS
 WATER LEG CONSTANT _____ psi; OTHER _____ psi
 27. REASON IF NOT TESTED

FIRING EQUIPMENT

ITEM	IN SERVICE	ALTERNATE
28. MANUFACTURER		
29. TYPE		
30. FUEL GRADE		

31. INSPECTOR'S COMMENTS

START & MAINTAIN PM LOG-

32. ATTACHMENT(S) (Check)
 COPY OF INSPECTOR'S REPORT SPECIAL COMMENTS

33. SIGNATURE
 R.M. Sellen
 BY DIRECTION

BOILER INSPECTION CHECK LIST

LOCATION MCBCL	BLDG NO. 650°	BOILER NO. TTHA	DATE PV ²⁶ 14 AUG 79
--------------------------	-------------------------	---------------------------	---

BOILER MFG. A KARGARD	OPERATING PRESS. 160	DESIGN PRESS. 200	CAP. 7 CFU
SERIAL NO. TRE KARGARD	MODEL NO.	N.B. NO.	494826

BURNER MFG. US GAGE X	FIRING RATE: 0-200 X
STEAM GAGE NAME: US GAGE X	TEST SHOULD BE 0-300
SV MFG Williams Valve Co	CAP 70 CFM
NO.	1
SIZE	1/4"

NO. 1	SET 200	OPEN 180	CLOSE
NO. 2	SET	OPEN	CLOSE
NO. 3	SET	OPEN	CLOSE

CO2%	02%	STACK TEMP	COMB. EFF.	PURGE TIME
NO. 1 FIREYE	C/O			A/L
NO. 2 FIREYE	C/O			A/L
HI-STEAM TEMP.	C/O			A/L
EXCESS STEAM TEMP.	C/O			A/L
HI OIL TEMP.	C/O			A/L
HI OIL PRESS.	C/O			A/L
LO OIL TEMP.	C/O			A/L
LO OIL PRESS.	C/O			A/L
LO ATOM AIR/STEAM	C/O			A/L
NO. 1 LW	C/O			A/L
NO. 2 LW	C/O			A/L
LO FURNACE DRAFT	C/O			A/L
LO FIRE START	C/O			A/L
TYPE OF FUEL	YEAR BUILT 1970			A/L

Ticked called
 Hold For GAGE

HEAT SURFACE: **Boiler** WATER WALL

REMARKS:
42 x 20
① NEEDS GAGE 0-300

SH **11/69**
 AD **11/41**

