

BOILER INSPECTION CHECK LIST

LOCATION		BLDG NO.	BOILER NO.	DATE
MCAS(H) HMM 362		AS 504	PV-103	13 JUNE 82
BOILER MFG. WOOD IND.	OPERATING PRESS. 125	DESIGN PRESS. 200	CAP. CFV 34.36	
SERIAL NO.	MODEL NO.	N.B. NO. 547764		
BURNER MFG.	FIRING RATE:			
STEAM GAGE NAME: US GALE	PRESS. 0-300		TEST 500 - OK	
SV MFG KUNKLE	CAP-CFM 569	NO. 1	SIZE 3/4"	
NO. 1	SET 175	OPEN	CLOSE	
NO. 2	SET	OPEN	CLOSE	
NO. 3	SET	OPEN	CLOSE	
CO2%	02%	STACK TEMP	COMB. EFF.	PURGE TIME
NO. 1 FIREYE C/O			A/L	
NO. 2 FIREYE C/O			A/L	
HI-STEAM TEMP. C/O			A/L	
EXCESS STEAM TEMP. C/O			A/L	
HI OIL TEMP. C/O			A/L	
HI OIL PRESS. C/O			A/L	
LO OIL TEMP. C/O			A/L	
LO OIL PRESS. C/O			A/L	
LO ATOM AIR/STEAM C/O			A/L	
NO. 1 LW C/O			A/L	
NO. 2 LW C/O			A/L	
LO FURNACE DRAFT C/O			A/L	
LO FIRE START C/O			A/L	
TYPE OF FUEL	YEAR BUILT 1972	A/L		
HEAT SURFACE	Boiler	WATER WALL		

HYDRO-300
 OK
 CERT TO EXPIRE
 13 JUNE 85

- REMARKS:
- ① INSTALLED NEW PRESS GAGE. 200PSI @ 650°F.
 - ② REPLACE ^{LOW} OIL LEVEL C/O SWITCH. SIZE 30" X 84"
 - ③ DRAIN TANK DAILY & INSTALL AUTO DRAIN

