

GYN LOWDER

GYN LOWDER  
6839

BOILER INSPECTION CHECK LIST

21 JUNE @ 0930

LOCATION		BLDG NO.	BOILER NO.	DATE
MCAS (H) H&MS 26		EAST END AS 518	PU-107	21 JUNE 83
BOILER MFG. WOOD	OPERATING PRESS. 100	DESIGN PRESS. 125	CAP. CFV 17	
SERIAL NO.	MODEL NO.	N.B. NO. 405170		
BURNER MFG.	FIRING RATE:			
STEAM GAGE NAME: U.S. GAGE	PRESS. 0-300		TEST 187	
SV MFG. <del>C.O.E.</del> KUNKLE	CAP. CFM 99	NO. 1	SIZE 1/4	
NO. 1	SET 125	OPEN 125	CLOSE	
NO. 2	SET	OPEN	CLOSE	
NO. 3	SET	OPEN	CLOSE	
CO2%	02%	STACK TEMP	COMB. EFF.	PURGE TIME
NO. 1 FIREYE C/O	TESTED - OK CERT. ISSUED			A/L
NO. 2 FIREYE C/O				A/L
HI-STEAM TEMP. C/O				A/L
EXCESS STEAM TEMP. C/O				A/L
HI OIL TEMP. C/O				A/L
HI OIL PRESS. C/O				A/L
LO OIL TEMP. C/O				A/L
LO OIL PRESS. C/O				A/L
LO ATOM AIR/STEAM C/O				A/L
NO. 1 LW C/O				A/L
NO. 2 LW C/O	A/L			
LO FURNACE DRAFT C/O	A/L			
LO FIRE START C/O	A/L			
TYPE OF FUEL	YEAR BUILT 1968	A/L		
HEAT SURFACE	Boiler	WATER WALL		

REMARKS:

SIZE - 24 X 46 = 17 CU FT.

125 PSE @ 650°F

- ① START & MAINTAIN P.M. LOG
- ② DRAIN TANK DAILY.
- ③ INSTALLED NEW SAFETY VALVE.
- ④ CLEAN AIR/COMP & TANK

