

JOB ORDER NO	DATE COMPLETE signed	COST	DESCRIPTION
579-61	1/24/61		Repair and paint exterior
023-03338-820515	4/22/63		Install guards on all elec equip
Contract	7/15/68		Install Collateral Equipment
3546	7-15-74		Annual - assist to Test + flush sprinkler sys
3157	7-10-73		" " " " " " " "
3588	7-11-69		" " " " " " " "
3862	7-6-71		Rpr leaking acid tank
3245 3860	4-11-73		Rpr to heating system
4078	10-3-73	360	Rpr door to drying room
1163	1-9-70	800	Install window head
31507	12-31-68		Repair water main break
31331	11-7-64		Rpl steam valve
31006	8-15-68	585	Rpl 2 condensate pumps
567-118	8-29-66	67	Rpl 2 fan blades
2653	10-10-74	566	Install receptacles
3987	10-21-69	187	Maint + rpr to filtering + heating equip
4157	1-12-71	949	Rpl heating coils
4493	12-12-75	495	Repair steam station
3895	8-28-75	0/E	Repair steam return line under pavement
3278	10/15/74	265	assist fire dept. to test + flush sprinkler
cont # 80-7011	8-25-80		Ext paint
2656	6-13-77	82	Cut 100 Oak stakes for trailers + stake bed trucks
5903	12/22/78	300	Flush sprinkler system
4155	4/7/78	407. ³²	repar elec motor replace bearings to blower
3193	(mp)	404	Replace floor on console
3214	(mp)	182979	Repair (hd)
3238	10/21/79	431	Assist fire dept to test + flush

JOB ORDER NO	DATE COMPLETED	COST	DESCRIPTION
3193	Comp	404	Replc 1100v in rms head
5000	1.16.81	1397	Remove Incandescent stem mount + replace Mercury
4264	11-21-80	1111	Repl unit heaters
3175	11.7.80	463	Assist Fire Dept.
2049	8 April 83	80,995	Replc Pan's Booth Heating
5014	12-19-80	775	Rpr. + PAINT heads
1192	2-26-82	817	Cut deck & install anchors & reflow concrete deck
3768	10-22-82	1133	Lower Existing Pendant Fixtures
4898	7-10-85	22155	Substandard shed - SA Fidy Award
3117	3-8-85	3173	Replc Air compressor worn out in normal serv.
3401	12-7-84	1271	Rpl Condensate Pump
4598	7-22-83	442	make Rep TO INTER. WALLS EXTER. WALLS & DOOR
8525	8-2-94	495	INSTALL OUTLET
3832	7-17-98	19790	RFC REMOVE DUCTS & INSTALL HEATERS
3832	7-17-98	19790	INSTR 6 HEATERS, 1st and delete juve PURGED 99
CLM1	5-31-02	20790.00	remove booth PV #02-135443