

JOB ORDER NO	DATE COMPLETED	COST	DESCRIPTION
5840	9-28-79	4098	Recurring maint to steam dist
3322	1-12-79	341	Make rps to aluminum cover on 3 smoke stacks
4574	1-12-78 1-12-78	1431	Rpt Condensate transfer pump
79-C-4442	9-15-81	3,128.50?	Connection to ventilating system
79-C-4475	7-1-82	201,916. ⁰⁰	Replace Boiler #54 -
3206	12-17-79	154	Remove + Repec burner blower motor
4671	12-28-79	609	Remove/Repec watt bra
4645	12-14-79	801	Repl refractory in Boiler #53
3904	12-5-79	2097	Insulate Boiler
4743	11-21-79	23,019	Request + install water tubes for Boiler
3179	11-9-79	222	Rewind 25 HP burner blower motor
4578	11-7-79	899	Replc smt blower element
3583	1-30-79	299	Ext Replc + pump new wood
3344	11-30-79	1231	Install pulley chain on safety valve
3794	7-27-79	1872	Replc pit cover
3936	9-26-80	402	Install for boiler #53 a phase monitoring relay
4367	6-27-80	316	Rps to elec motor on boiler #53.
3532	4-25-80	382	Remove + rpl elect circuit to boiler feed
4024	10-24-80	917	Make rps rps to Aldg.
4819	11-21-80	1415	Misc. rps to insulation on boiler etc.
4387	Comp	451	Rpl. pulser + sw hd to Corbat Tower.
4254	Comp	4634	Amend to 3207 Rps refractory in boiler #53
4254	12-19-80	1269	Amend to 4254 Rpl/Add valves on main
3728	3-13-80	801	Req. + install rps parts on boiler #53
3653	2-22-80	1026	Rps controls on boiler
4463	8-7-81	713.	Rps refractory in boiler #53
3997	6-5-81	470	Rps refractory in boiler #53
3786	5-7-82	749	Install bypass + drain pipe on steam header

