



NOTE: CENTER TO PARALLEL FINISH GRADE ON

NEW MANHOLE AND NEW POINT OF CHLORINE APPLICATION SEE DETAIL

NEW 12" GATE VALVES AND NEW 12" X 12" X 12" TEE

REMOVE AND SALVAGE EXISTING 12" LINE BETWEEN THESE POINTS

USE THIS PORTION OF EXISTING 12" CIP AS CONDUIT FOR CHLORINE SOLUTION HOSE

PROVIDE TRANSITION BETWEEN EXISTING 12" C.I. MAIN AND NEW 4" V.C. PIPE.

TO F

YHD
859315