



NOTE -
 INSTALL DUCTS ONLY ON RUNWAYS THAT
 HAVE NOT BEEN MADE SURFaced
 ON EXISTING RUNWAYS INSTALL 1-2 CONDUCTOR
 #6-3000V RUBBER SHEATHED CABLE UNDER
 ASPHALT

TYPICAL DUCT INSTALLATION
 Note: Install 2 Ducts Under Each Intersection
 Except Where Otherwise Noted. All Ducts To Be 4" Thick
 Wall Fiber And Shall Have 24" Min. Cover. Ducts Shall
 Extend 30" Min. Beyond Each Edge Of Pavement

BLDG. SCHEDULE

- OFFICERS BARRACKS
- WASHROOM
- MESS HALL
- EXISTED MEN'S BARRACKS
- WASHROOM
- AVIATION OPERATIONS BLDG.
- GASOLINE FACILITIES
- WATER PUMPING STATION

LEGEND

- PRIMARY CIRCUIT - 34 OF 60-7000-HR. TOL. 60KV
- SECONDARY
- PARKWAY CABLE
- SPAN GUY
- DOWN GUY & AVENUE
- PRESENT BUILDINGS
- NEW
- PRESENT POLES
- NEW

NOTES
 1- ALL POLES CHECKING PRIMARY TO BE 35' CL 5' EXCEPT AS NOTED
 2- SECONDARY ONLY TO BE 30' CL 5'
 3- ALL PRIMARY CIRCUITS TO BE 24-36 BARE EXCEPT AS NOTED
 4- ALL GUYS TO HAVE A LEAD OF GUY EXCEPT AS NOTED
 5- POLES MAY BE MOVED 5' IN FIELD IN EVENT OF
 CONFLICTS

6	7-5-43	ADDED SERVICE TO INVENTORY	A.E.B.
5	6-9-43	ADDED OFFICE SPACE IN USE TO INVENTORY	A.E.B.
4	5-18-43	GRANTED ROW FOR ADDITIONAL BLDG PROGRAM	M.P. RYN
3	5-23-43	ADDED TO INVENTORY INVENTORY	A.E.B.
2	1-18-43	RELOCATED 2 POLES	A.E.B.
1	1-8-43	PRIMARY VOLTAGE, NUMBER OF PHASES & TRANS CHANGED	A.E.B.

OUTLYING FIELDS
 NORTH CAROLINA
 OAK GROVE
 ELECTRICAL DISTRIBUTION SYSTEM
 300515

