

TEHM SURVEILLANCE REPORT FORM

Installation MCB - LA SEUNE - HADNOT POINT

Date Collected 21 OCT 80 AM

AVE 34 APPROX.

405P

Source	Sample Number	CHCl ₃	CHCl ₂ Br	CHClBr ₂	CBr ₃	TEHM
WTP	086	18.6	¹³⁸ (8)	5.1	0.3	32
NH-1	087	20.6	¹³⁸ (9)	6.3	0.6	35
1202	088	19.3	¹³⁸ (8)	5.4	0.3	33
65	089	18.8	¹³⁷ (8)	5.5	0.4	33
FC-530	090	18.7	¹³⁶ (8)	5.7	0.4	33
Reference OBS						
True						

Date Received 30 OCT 80

Date Analyzed 31 OCT 80

Remarks: WATER IS HIGHLY CONTAMINATED WITH LOW MOLECULAR WEIGHT HALOGENATED HYDROCARBONS. STRONG INTERFERENCE IN THE REGION OF CHCl₂Br.

William C. Neal, Jr.
 WILLIAM C. NEAL, JR.
 Chief, Laboratory Services

CANNOT ~~NOT~~ DETERMINE TRUE VALUE OF THAT COMPOUND. EXPERIENCE SHOWS THAT THE ^{CLW} TRUE CONCENTRATION IS LOW, SINCE THE 008010010436