

SUMMARY OF TRIHALOMETHANE ANALYSIS

Sample #'s	System	Averages (Units mg/l, Limit=0.10 mg/l)				Compliance*
		July	Jun-Aug	Mar-May	Running Average(2 Qtr)	
165-169	Tarawa Terrace	0.02	0.02	0.01	0.02	yes
179-175	Montford Point	0.01	<0.01	<0.01	<0.01	yes
176-180	New River	0.11	0.11**	0.09	0.10***	yes
181-185	Holcomb Blvd	0.03	0.03	0.04	0.04	yes
186-190	Rifle Range	0.05	0.06**	0.05	0.06***	yes
191-195	Courthouse Bay	0.05	0.05	0.05	0.05	yes
196-200	Onslow Beach	0.05	0.06	0.05	0.06	yes
201-205	Hadnot Point	0.05	0.03	0.04	0.04	yes

\*-Compliance is actually determined from the running annual(4 Qtr) average.  
 \*-This quarter average is incomplete, August sampling results aren't included.  
 \*\*-This running average is incomplete, August sampling results aren't included.

Note MCAS(H) New River continues to be borderline. Please Note attached memo to record for into on extra sampling done of Raw Water wells and in-plant on 17 Aug 82.

CLW

000000611