

0246

29 JUL 1985

ROUTING SLIP

	ACTION	INFO	INITIAL
BMO			
ABMO		✓	RM
ADMIN			
F&A			
MAINT NCO			
M&R			
OPNS			
PROP			
UMACS			
UTIL	✓	✓	
SECRETARY			

COMMENTS:

COPY TO [ KREHD (DANNY SHARPE)  
 ENVR. Eng (AC/S, FAC)  
 (BOB ALEXANDER)

Done  
 7/30/85  
 RM

CLW

0000001283

22 JUL 85

LANTDIV CDR 1142

FILE NUMBER

6280 1142APG

SUBJECT

VGA

REFERENCE

TO: MCB CAMP LEJEUNE  
BASE MAINTENANCE  
ENVIRONMENTAL AFFAIRS  
DIVISION

ENCLOSURE

(1) JTC REPORT  
#99 (REC'D 22 JUL 85)

This form may be used in a window envelope.

VIA \_\_\_\_\_ Endorsement n

FORWARDED  RETURNED  FOLLOW-UP  REQUEST  ADVISE  SUBMIT

X	MESSAGE	X	MESSAGE	X	MESSAGE
<input checked="" type="checkbox"/>	FOR APPROPRIATE ACTION		SUBJECT DOCUMENT(S) WAS/WERE FORWARDED TO YOUR OFFICE _____ AS A MATTER UNDER YOUR JURISDICTION.		CERTIFY ENCLOSURE _____ AS TO RECEIPT AND ACCEPTANCE OF MATERIAL AND FORWARD TO _____
	FOR INFORMATION OR CERTIFICATION AND/OR FILE.		SUBJECT DOCUMENTS WAS/WERE APPROVED _____ AND FORWARDED TO YOU.		_____ COPIES OF SUBJECT CHANGE ORDER AMENDMENT OR MODIFICATION
	<input type="checkbox"/> APPROVED <input type="checkbox"/> DISAPPROVED		_____ COPY(IES) OF THIS CORRESPONDENCE WITH YOUR REPLY.		CHANGE NOTICE TO THE SUPPLIER
	APPROVAL <input type="checkbox"/> IS <input type="checkbox"/> IS NOT RECOMMENDED		ENCLOSURE(S) _____ IS/ARE FORWARDED AS REQUESTED BY REFERENCE _____		_____ COPIES OF APPLICABLE PLANS AND/OR SPECIFICATIONS.
	CONCURRING IN RECOMMENDATIONS MADE IN THE BASIC CORRESPONDENCE.		ENCLOSURE(S) IS/ARE RETURNED FOR CORRECTION AS INDICATED.		FOR PLAN ACTION AS INDICATED
	COMMENTS AND/OR RECOMMENDATIONS.		CORRECTED ENCLOSURE(S) AS REQUESTED		CLASSIFICATIONS OF DEFECTS FOR SUBJECT ITEMS
	MAILING LIST ACTION		SUBJECT PERSON'S ATTENTION SHOULD BE INVITED TO THIS MATTER		CONFIRMATION THAT INSPECTION OR SOURCE INSPECTION IS NOT REQUIRED
	FOR ASSIGNMENT OF BUREAU FILE NUMBER(S)		SUBJECT PERSON(S) REPORTED TO THIS COMMAND _____		INSPECTION UNDER THE SUBJECT SUBCONTRACT IS NOT REQUIRED
	ON A LOAN BASIS - RETURN BY _____		SUBJECT PERSON(S) COMPLETED HIS/HER DUTY AND WAS/WERE DETACHED FROM THIS COMMAND _____		_____ COPIES OF SUBJECT PURCHASE DOCUMENT. IF SOURCE INSPECTION OR PROGRESSING IS REQUIRED
	SIGN ORIGINAL RECEIPT AND RETURN TO THIS OFFICE.		NAME AND LOCATION OF SUPPLIER OF SUBJECT ITEMS.		STATUS OF MATERIAL ON SUBJECT PURCHASE DOCUMENT
	SUBJECT FILES, WHICH ARE LOCATED IN BOX NO. _____ SHIPMENT NO. _____		SUBCONTRACT NUMBER FOR SUBJECT ITEM		CLEARANCE AS INDICATED IN BASIC CORRESPONDENCE VERIFIED. NO REPLY UNLESS NEGATIVE.
	REPLY TO THE ABOVE REFERENCE(S) BY _____		SUBJECT PURCHASE DOCUMENT HAS BEEN REQUESTED AND WILL BE FORWARDED WHEN RECEIVED.		VERIFICATION OF NEED-TO-KNOW FOR VISIT PERSONNEL CLEARANCES VERIFIED.
	_____ COPY(IES) OF REFERENCE DESCRIBED ABOVE WAS/WERE NOT RECEIVED.		ENDORSEMENT _____ OF SUBJECT SUBCONTRACT IS BEING DELAYED PENDING RECEIPT OF BASIC PURCHASE DOCUMENT.		<p><b>CLW</b></p> <p><b>0000001284</b></p>
	SUBJECT DOCUMENT(S) WAS/WERE FORWARDED TO _____		APPROPRIATION SYMBOL SUBHEAD AND CHARGEABLE ACTIVITY		
	SUBJECT DOCUMENT(S) IS/ARE WAS/WERE RETURNED FOR _____		WHETHER SUBJECT ITEMS ARE TO BE COMMERCIALY SHIPPED OR AT GOVERNMENT EXPENSE		
			A CERTIFICATE IN LIEU OF SUBJECT BILL OF LADING WHICH HAS BEEN LOST.		SEE REMARKS ON THE REVERSE SIDE.

COPY TO

114, 1142, 1145

SIGNATURE



REPORT # 99  
LABORATORY ANALYSIS ON  
NAVAL SAMPLES  
(A/E CONTRACT N62470-84-B-6932)  
JTC REPORT # 85-293

PREPARED FOR:  
DEPARTMENT OF THE NAVY  
ATLANTIC DIVISION  
NAVAL FACILITIES ENGINEERING COMMAND  
NORFOLK, VA 23511

PREPARED BY:  
JTC ENVIRONMENTAL CONSULTANTS, INC.  
4 RESEARCH PLACE, SUITE L-10  
ROCKVILLE, MARYLAND 20850

JULY 19, 1985

CLW

0000001285

*Ann E Rosecrance*

Ann E. Rosecrance  
Laboratory Director

JTC Environmental Consultants, Inc.

Date 7/19/85 Report No. 99 to Naval Facilities Engineering Command, Norfolk, Virginia

JTC Data Report No. 85-293 Table 1 Date of Sample Receipt 7-17-85

NAVY SAMPLE ID	JTC SAMPLE ID	ANALYSIS PARAMETER							
		VOA							
HP Treated 7/15/85 10:17	12-1268	see attached sheet							
TI Treated 7/15/85 10:34	12-1269	"							
		0000001286	CLW						



JTC ENVIRONMENTAL CONSULTANTS, INC.  
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

JTC SAMPLE # 12-1268 PROJECT NO. NF-12  
CLIENT SAMPLE ID HP Treated 7/15/85 DATE RECEIVED 7-17-85  
METHOD NO. 624 DETECTION LIMIT 10 ug/lit

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/li
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloropro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	7.8* N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	4.1* N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	14 N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

CLW

000001287

N.D. = NOT DETECTED

N.A. = NOT APPLICABLE/ANALYZED

\*Below method detection limit



JTC ENVIRONMENTAL CONSULTANTS, INC.  
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

JTC SAMPLE # 12-1269 PROJECT NO. NF-12  
CLIENT SAMPLE ID II Treated 7/15/85 DATE RECEIVED 7-17-85  
METHOD NO. 624 DETECTION LIMIT 10 ug/lit

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloropro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	5.3* N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	3.8* N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	7.7* N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	2* N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	CLW N.D.

0000001288

N.D. = NOT DETECTED  
N.A. = NOT APPLICABLE/ANALYZED

\*Below method detection limit