

11330
NREAD
12 Jul 1984

From: Commanding General, Marine Corps Base, Camp Lejeune
To: Commanding Officer, Dental Clinic, Camp Lejeune, NC 28542

Subj: FLUORIDE TESTING OF BASE WATER SUPPLY

Ref: (a) OPNAVINST 11330.1 of 1 Aug 1973

Encl: (1) Semi-Annual Fluoride Well Water Analyses for July 1984

1. In accordance with the reference, the enclosure is forwarded.
These samples were collected and analyzed for fluoride concentration.

J. I. WOOTEN
By direction

Blind copy to:
SupvChem
BMO (Utilities Dir)

CLW
0000004165

Writer: E. Betz, NREAD Ext 5977
Typist: J. Latham, 12 Jul 84

SEMIANNUAL WELL FLUORIDE RECORD

Well #:	mg/l	Well #:	mg/l	Well #:	mg/l	Well #:	mg/l
<u>HP</u> 602	0.20	<u>HP</u> 652	0.21	<u>CG</u> 1000	0.29	<u>CHB</u> 43	0.06
603	0.14	653	0.14	1001	0.14	44	0.07
606	0.18	654	0.10	<u>MCAS</u> 106	1.71	220	0.10
608	0.15	655	0.11	131	0.92	221	0.10
609	0.11	LCH 4006	Out of Service	203	0.52	BB 97	0.09
610	Out of Service	LCH 4007	0.16	4140	0.30	A-5	0.09
613	0.17	<u>HB</u> 643	0.25	4150	0.22	<u>MP</u> 142	0.18
615	Out of Service	644	0.23	5001	0.22	168	Out of Service
616	0.18	645	0.23	5009	0.23	197	0.12
620	0.18	646	0.17	1256(N)	0.23	267	0.12
632	0.08	647	0.13	1255(O)	0.23	628	Out of Service
633	0.14	648	0.15	1254(P)	0.36	629	0.13
634	0.12	649	0.19	1253(Q)	0.44	630	0.10
635	0.12	650	0.14	1251(R)	0.39	<u>TT</u> 25	0.20
636	0.12	<u>CG</u> 100	0.19	190(S)	0.83	26	0.17
637	0.11	201	0.26	191(T)	0.60	30	0.26
638	0.13	325	0.16	<u>OB</u> 164	0.18	31	0.16
639	0.09	502	0.13	BA 190	0.14	52	0.18
640	0.12	504	0.15	<u>RR</u> 45	0.09	53	Caved In
641	0.09	600	0.14	47	0.11	54	0.17
642	0.10	604	0.10	97	0.06	67	0.17
651	0.12	700	0.16				

CLW

0000004166