

National Bureau of Standards

Certificate

Standard Reference Material 4218-E

Point-Source Standard

Radionuclide	Europium-152
Source identification	4218-E-
Source description	Point source on polyester tape (1)*
Activity	Bq
Reference time	1200 EST August 27, 1982
Random uncertainty	0.03 percent (2)
Systematic uncertainty	1.44 percent (3)
Total uncertainty (Random plus systematic)	1.47 percent
Photon-emitting impurities (Activity ratios at reference time)	$^{154}\text{Eu}/^{152}\text{Eu}: (3.5 \pm 0.4) \times 10^{-3}$ (4)
Half life	13.6 ± 0.1 years (5)
Measuring instrument	"4 π " γ pressurized ionization chamber previously calibrated using 20.32-cm diameter NaI(Tl) well crystals

This Standard Reference Material was prepared in the Center for Radiation Research, Nuclear Radiation Division, Radioactivity Group, Dale D. Hoppes, Group Leader.

Washington, D.C.
November, 1982

George A. Uriano, Chief
Office of Standard Reference Materials

*Notes on back

FOOTNOTES

- (1) The point source support is a 5.4-cm diameter by 1-mm thick aluminum annulus supporting a 0.006-cm-thick layer of polyester tape. The active source is a 3-mm diameter dried deposit of europium, as the chloride, covered with another layer of the same tape.
- (2) Half the 99-percent confidence interval of the mean (2.64 times the standard error computed from 80 ionization-chamber measurements).
- (3) Linear sum of estimated uncertainty limits due to:
- | | |
|------------------------------------|--------------|
| a) NaI(Tl) detector efficiency | 0.54 percent |
| b) fluorescence yield | 0.18 percent |
| c) impurities | 0.20 percent |
| d) decay correction | 0.02 percent |
| e) gravimetric measurements | 0.30 percent |
| f) ionization-chamber measurements | 0.20 percent |
- (4) The limit of detection, expressed as a percentage of the gamma-ray-emission rate of the 1408-keV gamma rays emitted in the decay of europium-152, is
- 0.1 percent between 90 and 1900 keV,
- provided that the impurity photons are separated in energy by 5 keV or more from photons emitted in the decay of europium-152 and europium-154.
- (5) NBS-measured half-life value. The value recommended by the Oak Ridge Nuclear Data Project is 13.6 ± 0.2 years [Radioactive Decay Data Tables, D.C. Kocher (ed.) DOE/TIC-11026, 157 (1981).].

For further information please call Dr. Bert M. Coursey or Dr. Larry L. Lucas at 301-921-2665.